

ITEM	SIZE	RATING	TYPE	MATL	REMARKS	NOTES
A	2"	N.P.T.	W.F.	C.S.	PRIMARY	SUCTION
B	3"	N.P.T.	W.F.	C.S.	PRIMARY	EMERGENCY VENT
C	2"	N.P.T.	W.F.	C.S.	PRIMARY	UPDRAFT VENT
D	2"	N.P.T.	W.F.	C.S.	SECONDARY	THREAD PROTECTOR
E	3"	N.P.T.	W.F.	C.S.	SECONDARY	EMERGENCY VENT
F	1"	N.P.T.	W.F.	C.S.	SECONDARY	DIPSTICK
G	2"	N.P.T.	W.F.	C.S.	PRIMARY	40" AT-A-GLANCE GAUGE

**NOTES:**

- A. Quantity:
- B. Material: H.R. Carbon Steel.
- C. Design Pressure: Atmospheric.
- D. Design Temperature: Ambient.
- E. Built & labeled per U.L. spec. #142.
- F. Exterior: Gray primer included; see Sales Order for top coat.
- G. All fittings to be protected for shipment.
- H. Customer to verify nozzle sizes, locations and quantities.
- I. Saddles/skids may require shimming or grouting during installation.

\*All pages of this Schedule A are incorporated by reference and are a part of the additional terms of the Master Terms & Conditions of Sale.  
[www.newberrytanks.com/masterterms.pdf](http://www.newberrytanks.com/masterterms.pdf)


APPROVAL FOR CONSTRUCTION  
 SCHEDULE A - MASTER TERMS & CONDITIONS OF SALE\*

APPROVED AS DRAWN.

APPROVED WITH NOTED CHANGES, CONSTRUCTION WILL BE SCHEDULED WHEN SIGNED DRAWING AND CONFIRMED ORDER ARE RECEIVED.

SIGNATURE: \_\_\_\_\_

DATE: \_\_\_\_\_

SALES ORDER # xxxxx		Weight (lbs):	
<small>All units inches unless stated otherwise</small>  Phone: 870-735-4473 Fax: 870-735-3982			
VESSEL DESCRIPTION: 200 GALLON RECTANGULAR UL-142 DOUBLE WALL TANK			
CUSTOMER:		P.O.#	
DATE: 7/18/16	SCALE: DNS	DWG.# FTDW-200	REV 00
DRAWN BY: TC		CHKD. BY: TB	