


ITEM	SIZE	RATING	TYPE	MATL	REMARKS	NOTES
A	2"	N.P.T.	W.F.	C.S.	THREAD	PROTECTOR
B	2"	N.P.T.	W.F.	C.S.	STREET ELBOW	SUCTION
C	3"	N.P.T.	W.F.	C.S.	EMERGENCY	VENT
D	2"	N.P.T.	W.F.	C.S.	-	HEATER

NOTE:
 1. HEATER MUST BE POINTED TOWARDS CENTER OF TANK
 2. HEATER MUST BE INSTALLED 1/4" FROM BOTTOM OF TANK

- NOTES:**
- A. Quantity:
 - B. Material: 12 GA H.R. Carbon Steel.
 - C. Design Pressure: Atmospheric.
 - D. Design Temperature: Ambient.
 - E. Exterior: Gray primer included; see Sales Order for top coat.
 - F. All fittings to be protected for shipment.
 - G. Customer to verify nozzle sizes, locations and quantities.
 - H. Saddles/skids may require shimming or grouting during installation.

*All pages of this Schedule A are incorporated by reference and are a part of the additional terms of the Master Terms & Conditions of Sale.
www.newberrytanks.com/masterterms.pdf

APPROVAL FOR CONSTRUCTION SCHEDULE A - MASTER TERMS & CONDITIONS OF SALE* <input type="checkbox"/> APPROVED AS DRAWN. <input type="checkbox"/> APPROVED WITH NOTED CHANGES, CONSTRUCTION WILL BE SCHEDULED WHEN SIGNED DRAWING AND CONFIRMED ORDER ARE RECEIVED. SIGNATURE: _____ DATE: _____		SALES ORDER # xxxxx Weight (lbs): _____  Phone: 870-735-4473 Fax: 870-735-3982 VESSEL DESCRIPTION: 75 GALLON SINGLE WALL STORAGE TANK CUSTOMER: _____ P.O.# _____ DATE: 6/14/16 SCALE: DNS DWG.# FTCT-0075 REV 00 DRAWN BY: TC CHKD. BY: TB
--	--	---