

7 March 2016

Ref: 29664/TL/DD/gb

Contact: Don Duan

Phone: +61 3 9580 4500

E-mail: dduan@aga.asn.au



Mr Kai Huang
Yong Xiang Copper Products (Aust) Pty Ltd
2, 24 Waverley road
Chadstone VIC 3148

Dear Mr Huang,

**Re: 216 and 2302 Series Manual Shut-off Valves
AGA Application 15434 / AGA Certificate 7914**

Further to our Test Programme letter dated 16 July 2015, and your most recent communications with our office, I acknowledge receipt of CGAC's test reports 2015F-0154, 2015F-0156, 2015F-0157 and 2015F-0155.

Following review, I confirm all test results are satisfactory. We have successfully conducted Final Inspection on the sample received on 3/4/2016. I confirm no further assessment is required.

All work for this project is now complete, and I am pleased to enclose the following:

- Revised AGA Certificate **7914**
- Revised Specification Issue **02**
- Details of the certification entry as it will appear in the "Directory of AGA Certified Products", as found on our website www.aga.asn.au.

Yours Sincerely,

A handwritten signature in black ink, appearing to read 'Billy Tabourlos', is located below the 'Yours Sincerely,' text.

Billy (Vasilios) Tabourlos
Group Manager, Technical Operations

CC: Kelly (sale6@yongxiangvalve.com)



AGA CERTIFIED PRODUCT

JAS-ANZ



www.jas-anz.org/register

Certificate Holder: **YONG XIANG COPPER PRODUCTS (AUST) PTY LTD**

ABN/ACN No. (if applicable): **131 499 379**

Manufacturer: **NINGBO YONG XIANG COPPER PIPELINE CO., LTD**

Agent (if applicable): **N/A**

Type of Component: **MANUALLY OPERATED SHUT-OFF VALVE
TYPE 1 RWP 2500 kPa
TEMP: 0 – 60°**

Model No. & Description: **H
216 SERIES**
(Refer www.aga.asn.au for more details)

Model Designation:

Model	DN6	DN8	DN10	DN15	DN20	DN25	DN32	DN40	DN50	DN65	DN80	DN100
216	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
216T		✓	✓	✓	✓							
216TMF		✓	✓	✓	✓	✓						
216MFLS					✓	✓						
216LS					✓							
216LMF				✓	✓	✓						
216A				✓	✓	✓	✓	✓	✓			
2302				✓	✓							
2302A				✓								

Relevant Standard(s): **AS 4617 – 2004 (Including Amendment 1)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- This Certificate remains the property of the AGA; and
- The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



Reviewing Officer

Certificate Authorised

Certificate first issued: **26 July 2012**

Certificate No: **7914**

This copy valid from: **7 March 2016**

Refer specification issue: **02**

Directory Certificate Entry

Components	
Manual Shut-Off Valves	
Type 1 - Isolating Valves	

Yong Xiang Copper Products (Aust) Pty Ltd
(2, 24 Waverley road, Chadstone, 3148 VIC AUSTRALIA Ph: 03 9525 1445)

Relevant Standard/s: AS 4617 | 2004 Amdt 1 | Manual Shut-Off Gas Valves | 9/03/2011

H

7914 7.12

<i>H 216 Series Manually Operated Shut-Off Valve - Type 1</i>	<i>kPa Rating</i>
<i>Models:</i>	
216 - DN6, DN8, DN10, DN15, DN20, DN25, DN32, DN40, DN50, DN65, DN80, DN100	2500
216T - DN8, DN10, DN15, DN20	2500
216TMF - DN8, DN10, DN15, DN20, DN25	2500
216MFLS - DN20, DN25	2500
216LS - DN20	2500
216LMF - DN15, DN20, DN25	2500
216A - DN15, DN20, DN25, DN32, DN40, DN50	2500
2302 - DN15, DN20	2500
2302A - DN15	2500

Temperature Range: 0°C - 60°C

Tuesday, 8 March 2016