QF722/1

The Australian Gas Association

Specification

The Component described in this Specification

complies with the certification requirements of

The Australian Gas Association

A Company Limited by Guarantee ACN: 004 206 044

Brand Name: **H**

Model Designation:

Model	DN6	DN8	DN10	DN15	DN20	DN25	DN32	DN40	DN50	DN65	DN80	DN100
216	✔	✔	✔	✔	✔	✔	✔	✔	✔	✔	✔	✔
216T		✔	✔	✔	✔							
216TMF		✔	✔	✔	✔	✔						
216MFLS					✔	✔						
216LS					✔							
216LMF				✔	✔	✔						
216A				✔	✔	✔	✔	✔	✔			
2302				✔	✔							
2302A				✔								

Type of Component: **MANUALLY OPERATED SHUT-OFF VALVE – TYPE 1**
RWP 2500 kPa **Temperature 0 – 60°**

Code of Compliance: **AS 4617 – 2004 (Including Amendment 1)**
Approval Requirements for Manual shut off gas valves

Manufacturer: **NINGBO YONG XIANG COPPER PIPELINE CO., LTD**

Agent: **N/A**

Certificate Holder: **YONG XIANG COPPER PRODUCTS (AUST) PTY LTD**
ACN: 131 499 379

Test Laboratory: **SELECT SOLUTIONS CGAC**

Report No: **4617038-12** **2015F-0154, 2015F-0156, 2015F-0157, 2015F-0155**

REVISED:	7/3/16	Addition of models: 2302, 2302A, 216A, 216LMF, 216LS, 216MFLS, 216TMF, 216T.

Date of Certification: **26 July 2012** Certificate No: **7914 - 02**

SPECIFICATIONS CHECKED: DATE: 7/3/2016