



## Product certificate K67799/05

Issued 2020-08-01

Replaces K67799/04

Page 1 of 3

### Heat Exchangers

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Joulia SA

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

**BRL-K656:** "Heat exchangers intended for the indirect heating of drinking water", d.d. 2012-02-01.

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

# CERTIFICATE

287180711

**Kiwa Nederland B.V.**  
Sir Winston Churchillaan 273  
P.O.Box 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[info@kiwa.nl](mailto:info@kiwa.nl)  
[www.kiwa.nl](http://www.kiwa.nl)

**Supplier**  
Joulia SA  
Zentralstrasse 115  
2503 BIEL  
Zwitzerland  
Tel. +32 366 6423  
[info@joulia.com](mailto:info@joulia.com)  
[www.joulia.com](http://www.joulia.com)



**Certification process  
consists of initial and  
regular assessment of:**

- quality system
- product

## Heat Exchangers

**PRODUCT SPECIFICATION**

The products mentioned below belong to this technical approval-with-product certificate

| Product:             | Joulia Inline 3P | Joulia Inline 5P | Joulia Tinline 6P |    |     |    | Joulia Tinline 10P |    |     |    |
|----------------------|------------------|------------------|-------------------|----|-----|----|--------------------|----|-----|----|
| Nominal Length: (mm) | 630              | 630              | 630               |    | 830 |    | 630                |    | 830 |    |
| Version: (HF/LF)     | -                | -                | HF                | LF | HF  | LF | HF                 | LF | HF  | LF |

**Fitness for contact with drinking water**

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

**MARKING**

The Kiwa®-mark products are marked with the word mark "KIWA ".

Place of the mark:

- On the Manual Sticker of the Siphonhood

Compulsory specifications:

- Trade mark/type or logo;
- Construction (single-partition/double-partition) ;
- Intended purpose of use of the connection ends;
- Year of manufacture;
- Primary side working pressure;
- Secondary side working pressure;
- Maximum secondary water temperature;

Remark: The type of connection ends may be also described in the installation instructions, if it is ensured that no mistake can be made between which is the primary side and which is the secondary side.

Method of marking:

- Non-erasable;
- Visible after assembly.

**APPLICATION AND USE**

The heat exchangers are intended to be used in hot water installations with a working pressure of maximum 1 MPa (10 bar) and a water temperature of maximum 90 °C.

## Heat Exchangers

---

### **RECOMMENDATIONS FOR CUSTOMERS**

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Joulia SA
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.