Nuwave LLC

TEST REPORT

SCOPE OF WORK

Removal Rate Testing - Air Purifier - [See the Page 2 Model(s)]

REPORT NUMBER

211221146GZU-002

ISSUE DATE [REVISED DATE]

22-Aug-2022 None

PAGES

12

DOCUMENT CONTROL NUMBER

AP-US-TRF_V5.1[31-05-2021] ©2021 INTERTEK





Test Report

Report Number 211221146GZU-002

Test Laboratory Name / Address Intertek Testing Services Shenzhen Ltd. Guangzhou Branch

Room 02, & 101/E201/E301/E401/E501/E601/E701/E801 of Room 01 1-8/F., No.7-2, Caipin Road, Science City, GETDD, Guangzhou, Guangdong, China

Applicant Name / Address Nuwave LLC

560 Bunker Ct., Vernon Hills, IL 60061 USA

Manufacturing Name / Address Not provided

Product Air Purifier

Brand Name Nuwave Oxypure

Description The product covered by this report is a cord connected indoor used only Air

Purifier.

Model(s) (if applicable) 475**

Model Similarity ** may be two numbers; all models are identical except for the specific model

name

Rated voltage (V) 100-240~ Rated frequency (Hz) 50-60 Rated power (W) 12

Date of receipt of sample(s)

Date of test

Sample Condition

18-Jan-2022

26-Jan-2022

Prototype

Test standard(s) or criteria(s) Refer to ANSI/AHAM AC-1-2020 & Special Requirements of the Applicant.

Conclusion No conclusion for this test report.

Date of issue 22-Aug-2022

Date of revision None

Prepared by: Approved by:

Elvis Cai

Elvis Cai

Engineer Sr. Supervisor

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

The test report only allows to be revised only within the report defined retention period unless standard or regulation was withdrawn or invalid. When determining the test result, measurement uncertainty has been considered.

Effective date:31-May-2021



Test Equipment List:

Equipment Name	Туре	Number	Calibration Date	Due Date
Laser Aerosol Spectrometer	3340	SA016-23-04	2022/3/1	2023/2/28
Aerodynamic Particle Sizer	3321	SA016-23-05	2022/1/27	2023/1/26
Fluidized Bed Aerosol Generator	3400A	SA016-23-05	2022/6/3	2023/6/2
Air Cleaner testing Chamber		SA016-23	2022/6/3	2023/6/2

Device Under Test Description:

The device(s) tested for this report were/was Model 475**

The following device settings were used during testing: 120V/60Hz, Speed 3, Tested on the Table





Unit in test

Control Panel View



Filter view

Adaptor



Results of pollutants remove rate for Cigarette Smoke:

Monitored particle size ranges for the Cigarette Smoke particulates were: 0.1-1 microns.

Time			Cigarette smoke		
(min)	0.1µm	0.11µm	0.12µm	0.13µm	0.14µm
10	52.90%	57.18%	58.84%	61.32%	61.31%
20	81.87%	83.67%	85.54%	85.80%	86.55%
30	93.19%	93.90%	95.14%	95.43%	95.76%
40	97.65%	98.02%	98.12%	98.39%	98.24%
50	99.16%	99.24%	99.45%	99.37%	99.36%
60	99.76%	99.79%	99.72%	99.82%	99.93%
70	99.90%	99.91%	99.93%	99.88%	99.90%
80	99.98%	99.99%	99.95%	100.00%	99.95%
90	100.00%	99.99%	100.00%	100.00%	99.98%
100	100.00%	100.00%	100.00%	100.00%	100.00%
110	100.00%	100.00%	100.00%	100.00%	100.00%
120	100.00%	100.00%	100.00%	100.00%	100.00%
Time			Cigarette smoke		
(min)	0.15µm	0.16µm	0.17µm	0.18µm	0.19µm
10	63.61%	62.85%	67.06%	65.53%	62.42%
20	87.38%	87.18%	88.38%	89.17%	89.22%
30	96.00%	95.89%	96.27%	95.73%	95.55%
40	98.71%	98.92%	98.61%	99.02%	98.93%
50	99.43%	99.33%	99.33%	99.54%	99.73%
60	99.76%	99.85%	99.86%	99.87%	99.73%
70	99.88%	99.96%	99.95%	100.00%	100.00%
80	100.00%	100.00%	100.00%	100.00%	100.00%
90	100.00%	100.00%	100.00%	100.00%	100.00%
100	100.00%	100.00%	100.00%	100.00%	100.00%
110	100.00%	100.00%	100.00%	100.00%	100.00%
120	100.00%	100.00%	100.00%	100.00%	100.00%
Time			Cigarette smoke		
(min)	0.2µm	0.225µm	0.25µm	0.275μm	0.3µm
10	65.99%	61.74%	67.86%	76.25%	70.59%
20	88.82%	88.45%	88.95%	91.25%	88.23%
30	96.31%	97.18%	97.43%	96.88%	100.00%
40	98.87%	98.72%	99.49%	99.38%	100.00%
50	99.70%	99.49%	100.00%	100.00%	100.00%
60	99.94%	99.87%	100.00%	100.00%	100.00%
70	100.00%	100.00%	100.00%	100.00%	100.00%
80	100.00%	100.00%	100.00%	100.00%	100.00%
90	100.00%	100.00%	100.00%	100.00%	100.00%
100	100.00%	100.00%	100.00%	100.00%	100.00%
110	100.00%	100.00%	100.00%	100.00%	100.00%
120	100.00%	100.00%	100.00%	100.00%	100.00%




Results of pollutants remove rate for Cigarette Smoke:

Monitored particle size ranges for the Cigarette Smoke particulates were: 0.1-1 microns.

Time			Cigarette smoke		
(min)	0.325µm	0.35µm	0.4µm	0.45µm	0.5µm
10	74.00%	77.14%	70.00%	44.44%	100.00%
20	94.00%	94.29%	90.00%	77.78%	100.00%
30	98.00%	100.00%	95.00%	100.00%	100.00%
40	100.00%	100.00%	100.00%	100.00%	100.00%
50	100.00%	100.00%	100.00%	100.00%	100.00%
60	100.00%	100.00%	100.00%	100.00%	100.00%
70	100.00%	100.00%	100.00%	100.00%	100.00%
80	100.00%	100.00%	100.00%	100.00%	100.00%
90	100.00%	100.00%	100.00%	100.00%	100.00%
100	100.00%	100.00%	100.00%	100.00%	100.00%
110	100.00%	100.00%	100.00%	100.00%	100.00%
120	100.00%	100.00%	100.00%	100.00%	100.00%
	100.0070	100.0070	100.0070		
Time	100.0070	100.0070	Cigarette smoke		
	0.6µm	0.7μm		0.9µm	1µm
Time			Cigarette smoke		
Time (min)	0.6µm	0.7µm	Cigarette smoke 0.8µm	0.9µm	1µm
Time (min)	<mark>0.6µm</mark> 60.00%	<mark>0.7μm</mark> 75.00%	Cigarette smoke 0.8µm 100.00%	<mark>0.9µт</mark> 100.00%	<mark>1μm</mark> 100.00%
Time (min) 10 20	0.6µm 60.00% 100.00%	0.7μm 75.00% 100.00%	Cigarette smoke 0.8μm 100.00% 100.00%	0.9μm 100.00% 100.00%	1μm 100.00% 100.00%
Time (min) 10 20 30	0.6µm 60.00% 100.00% 100.00%	0.7μm 75.00% 100.00% 100.00%	Cigarette smoke 0.8µm 100.00% 100.00% 100.00%	0.9μm 100.00% 100.00% 100.00%	1μm 100.00% 100.00% 100.00%
Time (min) 10 20 30 40	0.6μm 60.00% 100.00% 100.00% 100.00%	0.7μm 75.00% 100.00% 100.00% 100.00%	Cigarette smoke 0.8µm 100.00% 100.00% 100.00% 100.00%	0.9µm 100.00% 100.00% 100.00%	1μm 100.00% 100.00% 100.00% 100.00%
Time (min) 10 20 30 40 50	0.6µm 60.00% 100.00% 100.00% 100.00%	0.7μm 75.00% 100.00% 100.00% 100.00%	Cigarette smoke 0.8µm 100.00% 100.00% 100.00% 100.00% 100.00%	0.9μm 100.00% 100.00% 100.00% 100.00%	1μm 100.00% 100.00% 100.00% 100.00%
Time (min) 10 20 30 40 50 60	0.6µm 60.00% 100.00% 100.00% 100.00% 100.00%	0.7μm 75.00% 100.00% 100.00% 100.00% 100.00%	Cigarette smoke 0.8µm 100.00% 100.00% 100.00% 100.00% 100.00% 100.00%	0.9μm 100.00% 100.00% 100.00% 100.00% 100.00%	1μm 100.00% 100.00% 100.00% 100.00% 100.00%
Time (min) 10 20 30 40 50 60 70	0.6µm 60.00% 100.00% 100.00% 100.00% 100.00% 100.00%	0.7μm 75.00% 100.00% 100.00% 100.00% 100.00% 100.00%	Cigarette smoke 0.8µm 100.00% 100.00% 100.00% 100.00% 100.00% 100.00%	0.9μm 100.00% 100.00% 100.00% 100.00% 100.00%	1μm 100.00% 100.00% 100.00% 100.00% 100.00% 100.00%
Time (min) 10 20 30 40 50 60 70 80	0.6µm 60.00% 100.00% 100.00% 100.00% 100.00% 100.00% 100.00%	0.7μm 75.00% 100.00% 100.00% 100.00% 100.00% 100.00% 100.00%	Cigarette smoke 0.8µm 100.00% 100.00% 100.00% 100.00% 100.00% 100.00% 100.00%	0.9μm 100.00% 100.00% 100.00% 100.00% 100.00% 100.00%	1μm 100.00% 100.00% 100.00% 100.00% 100.00% 100.00%
Time (min) 10 20 30 40 50 60 70 80 90	0.6µm 60.00% 100.00% 100.00% 100.00% 100.00% 100.00% 100.00% 100.00%	0.7μm 75.00% 100.00% 100.00% 100.00% 100.00% 100.00% 100.00%	Cigarette smoke 0.8µm 100.00% 100.00% 100.00% 100.00% 100.00% 100.00% 100.00% 100.00%	0.9μm 100.00% 100.00% 100.00% 100.00% 100.00% 100.00% 100.00%	1μm 100.00% 100.00% 100.00% 100.00% 100.00% 100.00% 100.00% 100.00%



Curve of average remove rate for Cigarette Smoke





Results of pollutants remove rate for Dust:

Monitored particle size ranges for the Dust particulates were: 0.5-3 microns.

Times			Duct		
Time (min)	<0.523μm	0.542µm	Dust 0.583µm	0.626µm	0.673µm
10	66.63%	67.72%	69.03%	68.59%	68.65%
20	88.93%	89.11%	89.04%	89.62%	89.14%
30	95.63%	96.24%	96.33%	96.24%	96.00%
40	98.70%	98.61%	98.88%	98.68%	98.63%
50	99.49%	99.57%		99.64%	
60	99.49%	99.75%	99.70% 99.87%	99.74%	99.62% 99.86%
70					99.80%
70 80	99.93%	99.87%	99.89%	99.91%	
90	99.96%	99.95%	99.96%	99.98%	99.93%
100	99.98%	100.00%	99.98%	99.98%	99.97%
	100.00%	100.00%	100.00%	99.98%	99.97%
110	100.00%	100.00%	100.00%	100.00%	100.00%
120	100.00%	100.00%	100.00%	100.00%	100.00%
Time			Dust		
(min)	0.723µm	0.777µm	0.835µm	0.898µm	0.965µm
10	67.71%	68.15%	68.09%	66.28%	67.61%
20	88.43%	88.33%	89.26%	88.73%	88.87%
30	95.79%	96.48%	96.26%	96.09%	97.10%
40	98.82%	98.43%	98.76%	98.61%	98.86%
50	99.65%	99.59%	99.63%	99.72%	99.41%
60	99.85%	99.81%	99.82%	99.76%	99.80%
70	99.98%	99.91%	99.94%	99.88%	99.91%
80	99.98%	99.95%	99.96%	99.98%	99.94%
90	100.00%	100.00%	99.96%	99.98%	99.97%
100	100.00%	100.00%	99.98%	100.00%	100.00%
110	100.00%	100.00%	99.98%	100.00%	100.00%
120	100.00%	100.00%	100.00%	100.00%	100.00%
Time			Dust		
(min)	1.037µm	1.114µm	1.197µm	1.286µm	1.382µm
10	66.95%	69.19%	68.77%	65.71%	70.83%
20	88.69%	89.84%	88.33%	89.02%	90.91%
30	96.32%	96.67%	97.35%	97.14%	97.70%
40	99.27%	99.13%	99.04%	98.89%	98.90%
50	99.65%	99.64%	99.58%	99.44%	99.80%
60	99.77%	99.77%	99.82%	99.92%	99.80%
70	100.00%	99.86%	99.94%	99.92%	100.00%
80	100.00%	99.86%	100.00%	99.92%	100.00%
90	100.00%	99.95%	100.00%	100.00%	100.00%
100	100.00%	99.95%	100.00%	100.00%	100.00%
110	100.00%	100.00%	100.00%	100.00%	100.00%
120	100.00%	100.00%	100.00%	100.00%	100.00%




Results of pollutants remove rate for Dust:

Monitored particle size ranges for the Dust particulates were: 0.5-3 microns.

1.981µm
75.86%
92.41%
99.31%
99.31%
99.31%
100.00%
100.00%
100.00%
100.00%
100.00%
100.00%
100.00%
2.839µm
50.00%
87.50%
87.50%
87.50% 100.00%
100.00%
100.00% 100.00%
100.00% 100.00% 100.00%
100.00% 100.00% 100.00% 100.00%
100.00% 100.00% 100.00% 100.00%
100.00% 100.00% 100.00% 100.00% 100.00%



Total Quality. Assured. Curve of average remove rate for Dust






Results of pollutants remove rate for Pollen:

Monitored particle size ranges for the Pollen particulates were: 5-11 microns.

Time	140	0-002, 475°°°, 120V/6	Pollen		
(min)	5.048µm	5.425µm	5.829µm	6.264µm	6.732µm
10	73.61%	83.75%	81.51%	80.31%	82.53%
20	97.22%	96.25%	97.48%	98.45%	97.47%
30	100.00%	100.00%	100.00%	100.00%	100.00%
40	100.00%	100.00%	100.00%	100.00%	100.00%
50	100.00%	100.00%	100.00%	100.00%	100.00%
60	100.00%	100.00%	100.00%	100.00%	100.00%
70	100.00%	100.00%	100.00%	100.00%	100.00%
80	100.00%	100.00%	100.00%	100.00%	100.00%
90	100.00%	100.00%	100.00%	100.00%	100.00%
100	100.00%	100.00%	100.00%	100.00%	100.00%
110	100.00%	100.00%	100.00%	100.00%	100.00%
120	100.00%	100.00%	100.00%	100.00%	100.00%
Time			Pollen		
(min)	7.234µm	7.774µm	8.354µm	8.977µm	9.647µm
10	87.77%	90.79%	92.45%	95.25%	95.44%
20	98.34%	98.67%	99.59%	98.93%	100.00%
30	100.00%	99.84%	100.00%	99.69%	100.00%
40	100.00%	100.00%	100.00%	100.00%	100.00%
50	100.00%	100.00%	100.00%	100.00%	100.00%
60	100.00%	100.00%	100.00%	100.00%	100.00%
70	100.00%	100.00%	100.00%	100.00%	100.00%
80	100.00%	100.00%	100.00%	100.00%	100.00%
90	100.00%	100.00%	100.00%	100.00%	100.00%
100	100.00%	100.00%	100.00%	100.00%	100.00%
110	100.00%	100.00%	100.00%	100.00%	100.00%
120	100.00%	100.00%	100.00%	100.00%	100.00%
Time			Pollen		
(min)	10.37µm	11.14µm			
10	96.15%	96.97%			
20	100.00%	100.00%			
30	100.00%	100.00%			
40	100.00%	100.00%			
50	100.00%	100.00%			
60	100.00%	100.00%			
70	100.00%	100.00%			
80	100.00%	100.00%			
90	100.00%	100.00%			
100	100.00%	100.00%			
110	100.00%	100.00%			
120	100.00%	100.00%			



Total Quality. Assured. Curve of average remove rate for Pollen





Revision Summary

Date/	Project Handler/	ltom	Description of change
Proj # Site ID	Reviewer	Item	Description of change
			None

****** End of Report *******