

CERTIFICATE OF CONFORMITY

This is to certify that

Allegion (Southeast Asia) Pte Ltd

31 Ubi Road 1
#07-01
Singapore 408694
UEN: 200007123E

has been assessed and found to meet the requirements of PLS - Scheme Type 5 for

Product: Controlled Door Closing Device
(Concealed Door Closer)

Brand: BRITON

Model: C2800

Country of Origin: China

Product Details: Fixed power sized rack and pinion concealed door closer without back check function with sliding arm
Suitable for use on 240mins uninsulated fire rated doors
Classification of Coding System:

3	8	3	1	1	0
---	---	---	---	---	---

See COC Appendix (1 Page) for Fire Performance

Test Standard(s): SS 332:2018 Clause 6 (Annex C)

Test Report(s): Intertek No. 190726006SHF-001
Sirim No. 2022FE0472-S1

This certificate issued in accordance with SCDF Fire Code 2018 requirements.



Eric Law

Head of Certification

For and on behalf of Element Testing Services (S) Pte Ltd

Certificate number:
21A0440

Issue number: 01

Date of initial certification:
21 July 2020

Date of revision:
24 August 2023

Expiry date:
20 July 2026

Page 1 of 2

Issuing Office: 249 Jalan Boon Lay Singapore 619523
Registered Office: 249 Jalan Boon Lay Singapore 619523
UEN 198004219D

This certificate remains the property of Element Testing Services (S) Pte Ltd.

This certificate and all copies or reproductions of the certificate shall be returned to Element Testing Services (S) Pte Ltd or destroyed if requested.

Further clarification regarding the scope of this certificate and verification of the certificate is available through Element Testing Services (S) Pte Ltd or at the above address or at <https://www.certificationsingapore.element.com/>

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation number PD-2010-12. This Certificate is part of a full report and should be read in conjunction with it.

For further information on Element Testing Services (S) Pte Ltd activities covered by SAC accreditation can be accessed at: <https://www.sac-accreditation.gov.sg/accredited-org/certified-cab-companies>

Certificate number:
21A0440

Issue number: 01



Date of initial certification:
21 July 2021

Date of revision:
24 August 2023

Expiry date:
20 July 2026

Page 2 of 2

Appendix

Product Details:

Fixed power sized rack and pinion concealed door closer
without back check function with sliding arm
Classification of coding system for concealed door closer as per below

<u>1st Digit</u> Category of Use	<u>2nd Digit</u> Test Duration	<u>3rd Digit</u> Door Closer Power Size	<u>4th Digit</u> Fire Resistance	<u>5th Digit</u> Essential requirements of safety use	<u>6th Digit</u> Corrosion Resistance
3	8	3	1	1	0
Grade 3 For closing door from 105°	Grade 8 500,000 cycles	Power Sizes: 3 (Can be used on fire rated doors)	Grade 1 *Suitable for 240mins uninsulated fire rated doors.	Grade 1 Satisfied essential requirements of safety use	Grade 0 no defined corrosion resistance

Please refer to Sirim No. 2022FE0472-S1 for more details.