
5



4

NO.	DESCRIPTION		
1	SEISMIC FRAME V4 - 30''W x 30''D		
2	MOUNTING RAIL CAGE-NUT 4.25" FOR BRUSH	4	
3	VERTICAL CABLE MGT 3.25 x 5		
4	VERTICAL CABLE MGT / U.A.C 6"	1	
5	TOP COVER FOR BRUSH	1	
6	TOP FRONT COVER PLATE	2	
7	TOP COVER MIDDLE Z4	1	
8	PERFORATED DOOR	1	
9	SPLIT DOOR PERF. RH	1	
10	SPLIT DOOR PERF. L.H.	1	
11	SHIM	8	
12	HALF SPLIT SIDE PANEL 30"D - OPTIONAL	2	

1 - CERTIFIED TO BELLCORE GR-63-CORE

2 - FINISH: TEXTURED POWEDER COAT

3 - CABINET MUST BE ANCHORED USING 4 SEISMIC RATED ANCHORS (NOT INCLUDED).


4 - FRAME MAT'L: 11 GA. (.120") COLD ROLLED STEEL


* SUBSTITUTE **RU** WITH ACTUAL NUMBER OF RACKUNITS.

PROUDLY MANUFACTURED IN CANADA. VITAINED IN THIS PROPERTY OF INC. ANY T OR AS A WHOLE ERMISSION OF INC IS PROHIBITED.	DRAWN BY: E.D.						
	CHECKED BY: E.D.	SEISMIC CABINET V4 - NETWORK CFG - 30''W x 30''D					
	PROJECT: G:\\$WDwgs\Cabinets\Zone_4_Etroit\EnsemblesReseau\			RLE: CabZ4_25xRUx30_2747-003_Eng			
	SEE TABLE		DRAWING NO.: 2747-003	REV.:	scale: 1:20	DATE: 2019-07-10	sheet: 1 / 2
		3					

CabZ4_25xRUx30_2747-003_Eng

PART NO.	RU	HEIGHT
CBZKI4-254230	42	79 11/16
CBZKI4-254430	44	83 3/16
CBZKI4-254830	48	90 3/16





.D.	SEISMIC CABINET V4 - NETWORK CFG - 30''W x 30''D							
.D.								
:\SWDwgs\Cc	ubinets\Zone_4_Etroit\EnsemblesReseau\		nue: CabZ4_25xRUx30_2747-003_Eng					
TNO.: EE TABLE		DRAWING NO.: 2747-003	REV.:	scale: 1:20	DATE: 2019-07-10	sheet: 2 / 2		
	3							