

MoldShield™

12 Months Durability Test Report

Determining Resistance of Synthetic Material to Fungi



STC Test Report

Date : 2018-03-01
No. : HC18030026

Applicant (Code: 01312550) : Prime-Label Janitorial Services Limited
Unit A 8/F Lucky Horse Industrial Building
64 Tong Mei Road
Mongkok Kln HK

Description of Sample(s) : One submitted sample said to be Prime-Living MoldShield Durable Non-toxic Anti-Mold Coating.
Country of Origin : USA

Sample(s) Received Condition(s): In intact original package under ambient temperature

Date Sample(s) Received : 2017-02-24

Date Tested : 2018-02-01 to 2018-02-28 於使用後12個月作測試

Investigation Requested : Standard Practice for Determining Resistance of Synthetic Materials to Fungi

Method(s) Used : ASTM G21-2013

Test Result(s):

Prime-Living MoldShield Durable Non-toxic Anti-Mold Coating	Rating* at the specific period of incubation (Day 28)
No growth	0

0 – None (no growth on specimen surface)

LEE Paul

Authorized Signatory
Chemical and Food Department
For and on behalf of

The Hong Kong Standards and Testing Centre Ltd.



The Hong Kong Standards and Testing Centre Limited

10 Dai Wang Street, Tai Po Industrial Estate, Tai Po, N.T., Hong Kong

Tel: +852 2666 1838 | Fax: +852 2664 4353 | Email: hkstc@hkstc.org | Website: www.stc-group.org

This report shall not be reproduced unless with prior written approval from The Hong Kong Standards and Testing Centre Limited.

For Conditions of Issuance of this test report, please refer to the overleaf and Website.