



UL Verification Services Inc.  
7036 Snowdrift Road  
Allentown, PA 18106  
610-774-1300



## In-Situ Test Report

Relevant Standards  
UL1598-2008

Prepared For  
**LED Waves, LLC**  
Tiago Zeitoune  
The Equire Building at 41st St, 4100 1st  
Avenue, 3rd Floor North  
Brooklyn, NY 11232-2022

Catalog Number  
LW30-EZ40-W5000K-Hood

Test Number  
1179950

Test Date

2015-11-18

Prepared By

*Derek Smarr*

Derek Smarr, Technician

Approved By

*Kyle Spaziani*

Kyle Spaziani, Project Handler

The results contained in this report pertain only to the tested sample.  
This report shall not be reproduced, except in full, without written approval of Underwriters Laboratories.

This report must not be used by the client to claim product certification, approval, or endorsement by  
NVLAP, NIST, or any agency of the Federal Government.



UL Verification Services Inc.  
7036 Snowdrift Road  
Allentown, PA 18106  
610-774-1300



Luminaire Description: Cast aluminum housing, prismatic glass lens enclosure  
Catalog Number: LW30-EZ40-W5000K-hood  
Lamp: One white LED  
Mounting: Wall Mount  
Ballast/Driver: One FSP Group FSP60-ZZAE(110)U

Luminaire



#### Summary of Results

LED Temperature: 64.2 °C  
Driver Temperature: 46.1 °C  
Maximum LED Current: 1.111 A

#### Test Conditions

Test Temperature: 23.3 °C  
Voltage: 120.0 VAC  
Frequency: 60 Hz


Temperatures are offset to an ambient temperature of 25°C as described in UL1598-2008.



UL Verification Services Inc.  
7036 Snowdrift Road  
Allentown, PA 18106  
610-774-1300



LED Temperature Location



Driver Temperature Location

