


				WATEN USAGE		LELOTHICAL								
С	ondenser	Model		ter Temp 24 hours 90°/ 70°F	Potable Gal. per 100 lbs. 90°/ 70°F	Condenser Gal. per 100 lbs. 90°/ 70°F	kWh Used per 100 lbs. 90°/ 70°F	Min. Circuit/ Max. Fuse Size	Amperage	Voltage	Circuit Wires (including ground)	Heat Rejection BTU/hr.	Refrigerant Charge Amount	Net / Ship Weight (Ibs.)
	Air	FD-650MAJ-C	634	495	12.0	N/A	5.50	20A	11.3A	115V/60/1	3	6,800	12.3 oz.	176 / 185
	Water	FD-650MWJ-C	622	520	12.0	95.3	4.02	20A	7.9A	115V/60/1	3	5,400	15 oz.	176 / 185
	Remote	FD-650MRJZ-C	588	470	12.0	N/A	4.95	20A	10.9A	115V/60/1	3	5,900	2 lbs. 3.3 oz. 4 lb. 1 oz.*	176 / 185
													*(with condenser)	

**Cube Dimensions\*** 



\* approximate size in inches, image not to scale

## **Operating Limits**

- Ambient Temp Range 45 100°F
  Water Temp Range 45 90°F
- Water Pressure 10 113 PSIG
- Voltage Range 104-127V
- If GFCI is required, a GFCI breaker MUST be used in lieu of GFCI receptacle

## Service

- Panels easily removed and all components accessible for service.
- Allow 24"(61 cm) clearance at top for removal of auger and 6" (15 cm) clearance at rear and sides for proper air circulation and ease of maintenance/service.

## Plumbing


- Icemaker Water Supply Line: Minimum 1/4" Nominal ID Copper Water Tubing or Equivalent
- Icemaker Drain Line: Minimum 3/4" Nominal ID Hard Pipe or Equivalent

Water-Cooled Model (Lines Must Be Independent of Icemaker)

- Condenser Water Supply Line: Minimum 1/4" Nominal ID Copper Water Tubing or Equivalent
- Condenser Drain/Return Line: Minimum 1/4" Nominal ID Hard Pipe (open drain system) or Copper Water Tubing (closed loop system) or Equivalent

Hoshizaki reserves the right to change specifications without notice.





© HOSHIZAKI AMERICA, INC. 618 Hwy, 74 S., Peachtree City, GA 30269 | TEL 800-438-6087 | FAX 800-345-1325 | www.hoshizakiamerica.com