



Certificate of Compliance

Certificate: 1460656

Master Contract: 219995

Project: 70029142

Date Issued: April 30, 2015

Issued to: R.C. Systems Co., Inc.

8621 Hwy 6

Hitchcock, TX 77563

USA

Attention: Roger Carter

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Konstantin Rybalko

Issued by: Konstantin Rybalko

PRODUCTS

CLASS 4828 01 - SIGNAL APPLIANCES - - Combustible Gas Detection Instruments-For Hazardous Locations

CLASS 4828 01 - SIGNAL APPLIANCES - Combustible Gas Detection Instruments – For Hazardous Locations

CLASS 4828 81 - SIGNAL APPLIANCES - Combustible Gas Detection Instruments – For Hazardous Locations -Certified to U.S. Standards

Class I, Div. 2, Groups A, B, C and D;

Dual Channel Controller, Model: ST-90/DUAL, 9000 and HA-20; Rated Input: 100-240Vac, 50/60Hz, 0.80Amps, 40 Watts or 10-30Vdc 5 Watts, Solid State relay contacts rated 250Vac, 2.0 Amp, Optional mechanical relay contacts rated 250Vac, 5.0 Amp; All other signal circuits all SELV, T4@ -25°C to +60°C, installation category II, pollution degree 3. May be used with the following optional boards: 4-20mA Analog output pcb Module # 10-0223, Electrochemical sensor input pcb Module # 10-0220, Catalytic Bead sensor input pcb Module # 10-0219 (1000 ppm max input), Catalytic/EC sensor input pcb Module # 10-0216 (1000 ppm max input), Analog Input pcb Module # 10-0221 and Discrete Relay PCB Module # 10-0222.

Quad Channel Controller. Model: ST-90/QUAD, GDA-400, RigProtector and HA-40, Rated Input: 100-240Vac, 50/60Hz, 0.80Amps, 40 Watts or 10-30Vdc 5 Watts, Solid State relay contacts rated 250Vac,



Certificate: 1460656

Master Contract: 219995

Project: 70029142

Date Issued: April 30, 2015

2.0 Amp, Optional mechanical relay contacts rated 250Vac, 5.0 Amp; All other signal circuits all SELV, T4@ -25°C to +60°C, installation category II, pollution degree 3. May be used with the following optional boards: 4-20mA Analog output pcb Module # 10-0308, Bridge sensor input pcb Module# 10-0309 (1000 ppm max input for catalytic bead), Analog Input pcb Module # 10-0221/4 and Discrete Relay PCB Module # 10-0222. May be fitted with an optional internal 50 Watt power supply and FHSS Wireless Interface boards 10-0328 and 10-0355.

CLASS 4828 02 - SIGNAL APPLIANCES - Toxic Gas Detection Instruments - For Hazardous Locations

CLASS 4828 82 - SIGNAL APPLIANCES - Toxic Gas Detection Instruments - For Hazardous Locations – Certified to U.S. Standards

Class I, Div. 2, Groups A, B, C and D;

Dual Channel Controller, Model: ST-90/DUAL, 9000 and HA-20; Rated Input: 100-240Vac, 50/60Hz, 0.80Amps, 40 Watts or 10-30Vdc 5 Watts, Solid State relay contacts rated 250Vac, 2.0 Amp, Optional mechanical relay contacts rated 250Vac, 5.0 Amp; All other signal circuits all SELV, T4@-25°C to +60°C, installation category II, pollution degree 3. May be used with the following optional boards: 4-20mA Analog output pcb Module # 10-0223, Electrochemical sensor input pcb Module # 10-0220), Analog Input pcb Module # 10-0221, and Discrete Relay PCB Module # 10-0222.

Quad Channel Controller. Model: ST-90/QUAD, GDA-400, RigProtector and HA-40, Rated Input: 100-240Vac, 50/60Hz, 0.80Amps, 40 Watts or 10-30Vdc 5 Watts, Solid State relay contacts rated 250Vac, 2.0 Amp, Optional mechanical relay contacts rated 250Vac, 5.0 Amp; All other signal circuits all SELV, T4@ -25°C to +60°C, installation category II, pollution degree 3. May be used with the following optional boards: 4-20mA Analog output pcb Module # 10-0308, Bridge sensor input pcb Module# 10-0309, Analog Input pcb Module # 10-0221/4 and Discrete Relay PCB Module # 10-0222. May be fitted with an optional internal 50 Watt power supply and FHSS Wireless Interface boards 10-0328 and 10-0355.

Wave Link Receiver (WLR). Wireless controller; Rated Input: 100-240Vac, 50/60Hz, 0.80Amps, 40 Watts or 10-30Vdc 5 Watts, Solid State relay contacts rated 250Vac, 2.0 Amp, Optional mechanical relay contacts rated 250Vac, 5.0 Amp; All other signal circuits all SELV, T4@ -25°C to +60°C, installation category II, pollution degree 3. Incorporates Discrete Relay PCB Module # 10-0222 and Multi Function Board # 10-0410 with optional Ethernet Board # 10-0476. May be fitted with an optional internal 50 Watt power supply and FHSS Wireless Interface boards 10-0328 and 10-0355.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 1010.1-92 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements.



Certificate: 1460656

Master Contract: 219995

Project: 70029142

Date Issued: April 30, 2015

CAN/CSA-C22.2 No. 1010.1B-97 - Amendment 2 to CAN/CSA-C22.2 No. 1010.1-92, "Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements"

ANSI/ISA-82.02.01 1999 - Safety Standards for Electrical and Electronic Test, Measuring, Controlling and Related Equipment - General Requirements.

CSA-C22.2 No. 142-M1987 - Process Control Equipment

CAN/CSA-C22.2 No. 152-M1984 - Combustible Gas Detection Instruments

ANSI/ISA-12.13.01-2000 - Performance Requirements for Combustible Gas Detectors.

CSA-C22.2 No. 213-M1987 -Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

ANSI/ISA-12.12.01-2010 - Non-Incendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations.