

# Stronghold GRP Premium System

## Fire Test Certificate



In accordance with BS 476-3:2004 the roof system tested shall be classified as: EXT.F.AA

Test description	BS 476-3:2004
Tester	The Glass Fibre Roofing Company Ltd Unit 33 Pontywindy Industrial Estate, Caerphilly CF83 3HU
Test reference number	3022
Product Classification	EXT.F.AA
Test date	26/02/2021

The product comprises a GRP laminate on a timber substrate. For the product classification to remain valid the complete Stronghold GRP Waterproofing System must be used to the following specification. All materials must be applied as specified in the Stronghold Installation Guide.

		Application rate
Component layer1	Timber substrate, 18mm OSB3 T&G4	
Component layer 2	Stronghold 600g CSM	0.6 kg per m <sup>2</sup>
	Stronghold Premium Resin	2.5 kg per m <sup>2</sup>
Component layer 3	Stronghold Premium Top coat RAL7011 (dark grey)	0.5 kg per m <sup>2</sup>
	Stronghold GRP Roofing Trims	

### Signatories

Testing officer			
Name	Richard Frost BEng (Hon)		
Position	Technical officer		
Signed		Date	26/02/2021
Counter signature			
Name	Michael Frost		
Position	MD		
Signed		Date	26/02/2021