NO.	ITEM	QTY.	MATERIAL	NOTES
1	LEG	4	304 SS	
2	INLET	1	304 SS	3″ FLANGE
3	SHELL	1	304 SS	
4	LID	1	304 SS	
5	VENT	1	304 SS	$\frac{1}{4}$ " NPT
6	SWING BOLTS	6	304 SS	M12
7	O-RING	1	EPDM	
8	BRACKETS	6	304 SS	
9	INLET PRESSURE PORT	1	304 SS	$\frac{1}{2}$ " NPT
10	OUTLET PRESSURE PORT	1	304 SS	$\frac{1}{2}$ " NPT
11	OUTLET	1	304 SS	3″ FLANGE

NOTES:


- 1. PRM FILTRATION IS ONLY A SUPPLIER OF THIS EQUIPMENT.
- 2. PRM IS NOT RESPONSIBLE FOR SPECIFYING THIS PRODUCT FOR THE APPLICATION.
- 3. BUYERS AND/OR USER SHOULD REQUIRE AN ENGINEER FOR ENSURING THAT THE PROPER EQUIPMENT IS INSTALLED FOR THE APPLICATION INCLUDING ALL PROPER SAFETY PRACTICES.
- 4. PRM IS NOT RESPONSIBLE FOR ANY DAMAGES TO PROPERTY AND/OR INJURY/DEATH RELATED TO IMPROPER INSTALLATION. FILTRATION EQUIPMENT INSTALLATIONS SHOULD ALWAYS INCLUDE ANCILLARY SAFETY DEVICES AND/OR OPERATIONAL PRACTICES.
- 5. IT IS AGREED THAT PRM NOR ITS OWNERS HAVE LIABILITY WITH THE INSTALLATION AND OPERATION OF THESE OR OTHER PRODUCTS PURCHASED FROM PRM.
- 6. ALLOW UP TO $\frac{1}{4}$ " TOLERANCE ON ALL MEASUREMENTS.

Product Recovery Management Inc.

This information is proprietary and confidential.

No copies or reproductions allowed without the express written consent of PRM, Inc.

7. MODEL LINK: https://a360.co/3PXq1Ad



6 10" <u>7</u>,, 7,, 10 NO. REVISION

D-1

10/03/2023

SHEET TI

304 SS 40" 7 CARTRIDGE HOUSING BFCARTSSC28304X