

Stainless Steel Multi Cartridge Filter Housings



Multi-Cartridge Filter Housings work by evenly distributing unfiltered water around the filter cartridges. Suspended solids are captured in the filters and the filtered water exits through the outlet. PRM Stainless Steel Cartridge housings use industry standard 2.5 Inch x 20 Inch cartridge filters.

Part Number: BFCARTSSC10304X

Multi Cartridge Stainless Steel Housing

- Uses (5) 2.5" x 20" Filter Cartridges
- Inlet/Outlet: 2 Inch FNPT
- Flow Rate: 60 GPM

Features:

- 304 Stainless Steel Housing
- 2 Inch NPT Inlet/Outlet Connections
- 1/2 Inch NPT Drain Connections
- Filtration for Silt, Odor, Sediment, and More
- Easily Cleaned and Maintained
- Accepts standard length cartridges
- Air vent for use before start-up or draining
- Accepts complete range of filter media
- Silicone O-Rings
- Operating pressure: 108 psig max.
- Operating temperature: 40° - 140°F



REPLACEMENT FILTERS AVAILABLE

PRM 2.5" x 20" spun polypropylene sediment filters are kept in stock for quick delivery.

Available in a variety of micron ratings and sizes. PRM spun polypropylene sediment filters meet NSF standards.

Cartridge Filters with activated carbon or special resin filled units designed specifically for removal of tannins, PFOS/PFAS, arsenic and more can be found at PRM Online Store:

shop.prmfiltration.com

(888-TREAT-IT) • www.prmfiltration.com • sales@prmfiltration.com

NO.	ITEM	QTY.	MATERIAL	NOTES
1	LEG	4	304 SS	
2	INLET	1	304 SS	2" NPT
3	SHELL	1	304 SS	
4	LID	1	304 SS	
5	VENT	1	304 SS	1" NPT
6	SWING BOLTS	6	304 SS	M12
7	O-RING	1	EPDM	
8	BRACKETS	6	304 SS	
9	INLET PRESSURE PORT	1	304 SS	1" NPT
10	OUTLET PRESSURE PORT	1	304 SS	2" NPT
11	OUTLET	1	304 SS	2" NPT

NOTES:

1. PRM FILTRATION IS ONLY A SUPPLIER OF THIS EQUIPMENT.
2. PRM IS NOT RESPONSIBLE FOR SPECIFYING THIS PRODUCT FOR THE APPLICATION.
3. BUYERS AND/OR USER SHOULD REQUIRE AN ENGINEER FOR ENSURING THAT THE PROPER EQUIPMENT IS INSTALLED FOR THE APPLICATION INCLUDING ALL PROPER SAFETY PRACTICES.
4. PRM IS NOT RESPONSIBLE FOR ANY DAMAGES TO PROPERTY AND/OR INJURY/DEATH RELATED TO IMPROPER INSTALLATION. FILTRATION EQUIPMENT INSTALLATIONS SHOULD ALWAYS INCLUDE ANCILLARY SAFETY DEVICES AND/OR OPERATIONAL PRACTICES. IT IS AGREED THAT PRM NOR ITS OWNERS HAVE LIABILITY WITH THE INSTALLATION AND OPERATION OF THESE OR OTHER PRODUCTS PURCHASED FROM PRM.
5. ALLOW UP TO $\frac{1}{4}$ " TOLERANCE ON ALL MEASUREMENTS.
6. MODEL LINK: <https://a360.co/3r6xgMv>
- 7.

