

Sample Description:

Specimen No.	SGS Sample ID	Description
1	GZF22-024397.001	Equipment

Air virus elimination effect
 Test Method: T/SAEPI 005-2020
 Test results:

Virus and host cell	Action Time	Serial Number	Air virus content (TCID ₅₀ /m ³)	Removal rate (%)
Influenza A virus H1N1 (A/PR/8/ 34) (ATCC VR-1469) Host cell : MDCK	0h(CK)	1	2.44×10 ⁶	-
		2	2.44×10 ⁶	-
		3	2.33×10 ⁶	-
	1h	1	<97.3	>99.99
		2	<97.3	>99.99
		3	<97.3	>99.99

Remark:

- 1.The natural decay of the microorganisms in the air has been eliminated.
- 2.The test was carried out by external laboratory assessed as competent.
- 3.The maximum gear of the prototype was turned on and tested in a 30 m³ test chamber.

