

Date of valid edition
2017-04-19

No:
5085

Date of first issue
2009-08-25

Reference

Name and address of certificate holder

Kaczmarek Malewo Sp.J.
Malewo 1
PL-63 800 Gostyn

Conformity mark covered by certificate



Information regarding certificate holder/manufacturer

Contact person Jakub Roszak	Telephone +48 602 651 151	Telefax +48 65 5723 530
	E-mail j.roszak@kaczmarek2.pl	
Manufacturer Kaczmarek Malewo Sp.J.	Place of manufacture Gostyn, Poland	

Product covered by the certificate

Type of product Plastics piping systems for water supply, and for drainage and sewerage under pressure – Polyethylene (PE)	Standard Normative document EN 12201:2011	Specific rules INSTA SBC EN 12201
--	---	---

Specification of product

PE80

SDR class	11	17
Nominal outside diameter	16 - 63 mm	16 - 63 mm
Size group	1	1

PE100

SDR class	11	17	26
Nominal outside diameter	16 - 630 mm	16 - 1600 mm	16 - 1600 mm
Size group	1, 2, 3	1, 2, 3, 4	1, 2, 3, 4

Confidential information according to the enclosure

The certificate holder above is hereby given permission to use the INSTA-CERT mark on or in connection with products, which fulfil the requirements of the standard or the normative document specified above (what is said in this document about INSTA-CERT mark will also be valid for marks defined in relevant SBC). The certificate is valid on the condition that the certificate holder complies with the "General rules for certification by partners of INSTA-CERT" (GRC) and the specific rules applying to certification of products of the type mentioned. The certificate holder is obliged to indemnify INSTA-CERT partners of any claim for damages or any other expenses to which partners may become liable as a result of injuries caused by a product manufactured or sold by the licensee. This also applies to defective or faulty products.

Unless terminated, the certificate will be automatically extended for one year at a time. The certificate will be re-issued with a new "date of valid edition" only if the content and/or conditions of the certificate have been changed. Termination may take place to the end of a year subject to three months' notice on the part of the certificate holder and the certification body.

The certificate is not transferable.

MEMBER OF INSTA-CERT

**RISE Research Institutes of Sweden AB
Certification**

Lennart Månsson