

IS THE WATER FROM THE MUNICIPAL AQUEDUCT FLUORIDATED?



DO YOU HAVE THE ANALYSIS RESULTS FOR IRON, TOTAL HARDNESS, ALKALINITY AND PH OF THE WATER DISTRIBUTED BY THE WATER AUTHORITY?



Iron: 0

Total hardness: 27 mg/l

Alkalinity: 18 mg/l

pH: 7.2

DO YOU DO A LEAD ANALYSIS IN THE WATER?

