



Technical Data

Document Reference
Data Sheet

R1310

RAMCRO - BMS-HFFR-TC Cable For standard applications, flame retardant.

Single pair, LSZH/FRNC-Insulation, Collective Screened, LSZH/FRNC-Sheath

MAS0107HXEEN-T-RB

Application

LSZH - FRNC sheathed multi-conductor cables are suitable for Building Management Systems (BMS), Sound, Audio, Security, Safety, Control and Instrumentation.


Construction

		Unit	Nominal Value
Formation	1 Pair		
Section	22 AWG		
Conductor	Tinned copper wire, 7 strand	mm	0,7
Insulation	Thermoplastic Low Smoke, Halogen Free - LSZH (FRNC)	mm	1,6
Colour Code	Black, White		
Individual Screen	N.A.		
Wrapping	at least 1 layer of plastic tape 0,023 mm		
Collective Screen	0,026 mm Aluminium / PETP tape over tinned copper drain wire		
Inner Sheath	N.A.		
Armour	N.A.		
Outer Sheath	Thermoplastic Low Smoke, Halogen Free - LSZH (FRNC) - Purple RAL 4005	mm	4,5
Cable Printing	RAMCRO ITALY R1310 DATA LAN CABLE - M-BUS - 1PR 22 AWG SCREENED LSZH (FRNC) 300 V 75 C IEC 60332-3-24 -MAS0107HXEEN-T-RB - 'PROD.WEEK/18' + BATCH + METER MARKING		

Technical Data & Standard References

Fire Propagation:		Type of Cable:	BMS-HFFR-TC Cable
- Test on single cable	IEC 60332-1	Low Voltage Directive	2014/35/UE
- Test on bunched cables	IEC 60332-3	Other References:	
Smoke Density	IEC 61034		
Amount of halogen acc. to IEC 60754-1 & EN 50267-1	ZERO		
Acidity (ph value) and conductivity	IEC 60754-2		
Sunlight resistance	UL 1581 section 1200		
Notes			

Electrical & Mechanical Data

Conductor Cross-section	Nom.	22 AWG	Temperature Range:		
DC Resistance per core at 20° C	max Ω/km	57,4	During Operation	° C	-30°C up to 80°C
Insulation Resistance at 20° C	min MΩ*km	25	During Installation	° C	-30°C up to 80°C
Nominal Mutual Capacitance	max pF/m	130	Min. Bending Radius	mm	8 x cable diameter
Inductance	max mH/km	1	Max Pulling Tension	N/mm2	32
Test Voltage - Core/Core	V	2000	Weight Approx	kg/km	26
Test Voltage - Core/Screen	V	2000	Operating Voltage	V	300
Operating Voltage	V	300	Put up length	mt	305

Issued by: RAMCRO S.p.A.



Date of issue:

Prepared by RAMCRO Tech

Via Marzorati, 15 - 20014 Nerviano - Milan - Italy / www.ramcro.it

06/02/2019 00:00

Creator: LDG

Transfer to third parties only under authorization by Ramcro S.p.A.

Empty Form

Printing errors excepted. Subject to alterations.