

FINAL REPORT

This report supersedes the following issued reports:

150993, 151097.

Report ID : 151306

Report Information

Submitting Organisation : 00121524 : Esdan Plastics Pty Ltd
Account : 142513 : Esdan Plastics Pty Ltd
AWQC Reference : 142513-2014-CSR-1 : Prod Test: 12 mm Diameter Drinking Water Hose
Project Reference : PT-2514
Product Designation : Esdan Caravan/Drinking Water Hose 12mm (16/07/14 SD5195 16:02)
Composition of Product : Flexible Plastic.
Product Manufacturer : Esdan Plastics Pty Ltd., Hammond Road, Dandenong, Victoria, AUSTRALIA.
Use of Product : In-Line/Drinking Water Hose.
Sample Selection: As provided by the submitting organisation.
Testing Requested : **AS/NZS 4020:2005 TESTING OF PRODUCTS FOR USE IN CONTACT WITH DRINKING WATER**
Product Type : Composite
Samples : Samples were prepared and controlled as described in Appendix A of AS/NZS 4020:2005
Extracts : Extracts were prepared as described in Appendix C, D, E, F, G, H.
Project Completion Date : 13-Feb-2015
Project Comment : The results presented herein demonstrate compliance of Esdan Caravan/Drinking Water Hose 12mm (16/07/14 SD5195 16:02) to AS/NZS 4020 when exposed at area to volume ratios up to 334,730 mm²/L at 20° ± 2°C.

PLEASE NOTE THAT THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL

THE RESULTS STATED IN THIS REPORT RELATE TO THE SAMPLE OF THE PRODUCT SUBMITTED FOR TESTING. ANY CHANGES IN THE MATERIAL FORMULATION, PROCESS OF MANUFACTURE, THE METHOD OF APPLICATION, OR THE SURFACE AREA-TO-VOLUME RATIO IN THE END USE, COULD AFFECT THE SUITABILITY OF THE PRODUCT FOR USE IN CONTACT WITH DRINKING WATER



Michael Glasson
APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance with ISO/IEC 17025