

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Divine Hardwood Flooring, LLC

2350750 Ryan Road, Rocky View, AB, Canada

For the following product(s):

Vinyl Tile:

Journey Loose Lay Vinyl, Passage WPC Tile, Quest SPC Plank, Voyage II WPC Chevron, Voyage II WPC Plank

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m^3 (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-04970

Valid from: June 1, 2023 to May 31, 2024

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA