Device Manual









### FEATURES

CASAMBI LED DIMMER Power input: 12-24-48 Vdc Voltage Output for stripLED and LED module WHITE, MONOCOLOR, DYNAMIC WHITE AND DIM TO WARM Light Control Command: CASAMBI APP Local Command: N° 2 Button Normally Open Control voltage output for R Minimum brightness level: down to 0,5% PWM Modulation Frequency PWM <u>4000Hz</u> <u>Linear / Logarithmic</u> adjustment curve depending on the set Fixture Soft start and soft stop Soft dimming regulation Extended temperature range 100% Functional Test

### PRODUCT DESCRIPTION

The SLIM-2CV-CASAMBI is a 2-channel output dimmerLED, controllable via Bluetooth thanks to the Casambi APP or locally through two normally open buttons.

The dimmerLED is suitable for driving loads such as StripLED and LED modules, White, monochromatic colour, Dynamic White and Dim to Warm at constant voltage. It's possible to connect a power supply at 12-24-48 Vdc.

The maximum value of the output current is equal to 10A. The dimmerLED has the following protections: over-power protection, under-power protection, reverse polarity protection and input fuse protection.

Through the CASAMBI APP, the SLIM-2CV-CASAMBI allows you to make from simple brightness adjustments, to more complex lighting control systems, thanks to the creation of multiple scenarios, animations, timers, daylight controls, etc.

The CASAMBI APP can be downloaded for free from the Apple App Store and the Google Play Store.









DISTRIBUTED BY Wired 4 Signs USA +1 (865) 339 4956 info@w4susa.com





### PRODUCT CODE

CODE	SUPPLY VOLTAGE	OUTPUT LED	N° OF CHANNELS	TYPE OF COMMAND
SLIM-2CV-CASAMBI	12-24-48 VDC	2 x 5A (max 10A) <sup>1</sup>	2	APP CASAMBI N° 2 Button N.A.

# PROTECTIONS

OVP	Over voltage protection <sup>2</sup>	
UVP	Under voltage protection <sup>2</sup>	
RVP	Reverse polarity protection <sup>2</sup>	
IFP	Input fuse protection <sup>2</sup>	

# TYPE OF PROFILES

NAME OF PROFILE	# PROFILE	DESCRIPTION
SLIM 2xDIM (Lin)	24998	N° 2 LED output channels, two slides to dim the outputs. PWM frequency = 4000Hz. Linear dimming curve. PWM resolution 1000S tep.
SLIM 2xDIM (Log)	23925	N° 2 LED output channels, two slides to dim the outputs. PWM frequency = 4000Hz. Logarithmic dimming curve. PWM resolution 1000S tep.
SLIM TUNABLE WHITE 2700-6500K	25254	N° 2 LED output channels, a slide to dim the TW output and a slide to vary the Color Temperature. PWM frequency = 4000Hz. Linear dimming curve. PWM resolution 1000S tep.
SLIM DIM TO WARM	25255	N° 2 LED output channels, a single slide to control LED loads DIM to WARM PWM frequency = 4000Hz. PWM resolution 1000Step.





<sup>&</sup>lt;sup>1</sup> The maximum output current depends on the opera ng condi ons and the ambient temperature of the installa on. For the correct configura on, check the maximum deliverable power in the "<u>Technical Specifica ons</u>" sec on and the "<u>Opera ng Windows</u>".

<sup>&</sup>lt;sup>2</sup> The protections refer to the logical control circuit.



### REFERENCE STANDARDS

EN 55015	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment	
EN 61547	Equipment for general lighting purposes – EMC immunity requirement	
EN 61347-1	Lamp Controlgear - Part 1: General and safety requirement	
EN 61347-2-13	Lamp Controlgear – Part 2-13: Particular requirement for d.c. or a.c. supplied electronic Controlgear for LED modules	

# TECHNICAL SPECIFICATIONS

		SLIM 2CV	CASAMBI	
Supply voltage		Min: 10,8Vdc - Max: 52,8Vdc		
Output voltage		= Vin		
Input current		Max 10A		
Output current <sup>3</sup>		2x max 5A	1x max 10A	
	12 Vdc	60W	120W	
Nominal power	24 Vdc	120W	240W	
	48 Vdc	240W	480W	
Power loss in standby mode		< 0.5W		
Type of load <sup>4</sup>		R		
Dimming curves		Logarithmic or Linear		
Dimming range⁵	Dimming range⁵		0,5 - 100%	
Minimum dimming level		0,5% (Logarithmic Curve)		
5		0,8% (Linear Curve)		
Dimming method		Pulse Width Modulation "PWM"		
	PWM Frequency <sup>5</sup>		4000 Hz	
	PWM Resolution <sup>5</sup>		1000 Step	
Operating Frequencies <sup>5</sup>		2402 – 2483 MHz		
Maximum output power⁵		7dBm		
Storage temperature		Min: -40°C – Max: 60°C		
Ambient temperature, Ta range <sup>3</sup>		Min: -10°C - Max: 60°C		
Type of connector		Push-In terminals		
Wiring	Solid Size	0.2 ÷ 1.5mm² / 24 ÷ 16 AWG		
	Stranded size			
Wire strip length		9 ÷ 10 mm		
IP protection grade		IP20		
Casing material		Plastic		
Packaging units (pieces/units)		1pcs		
Mechanical dimensions		136 x 29 x 22 mm		
Packaging dimensions		147 x 34 x 29 mm		
Weight		53g		





DISTRIBUTED BY Wired 4 Signs USA +1 (865) 339 4956 info@w4susa.com

<sup>&</sup>lt;sup>3</sup> For the full range check the <u>Operating Window</u> of product.

<sup>&</sup>lt;sup>4</sup> Type of load: Resis ve and DC/DC Converter.

<sup>&</sup>lt;sup>5</sup> The parameters are derived from the configuration of the Casambi module.

# DALC NET

SLIM 2CV CASAMBI

Device Manual



### WIRING DIAGRAM

As show in the wiring diagram carry out the following steps for the installation of the product:

- Connect the positive of the LED load to the "L1" or "L2" terminals with the "+" symbol, instead the negative of the LED load to the "L1" or "L2" terminals with the "-" symbol.
- Connect the N.O. push button to the "INPUT 1" and "INPUT 2" terminals with the "
   "
   "
   symbol.

   Be sure not to connect live parts to the "INPUT" terminals.
- Connect a 12-24-48 Vdc constant voltage SELV power supply (depending on the technical characteristics of LED load) to the DC IN terminal with the "+" and "-" symbols.
   Be sure not to use constant current LED Driver and check that the polarity of the cables is correct.

Like any other product with Bluetooth control, be sure not to place the product inside a metal case or placed near large metal structures. The metal will greatly block the radio signal, important for the correct operation of the device.



#### CONNECTION SCHEME PROFILE: SLIM 2xDIM







DISTRIBUTED BY Wired 4 Signs USA +1 (865) 339 4956 info@w4susa.com






103.0 %

#### CONNECTION SCHEME PROFILE: SLIM TUNABLE WHITE





#### CONNECTION SCHEME PROFILE: DIM TO WARM







DISTRIBUTED BY Wired 4 Signs USA +1 (865) 339 4956 info@w4susa.com

www.w4susa.com 7669 Clinton Highway, Powell, Tennessee, 37849

Day: To Martin

1000% .



### LOCAL COMMANDS FUNCTIONALITY

#### N.O. PUSH BUTTON<sup>6</sup>

N° Button	Function		
	Controls a luminaire	Click	Tap to turn a luminaire on or o - hold to adjust luminaire
		Long pressure (>1s)	brightness
	Controls an element	Click	Tap to turn a device element on or o - hold to adjust
		Long pressure (>1s)	the element value
	Control a group	Click	Tap to turn a group on or o – hold to adjust brightness
		Long pressure (>1s)	
1-2	Control scene	Click	Tap to turn a scene on or o - hold to adjust scene
		Long pressure (>1s)	brightness
	Control all luminaires	Click	Tap to turn all luminaires on or o - hold to adjust
		Long pressure (>1s)	brightness
	Cycles scenes	Click	Tap to cycle through the list of scenes - hold to adjust
		Long pressure (>1s)	current scene brightness
	Active/Standby	Click	Tap to switch between two scenes - hold to adjust
		Long pressure (>1s)	current scene brightness
For all other functions consult the documentation of the CASAMBI APP at:			
https://support.casambi.com/support/home_			

### UNPAIR DEVICE FROM THE CASAMBI NETWORK

If the device is associated with a network to which you do not have the credentials and you want to associate it with a new one, follow the settings specified in the Casambi APP in the "Nearby Devices" section. Once you have selected the unpair function and started the procedure, turn o the main power of the power supply connected to the SLIM-2CV-CASAMBI and turn it on again after 1 - 2 seconds.

If the main power supply is switched o and on again quickly, unpair may not be done properly. Repeat the unpair sequence by allowing 1 or 2 more seconds to elapse between the moment you turn o and re-turn on the main power of the power supply<sup>7</sup>.

A second method to unpair the product is to connect an N.O. push button to an "INPUT" terminal of the SLIM-2CV-CASAMBI and during the decoupling procedure press the button.





DISTRIBUTED BY Wired 4 Signs USA +1 (865) 339 4956 info@w4susa.com

<sup>&</sup>lt;sup>6</sup> By default, the N.O. Push bu on is set as "Control a luminaire" and controls the outputs of the SLIM-2CV-CASAMBI.


<sup>&</sup>lt;sup>7</sup> The discharge time of the power supply secondary depends on the construction characteristics of the power supply used.








#### OPERATING WINDOW



Ambient temperature [Ta]:

- provides a current up to 10A, with a working temperature range of -10°C  $\div$  + 60°C.

These maximum current values can be applied only under proper ventilation conditions.



### FLICKER PERFORMANCE

Thanks to the 4khz dimming frequency the SLIM-2CV-CASAMBI allows to reduce the Flicker phenomenon. Depending on the sensitivity of a person and type of activity, Flickering can a ect a person's well-being even if the luminance fluctuations are above the threshold that can be perceived by the human eye.

The graph shows the phenomenon of Flickering in function at the frequency, measured throughout the dimming range.

The results show the low-risk zone (yellow) and the noe ect zone (green). Defined by IEEE  $1789-2015^8$ 

<sup>8</sup> Institute of Electrical and Electronics Engineers (IEEE). *IEEE std 1789: Recommended Practices for Modulating Current in High-Brightness LEDs for Mitigating Health Risks to Viewers.* 






DISTRIBUTED BY Wired 4 Signs USA +1 (865) 339 4956 info@w4susa.com






Device Manual

# DIMMING CURVE



# MECHANICAL DIMENSIONS







DISTRIBUTED BY Wired 4 Signs USA +1 (865) 339 4956 info@w4susa.com

#### Device Manual



#### TECHNICAL NOTE

#### INSTALLATION

- CAUTION: The product may only be connected and installed by a qualified electrician. All applicable regulations, legislation, and building codes must be observed. Incorrect installation of the product can cause irreparable damage to the product and the connected LEDs.
- Maintenance must be performed only by a qualified electrician in compliance with current regulations.
   Pay attention when connecting the LEDs: polarity reversal results in no light output and often damages the LEDs.
- The product is designed and intended to operate LED loads only. Powering non-LED loads may push the product outside its specified design limits and is, therefore, not covered by any warranty.
- Operating conditions of the product may never exceed the specifications as per the product datasheet.
- The product must be installed inside a switchgear/controlgear cabinet and/or junction box protection against overvoltage.
- The product must be installed in a vertical or horizontal position with the label/top cover facing upwards or vertically. Other positions are not permitted. The bottom position is not permitted (label/top cover facing down).
- Keep separated 230Vac (LV) circuits and not SELV circuit from safety extra low voltage (SELV) circuit and from any connection with this product. It is absolutely forbitten to connect, for any reason whatsoever, directly or indirectly, the 230Vac mains voltage to the product (terminal block of BUS included).
- The product must be dissipated correctly.
- The use of the product in harsh environments could limit the output power.
- For built-in components inside luminaires, the ta ambient temperature range is a guideline given for the optimum operating environment. However, integrator must always ensure proper thermal management (i.e. correct mounting of the device, a ir flow etc.) so that the tc point temperature does not exceed the tc maximum limit in any circumstance. Reliable operation and lifetime is only guaranteed if the maximum tc point temperature is not exceeded under the conditions of use.

#### POWER SUPPLY

- Only use SELV power supplies with limited current for device power supply, short circuit protection and the power must be dimensioned correctly.
  - In the case of power supplies equipped with ground terminals, it is mandatory to connect ALL protective ground points (PE = Protection Earth) to a properly and certified protection earth.
- The connection cables between the very low voltage power source and the product must be properly dimensioned and must be insulated from any wiring or part at non-SELV voltage. Use double insulated cables.
- Dimension the power of the power supply in relation to the load connected to the device. In case the power supply is oversized compared to the maximum absorbed current, insert a protection against over-current between the power supply and the device.

#### COMMAND

- The length of the cables connecting between the local commands (N.O. Push button or other) and the product must be less than 10m. The cables must be properly dimensioned and must be insulated from any non-SELV wiring or voltage. It is recommended to use double insulated cables, if deemed appropriate also shielded.
- ALL device and control signal connected to the local command "N.O. Push button" with range symbol, they must not supply any type of voltage.

#### OUTPUTS

• It is recommended a length of the connecting cables between the product and the LED module less than 10m. The cables must be properly dimensioned and must be insulated from any wiring or circuits at voltage not SELV. It is recommended to use double insulated cables. In case you want to use connecting cables between the product and the LED module greater than 10m, the installer must guarantee the correct operation of the system. In any case, the connection between the product and the LED module must not exceed 30m.

#### ONLY CASAMBI/BLUETTOTH PRODUCT

• WARNING: For optimal functionality of the Casambi signal, do not put the device into metal or aluminium boxes and do not shield the device. As any other Casambi product, should not be placed in a metal enclosure or next to large metal structures. Metal will e ectively block all radio signals which are crucial to the operation of the product.

#### WARNINGS

- To guarantee the best performances and the full use of functions, make sure to download on your device the last release of CASAMBI APP.
- Whenever CASAMBI APP requires an upgrade of the profile installed in the LED Dimmers, follow the instruction to do it. This allows you to stay always up to date and benefit of new functions released.
- Functionality test are done on all dimmers to ensure the right working. In case the device is still paired to "Dalcnet network", you are asked to unpair it by following the instructions on CASAMBI APP and in paragraph <u>"UNPAIR DEVICE FROM THE CASAMBI NETWORK".</u>





DISTRIBUTED BY Wired 4 Signs USA +1 (865) 339 4956 info@w4susa.com