

## Intelligent Input/Output Unit Installation Guide

<b>Part No</b>	<b>Product Name</b>
SA4700-102APO	Intelligent Input/Output Unit

### Technical Information

All data is supplied subject to change without notice. Specifications are typical at 24V, 25°C and 50% RH unless otherwise stated.

<b>Supply Voltage</b>	17-35V dc
<b>Quiescent Current</b>	500µA
<b>Power-up Surge Current</b>	900µA
<b>Relay Output Contact Rating</b>	1A at 30V dc or ac
<b>LED Current</b>	1.6mA per LED
<b>Maximum Loop Current</b>	1A
<b>(I<sub>e</sub> max; L1 in/out)</b>	
<b>Operating Temperature</b>	-40°C to 70°C
<b>Humidity</b>	0% to 95% RH (no condensation or icing)
<b>Approvals</b>	EN 54-17 & EN 54-18

For additional technical information please refer to the following documents which are available on request.

PP2553 - Intelligent Input/Output Unit

**1**

**i** Drill holes where required.

**2**

**!** Do not over tighten screws

**3**

**i** Remove knockouts and fit glands where required.

**4**

**i** Note the alignment marks

**5**

**!** Do not over tighten screws

**6**

**i** See Table 1

126

**!** The 8th segment must be in set to '0' for Discovery / XP95 operation

**7**

**!** All CI tests must be carried before connecting the interface. For connectivity instruction see Figs 1, 2 & 3

**8**

**i** Note the alignment marks

**9**








### Addressing

Table 1

	XP95 / Discovery Systems	CoreProtocol Systems
<b>Segment</b>	1	Sets the address
	2	
	3	
	4	
	5	
	6	
	7	
	8	Set to '0' (Fault value is returned if set to '1')
FS	Enables failsafe mode (compliant with BS7273-4 for door holders)	Enables failsafe mode (compliant with BS7273-4 for door holders)
LED	Enables/Disables LED (except Isolator LED)	Enables/Disables LED (except Isolator LED)


**Note: On mixed systems addresses 127 and 128 are reserved. Refer to system's panel manufacturer for further information.**

## Address Setting Examples




## Connectivity Examples


**Fig. 1 Standard resistive monitoring mode**



**Fig. 2 Normally open monitoring mode (compatible with CoreProtocol only)**



**Fig. 3 Normally closed monitoring mode (Compatible with CoreProtocol only)**



When operated under XP95 or Discovery Protocols, EN54-13 type 2 devices can be connected. In case EN54-13 type 1 devices need to be connected they must be installed directly next to this module, with no transmission path according to EN 54-13.

## LED Status Indicator

RLY	Continuous Red	Relay Active
	Continuous Yellow	Fault
POLL/ISO	Flashing Green	Device Polled
	Continuous Yellow	Isolator Active
IP	Continuous Red	Input Active
	Continuous Yellow	Input Fault

**Note:**  
Not all LEDs can be on simultaneously.

## Commissioning

The installation must conform to BS5839-1 (or applicable local codes).

## Maintenance

Removal of the external cover must be carried out using a flat screwdriver or similar tool.

## Caution

Unit damage. No electrical supply greater than 50V ac rms or 75V dc should be connected to any terminal of this Input/Output Unit.

Note: For compliance with Electrical Safety Standards the sources switched by the output relays must be limited to a 71V transient over-voltage condition. Contact Apollo for more information.

## Troubleshooting

Before investigating individual units for faults, it is important to check that the system wiring is fault free. Earth faults on data loops or interface zone wiring may cause communication errors. Many fault conditions are the result of simple wiring errors. Check all connections to the unit.

Problem	Possible Cause
No response or missing	Incorrect address setting
Fault condition reported Relay fails to operate	Incorrect loop wiring
	Incorrect input wiring
Relay energised continuously	Incorrect wiring
	Control panel has incorrect cause and effect programming
Analogue value unstable	Incorrect loop wiring
	Incorrect address setting
Constant Alarm	Dual address
	Loop data fault, data corruption
Isolator LED on	Incorrect wiring
	Incorrect end-of-line resistor fitted
	Incompatible control panel software
	Short-circuit on loop wiring
	Wiring reverse polarity
	Too many devices between isolators

## Mode Table\*

Mode	Description
1	DIL Switch XP Mode
2	Alarm Delays
3	Output and N/O input (can be equivalent for Output only)
4	Output and N/C input
5	Output with Feedback (N/C)
6	Failsafe Output with Feedback (N/C)
7	Failsafe Output without Feedback
8	Momentary Input Activation Sets Output Relay
9	Input Activation Sets Output

\*CoreProtocol enabled systems only