



BACstac/Win v7.2

Installation Guide

Document Version: 1.0

Cimetrics, Inc.

BOSTON, MASSACHUSETTS
USA

TELEPHONE: +1 (617) 350-7550

FAX: +1 (617) 350-7552

E-MAIL: products@cimetrics.com (sales), support@cimetrics.com (tech. support)

WEB: <http://www.cimetrics.com>



BACstac/Win v7.2 Installation Guide

by Cimetrics, Inc.

Document Version: 1.0 Edition

Copyright © 1999-2019 Cimetrics, Inc.

BACstac and BACstac/32 are trademarks of Cimetrics Inc. BACnet is a registered trademark of the American Society of Heating, Refrigeration and Air-Conditioning Engineers, Inc. (ASHRAE). LonTalk is a trademark of Echelon Corp. All other trademarks are owned by their respective companies.

Table of Contents

1. Introduction	1
Technical Support.....	1
2. Getting Started	2
Data Link Layers.....	2
Protocol Stack Installation.....	2
Uninstalling the Protocol Stack.....	2
Protocol Stack Upgrade.....	3
Development Environment Installation.....	3
Example Applications.....	3
3. Windows-Specific Features	5
Multiple Processes.....	5
Multiple Threads.....	5
4. Configuration	6
Configuring the Network Layer Ports.....	6
BACnet/Ethernet Ports.....	6
BACnet/IP Ports.....	7
BACnet/PTP Ports.....	7
Virtual Ports.....	9
Registry Entries.....	9
A. Object Database Default Sizes	16

List of Tables

- 4-1. BACstac Service configuration parameters9
- 4-2. Routing entries parameters12
- 4-3. BACstac Application configuration parameters13
- A-1. The default property sizes in the Object Database16
- A-2. Default for the maximum number of elements in variable-size array properties.20
- A-3. Sample Data Type Instances21

Chapter 1. Introduction

Thank you for your interest in Cimetrics' BACstac software. The BACstac Standard Edition provides you with the ability to create client and server application programs which use ASHRAE's BACnet protocol for communication. The BACstac Routing Edition also allows you to route between BACnet networks or make a proprietary network of devices appear as a virtual BACnet network containing multiple devices.

The BACstac Standard Edition and Routing Edition are available for Windows 7, Windows 8, Windows 8.1, Windows 10, Windows Server 2008, Windows Server 2008 R2, Windows Server 2012, Windows Server 2012 R2, and 32-bit embedded platforms.

This document describes how to install the BACstac software, as well as some features specific to the Windows version.

For a description of how to construct applications using the BACstac software, please refer to the BACstac Users' Guide. For a description of the data types and API routines available in Cimetrics' BACstac software, see the BACstac Programmers' Reference.

For a complete description of the BACnet protocol, please refer to American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. ANSI/ASHRAE Standard 135-2012 or later, "BACnet™ - A Data Communication Protocol for Building Automation and Control Networks".

In order to use this software, you will need the following:

- Windows 7 or later
- Ethernet network interface card and appropriate cable
- The WinPCap driver to use BACnet over Ethernet
- Microsoft Visual Studio 2012 or higher

Technical Support

Cimetrics offers technical support to assist you in developing applications using the BACstac software. The terms of the available technical support are found in your license agreement. You may contact us by any of the following means (e-mail is preferred):

telephone: +1 617-350-7550 (10 a.m. to 5 p.m. EDT)

fax: +1 617-350-7552

e-mail: support@cimetrics.com (<mailto:support@cimetrics.com>)

Chapter 2. Getting Started

The BACstac distribution consists of two parts: redistributable and developer parts. The redistributable part consists of binary files that you should install on user computers along with your BACstac application. The redistributable part for Windows includes the BACstac Service (BACSTAC.EXE), which provides the core of the BACnet protocol stack implementation. The developer part includes examples of BACstac applications, BACstac static libraries, and header files needed for developing BACstac applications.

Note: To run BACstac applications, you must set up a correct BACstac configuration as described in the Configuration chapter.

Data Link Layers

The BACstac protocol stack supports several standard BACnet data link layers. Some of these data link layers require lower level operating system components to be installed as described below.

The BACnet/Ethernet data link layer uses the WinPCap interface. The WinPCap driver can be downloaded here (<http://www.winpcap.org/install/>).

The BACnet/IP data link layer uses the TCP/IP protocol stack through the Windows Sockets API.

The BACnet/PTP data link layer uses an unoccupied serial port. If your PTP DL is modem-configured, it will be capable of dialing and receiving calls.

You can have any number of BACnet/Ethernet, BACnet/IP, Virtual, and BACnet/PTP ports. A valid BACstac configuration should have at least one physical port (i.e. a configuration that consists only of Virtual and/or PTP ports is not allowed).

Protocol Stack Installation

If you have BACstac for Projects, first of all you need to install the Sentinel driver for your dongle key, which can be downloaded here: <http://www.safenet-inc.com/support-downloads/sentinel-drivers>. During installation of BACstac, do not forget to insert your dongle key into the computer.

To install the BACstac stack on your computer, please run bacstac.msi located in the setup folder of the BACstac distributive. During the process of installation, the installer may ask you to reboot the computer. This happens when some installed components are used by the system and stopping the BACstac service is not sufficient to release them. To integrate BACstac stack installation into the installer of your BACstac based program, please use bacstac.msm located in the same directory. If you plan to use BACnet over Ethernet, you should also install WinPCap driver.

Note: During the installation, the BACstac installer asks for the correct BACstac configuration. The default configuration uses BACnet over IP with the default hostname as IP address. This configuration works for most installations. However, if the configuration happen to be invalid for any reason, the installation will fail complaining about inability to start the BACstac service. If you use BACnet/IP (the default configuration), please, make sure that you have at least one network adapter with TCP/IP enabled when you install bacstac.msi on the computer.

Uninstalling the Protocol Stack

To uninstall the BACstac protocol stack, click on the Start button, choose Settings and then click on the Control Panel in them. When the Control Panel dialog appears, double click on the Add or Remove Programs icon. In the Add or Remove Programs dialog, choose BACstac and click on the Remove button.

Protocol Stack Upgrade

During installation of BACstac 6.0 on a PC with BACstac 5.0 or an older version already installed, the installation program will ask you whether you want to remove the old version. Removing the old version is necessary for the successful installation of BACstac v6.0. If the BACstac was installed manually on that computer then you should agree, however if the BACstac was installed by a third-party program it may be safer to let that program to remove the previous version of BACstac.

Starting with BACstac 6.0, it is possible to have different versions of BACstac being installed on the same computer. If more than one BACstac is installed then the latest version is usually chosen to be active. The active BACstac service should be able to serve all BACstac applications. It is possible to install BACstac application based on different BACstac versions on the same computer. If the currently active BACstac service is uninstalled (as part of some BACstac based program) then another installed BACstac service is activated automatically.

Note: The BACstac v6.0 Service is fully backward compatible with all BACstac 4.x and 5.0 versions, i.e. all BACstac 5.0 applications and BACstac 4.x applications using DLLs from previous BACstac versions can work correctly with the new service. However, new BACstac applications cannot work with old versions of the BACstac service.

Development Environment Installation

To install the BACstac development environment, please unzip the BACstac archive to a directory which you have chosen to be the BACstac development directory on your computer.

The BACstac directory tree contains *bin*, *examples*, *include*, *lib*, and *setup* subdirectories. The README.TXT file at the top of distribution provides more details about each of them.

If you licensed the source code, you will find it in the *src* directory. Read the SOURCE.TXT file in it for information about creating a release or debug build for each included component: BACstac Service, libraries, etc. You might want to use debug build while developing your application because the debug version includes extra debug code (such as ASSERT() macros) as well as source-level debug information.

The BACstac distribution includes only the release build of all programs and libraries, therefore they contain no extra debug code or debug information.

Example Applications

The BACstac development distribution includes more than 20 examples of different types of BACstac applications (client, server, and gateway*) designed to illustrate various BACstac features. Please consult the README.TXT file in *examples* directory for instructions on how to build them.

Each BACstac server or gateway application represents a BACnet device, and therefore it must abide by the BACnet standard which, in particular, asserts that each device on the BACnet network shall have a unique Device ID and a unique Device Object Name. Each server or gateway application has some built-in values for them, which you might want to change before running it. You can also change a Device ID for a particular instance of one application by using the `-i` command line option.

Each gateway application requires an unused virtual network to attach to. The selection of the network is done by specifying its Port ID number in the current BACstac configuration (see chapter 4 for details). The default value of Port ID is 2, which corresponds the Port ID of the virtual network in default BACstac configuration. If you have changed the BACstac configuration, you must set an appropriate value for Port ID either by changing the built-in parameter, or by using the `-p` command line option.

Chapter 3. Windows-Specific Features

Multiple Processes

On Microsoft Windows, multiple processes can share access to the BACstac protocol stack simultaneously. Other protocols (such as UDP and TCP) include the concept of ports to allow multiple processes to share a common network interface. The BACnet protocol does not include a concept of an application or transport layer port, but there are several multiplexing mechanisms that fit the BACnet specification nicely:

- Network Layer (NL) multiplexing
- Application Layer (AL) or Service-based multiplexing
- Object-based multiplexing

With NL multiplexing, processes can be made to appear to be virtual devices on virtual networks, or a single process could be made to appear to be all of the devices on a virtual network. The BACstac Routing Edition allows this type of multiplexing. To accomplish this the NL has to act like a BACnet router. A Gateway application must also be capable of handling multiple “local” Devices.

With AL multiplexing, it is possible to concurrently run a single Server process and an unlimited number of Client processes. The BACstac Standard Edition allows this type of multiple process access (with a fixed total for the processes amount). This becomes possible because Confirmed Service requests are identified by an Invoke ID, and Unconfirmed Service requests are typically broadcasts or contain a Process ID field. Incoming replies and notifications can be matched up with the correct process, incoming broadcasts can be forwarded to all processes, and incoming requests go to the Server process. Local clients can talk to local servers transparently. Local messages do not show up on the network.

The BACstac Service implements AL multiplexing using a custom IPC mechanism. The IPC mechanism was chosen to allow portability to embedded systems, and it uses a fixed number of *slots*. The slots are recycled when an application stops running.

With Object-based multiplexing, Service requests that identify a particular Object (e.g. Read-Property) can be forwarded to a dedicated process. The BACstac Standard Edition does not support this type of multiplexing directly. A multiplexing server using an appropriate IPC mechanism (e.g. CORBA, COM, or UDP) can be built on top of the BACstac API.

Multiple Threads

Windows provides a multithreading environment. The BACstac software uses multiple threads to implement the protocol stack and it allows multiple application threads to use its API.

- Object Database locking is required for atomic service request handling in Servers
- API calls are multithread safe
- Hook processing is done in a separate thread
- Asynchronous hook completion is allowed outside of the hook-processing thread
- Asynchronous request completion notification is allowed in a dedicated thread

Chapter 4. Configuration

Configuring the Network Layer Ports

The Network Layer of the BACstac Standard Edition protocol stack dispatches messages from/to local and remote networks, through a single network port. The Network Layer of the BACstac Routing Edition protocol stack is a BACnet router between multiple physical and virtual network ports.

The Network Layer is a part of the BACstac Service, and maintains a routing table that can be updated by BACnet messages. When it is started, the BACstac Service reads the initial values for the routing table from the Registry. The BACstac Service also writes values updated by BACnet messages to the Registry.

The initial values for the routing table can be modified using the BACstac Protocol Properties dialog box of the Network Control Panel applet. Updated values will take effect when the BACstac Service is restarted by rebooting or by using the Services Control Panel applet. You should not restart the BACstac Service while BACstac applications are running.

The routing table consists of a list of globally unique ports. Each port has a locally unique port ID, port type and BACnet network number. Ports can be physical or virtual. BACstac Routing Edition supports routing between multiple physical and virtual ports. At least one physical port (BACnet/Ethernet or BACnet/IP) must be included. Ports can be “unattached”, so they are inaccessible until BACnet Network Layer messages assign network numbers to them.

For most installations, the only fields in the default routing table which need to be modified are the network numbers. Each network segment in a BACnet internetwork must be assigned a single unique network number. Each of the routers directly attached to a network segment contains this network number in their routing tables.

A new port can be added in the Protocol Properties dialog box (in NCPA). To add a new port select “Add. . .” button in the Protocol Properties dialog box and choose the needed port type. The Port Properties dialog box will be displayed. Fill in the fields and click Ok.

Configuration of a BACnet/Ethernet port requires installation of the WinPCap driver, which can be download from <http://www.winpcap.org/install/>.

Port settings can be modified by clicking the Edit button in the Protocol Properties dialog box, which will call up a dialog box specific to the type of port. A port can be removed from the routing table with the Remove button in the Protocol Properties dialog box.

Important: If you use the BACstac Routing Edition’s BACnet routing capability, all network segments in a BACnet internetwork must be given unique network numbers. The BACnet Standard allows only one path between any two network segments. If this restriction is violated, a loop is created, and global broadcasts could be repeated around the loop up to 255 times (and a Who-Is/I-Am transaction could generate 64k broadcasts). The lifetime of a message is limited by the Hop Count field in the message. The BACstac Network Layer decrements this field value by the NL\Hop_Decrement parameter value specified in the Windows registry; the default value for this parameter is 1. The BACstac Network Layer attempts to detect loops and will discard suspicious broadcasts.

BACnet/Ethernet Ports

The BACnet/Ethernet Port Properties dialog box has fields for the port ID, network number, network interface card (NIC) and a check box to specify whether the port is attached.

An WinPCap driver must be installed on the system. You can download it here (<http://www.winpcap.org/install/>).

BACnet/IP Ports

The BACnet/IP Port Properties dialog box has three tabs, but you usually need to use the first tab only. The TCP/IP protocol (and any relevant drivers for the Ethernet card or Remote Access Services and modems) must be installed before using the BACnet/IP port.

The first tab of the BACnet/IP Port Properties dialog box contains fields for the port ID, network number, Adapter combobox, IP address, and UDP port number for this BACnet/IP port. It also contains a checkbox to specify whether this port is attached. You can choose a BACnet/IP binding either by choosing the desired adapter in the combobox, or by specifying the correct IP address. The first method is used when an IP address is received by DHCP or it may be changed often. The second method is useful when you don't want to bind to a specific adapter but you want to use a specific IP address for your BACnet device. If you have only one local network connection (one Ethernet card) or you are not interested in which of a few local connections will be used, then it is preferable to leave the default values for both these fields -- Adapter: "Any", IP address: "Default". The UDP port number should probably be left as the default value of 47808 (in hexadecimal this is 0xBAC0).

The second tab is used to configure this BACnet/IP port to be a BACnet Broadcast Management Device (BBMD). BBMDs are used to propagate broadcasts. This is only necessary if your BACnet/IP network is going to span IP subnets or if you need to support connections from BACnet/IP Foreign Devices (FDs). Use this tab only if this device is to be a BBMD on the current subnet.

Starting with BACstac 6.1, it is possible to have more than one BBMD on the same IP subnet. It works only if other BBMDs on the same IP subnet also support Addendum 135-2008o. If there are two or more BBMDs on a single IP subnet, their BDTs must not contain any common entries. Also, masks referring to the same subnet are required to be identical in all BBMDs. For more detailed information, please, refer to Addendum 135-2008o.

Table entries are added using the three-edit fields and the Add/Remove buttons. Don't add an entry corresponding to the local BBMD — it is maintained internally by the BACstac. The Two-Hop Forwarding option overrides the local BBMD's subnet mask with the value 255.255.255.255. In addition, you can enable/disable the handling of Foreign Devices and specify the maximum size of the Foreign Device Table (FDT). Note that once configured as a BBMD, this port is required to respond to BBMD messages that can change the BDT and FDT. Changes to the BDT by BACnet/IP messages are stored in Registry, and will persist if the BACstac protocol is restarted, while changes to the FDT are not persistent.

The third tab is used to configure this BACnet/IP port to be a Foreign Device (FD). When the BACstac starts up, it will request that the specified BBMD include this port in the broadcasts for the BACnet/IP network. A time-to-live parameter is included in this request.

A BACnet/IP port can be configured as one of the following:

- a regular BACnet/IP port
- a BACnet/IP port and a BBMD device
- an FD port and FD device.

BACnet/PTP Ports

The BACnet/PTP Properties dialog box is unique and although it has a port ID field, it doesn't have a network number field. This is because PTP ports are not regular network ports, but rather they are connections between half-routers.

When a connection is established the routers on each end of a PTP link exchange lists of the network numbers accessible to them. The PTP Data Link Layer and Network Layer are described in Clauses 6 and 10 of the BACnet Standard, ANSI/ASHRAE 135-2012 or later. The BACnet/PTP Properties dialog box has edit fields to specify the port ID and an RS-232 port. The Configure button will call up a dialog box to modify the port settings for the RS-232 port. These settings should match the settings of the peer PTP device.

The next field in the dialog box is used to add “could be” network numbers using the Add/Remove buttons. A PTP half-router is required to respond to some requests for specific network numbers by saying I-Could-Be-Router-To-Network if it knows it can become a connection to the requested network by making a PTP link. The performance index is a parameter included in the I-Could-Be-Router-To-Network reply, to help the client decide which half-router is the best one for the connection. A low value in this field indicates a higher performance index, or desirable connection. The client will then send that half-router an Establish-Connection-To-Network request. The BACstac protocol network layer will attempt to establish a connection automatically on behalf of its applications (for both local and remote PTP half-routers).

When peer PTP half-routers attempt to establish a connection, the calling half-router sends a password. You can specify the password sent by this PTP port, in addition to listing passwords that this PTP port will accept.

An important field in this dialog box is the Permanent check box. This should be checked for hard-wired connections to PTP devices, since it will cause the BACstac Service to attempt to establish the PTP link at start-up. If this box is not checked, the PTP port will wait for the other device to initiate the connection, or the PTP port will wait for a client application to request the connection.

Both cable connection and phone-line connection are types of physical connections. The physical one is required for the logical connection discussed in Clause 10 of the BACnet Standard. The logical connection can be established only if the physical one is established already. Whenever a logical connection establishment is initiated by this port, physical connection is established automatically. If the logical connection is terminated the physical one is terminated too and vice versa.

To use the dialing ability of a PTP device effectively, the modem parameters should be customized. For this purpose, check the Modem checkbox of the new PTP Port Properties Dialog box. If you leave this box unchecked, the PTP port assumes that you will use a direct serial connection without enabling any Dial properties. Then click the “Dial...” button to enter the “Dial and Modem Properties” dialog box. This dialog contains the following fields:

- Phone numbers: “number-list”

List of space-separated phone numbers to dial. The modem will attempt to dial all numbers in sequence. Each phone number is formatted in a modem-ready way (may include ‘,’, ‘w’, etc.: see your modem manual). Example:

```
"5551234 t8w095p,777-8888"
```

- Retries: n

Number of times to dial through the entire phone list before giving up. Zero means don’t dial. The default value is 1. -1 means infinitely (in fact, until the overall timeout expires). If this value is not present, the number of retries is -1.

- Interval: n sec

Interval, in seconds, between two consecutive dial attempts. By default, the zero value is assumed.

- Rings: n

Number of rings to allow before answering an incoming call. Default value is 1.

- Initialization string: “how-to-init-modem”

Character sequence used once to initialize modem. Defaults to the following string:

```
" atx4q0v1s0=0&d2&b1&c1"
```

Modem options set in this example are crucial for the BACstac to work. Please make sure that the modem options are set properly — either in the initialization string parameter or by some other means (i.e. by storing in an appropriate internal modem configuration). Description of each option follows. Some of the options may be specific for 3COM (formerly US Robotics) modems but analogs for other modems should exist.

x4: set modem result (error) code display filter

q0: enable modem result (error) codes

v1: display modem result (error) codes in verbal form

s0=0: disable modem autoanswer

&d2: use default DTR handling

&b1: Fixed serial port rate

&c1: Normal CD operations

- Dial prefix: “dial-string”

Character sequence to prepend to a telephone number before sending it to modem.

The default is “ATD”. Example:

“atdp” — force pulse dialing.

Virtual Ports

A Virtual port just has a port ID, network number and “Attached” checkbox as parameters. Virtual ports are used by Gateway applications. Gateway applications attach to virtual ports using the port ID parameter, so it is important that the values in the routing table match the values used by applications. Only one Gateway application can be attached to a single virtual port.

Registry Entries

A number of BACstac protocol stack run-time parameters are stored in the Windows Registry. These values are created and initialized when the protocol stack is installed. The registry entries are not completely removed when the protocol stack is uninstalled (this is standard behaviour for .INF files).

The Registry entries are located in:

HKEY_LOCAL_MACHINE\SOFTWARE\Cimetrics\BACstac

HKEY_LOCAL_MACHINE\SYSTEM\CurrentControlSet\Services\BACstac

The BACstac Service parameters (in .\Services\BACstac) include:

Table 4-1. BACstac Service configuration parameters

Key	Default	Comments
D\Def_Rcv_Queue	150	number of packs in the receive queue

Key	Default	Comments
D\Pdu_Pool_Size	200	PDU pool size This number specifies the maximum number of PDUs that can be held in all internal queues simultaneously. Its number should be more than the size of largest segmented window, otherwise segmentation may not work or work very slowly because of “lost” messages inside of the stack.
D\Socket_Buffer_Size	32k	size, in bytes, of the socket input and output buffer, used by BACnet/IP
N\Ptp_Term_Time_Value	30	in seconds, used when PTP connection is initiated locally
N\Find_Dnet_Timeout	30 000	time in milliseconds to wait for I-Am-Router-To-Network in response to Who-Is-Router-To-Network sent by the BACstac, when it tries to locate a router for an unknown remote network
N\Connect_Ack_Timeout	1 000	time in ms, to wait after PTP connection is established, before sending any packet to it.
N\Connect_Timeout	120 000	time in milliseconds to wait for a PTP connection to be established
N\Ptp_Term_Time_Value	30	inactivity timeout for establishing a new PTP connection, in seconds. The value may be from 0 to 255; 0 means infinity
N\Ptp_Term_Delay	60 000	connection termination delay by I-Am-Router-To-Network, in milliseconds.
N\Ptp_Connect_Delay	1 000	Delay after receiving the I-Could-Be-Router-To-Network message before establishing a PTP connection to otherwise unreachable network, in milliseconds.
N\Ptp_Safety_Timeout	300 000	PTP safety timeout, in milliseconds.
N\Router_Busy_Timeout	30 000	Router-Busy-To-Network timeout, in milliseconds See ANSI/ASHRAE Standard 135-2012 or later, section 6.6.3.6 for details

Key	Default	Comments
N\Delay_PDU_On_Busy	120 000	<p>the maximum delay time for APDUs to a busy network, in milliseconds.</p> <p>If the network is in the temporarily unreachable state for less than the specified value than packets from BACstac applications will be accepted and STATUS_OK is returned to the application. If the network remains in this state longer than the Delay_PDU-On_Busy time, no new APDU to this network is accepted and the error DNET_BUSY is returned to the application.</p> <p>Zero value of this timeout has a special meaning: defer all messages to the busy network until the destination network becomes available.</p> <p>The default value for this option is 2 minutes.</p> <p>The meaning of this option has been changed in BACstac 6.3. Now it does not affect routing. Starting with BACstac 6.3, upon receiving a message whose destination is one of the temporarily unreachable networks, BACstac sends a Reject-Message-To-Network message with a reject reason of 2 to the originating node.</p>
N\Fd_Reg_Timeout	30 000	<p>time in milliseconds, to wait for BVLC-Result Success during Foreign Device registration.</p> <p>This option is deprecated in BACstac 4.3. Instead of it, "Bip\Num_Fd_Reg_Retries" should be used in the corresponding port entry.</p>
N\Port_Table\Num_Entries		current number of routing table ports
N\Port_Table\EntryX*		routing table entries
N\Max_Pending_Xmt	150	<p>maximum number of pending transmit packets</p> <p>When the target network is in search, then the PDU is stored in the pending queue until either the network is found or the search timeout expires.</p>
N\Max_Known_Dnets	100	<p>maximum number of known remote networks</p> <p>The size of the pool used to store all known remote networks.</p>

Key	Default	Comments
NI\Max_Dnets_In_Search	100	maximum number of remote networks in search simultaneously When the BACstac does not know the router for a remote network, it tries to locate it using a Who-Is-Router-To-Network message, and then waits up to Find_Dnet_Timeout (milliseconds) for an I-Am-Router message. This number specifies the maximum number of networks in search.
NI\Hop_Decrement	1	hop counter decrement value when a packet is routed to another network (1..255)
Tsm\Max_Processes	10	maximum number of BACstac applications working simultaneously This number is limited only by available memory.
Tsm\Apdu_Max_Segs_Present	1	To set max-segments-accepted fields in an APDU header. BACnet 2001 or later allows for a BACnet device to advertise the maximal number of segments that it can accept in the response. This functionality is enabled by default starting with BACstac 5.0. For better compatibility with old devices, which may be confused by this new parameter, you may want to change this value to zero.
Tsm\Bind_On_Start	0	Specifies whether all ports are should be bind on start (1) or later when an application is connected (0).
Tsm\ConnIpc	\\.\pipe\bacstac	Named pipe used for IPC connection between a BACstac application and the BACstac service. This parameter should not normally be changed by the user.

The modified value of port entries listed above will take effect after the BACstac service restarts.

The routing table port entries can be modified using the Protocol Properties dialog box.

In addition the library parameters used by each application include (the keys are repeated for Cli\ and Gtw\):

Table 4-2. Routing entries parameters

Key	Default	Comments
Network_Type		BACnet Network Type
Port		Port ID
Label		Port name for log messages
Dnet		Network number
Connected	1	Enabled to receive messages
Nic		Network Interface Card name
Secondary_Info		Additional port information

Key	Default	Comments
Ptp_Permanent	0	PTP permanent connection
Ptp_Dnets		could be a router to these networks
Ptp_Performance	0	expected PTP performance
Bip*		BACnet/IP specific parameters
Bip\Bbmd	0	Enable BBMD functionality
Bip\Bdt		A space-separated list of all BDT entries. Each entry has the following format: <ip>[/<subnet>][:<port>].
Bip\Fdt_Present	0	Enable Foreign Device Table
Bip\Max_Fdt_Entries	16	Maximum number of FDT entries
Bip\Foreign_Device	0	Work as a foreign device
Bip\Fd_Bbmd_Ip		IP address of the BBMD device to connect
Bip\Fd_Bbmd_Udp	47808	UDP port of the BBMD device to connect
Bip\Fd_Time_To_Live	1800	Time-to-live for registration, in seconds
Bip\Nat_Ip		If the BBMD is located behind an IP router that performs network address translation (NAT) then this field should contain the global IP address or hostname of the IP router
Bip\Nat_Udp	47808	The external UDP port that is configured on the router with NAT to be used for receiving BACnet/IP packets directed to this BBMD
Bip\Fd_Reg_Timeout	30 000	Time to wait before retrying the registration request, in milliseconds
Bip\Num_Fd_Reg_Attempts	0	number of attempts to register the Foreign Device, zero means infinity.
PTP*		PTP specific parameters
PTP\Dial	"ATD"	The dial prefix.
PTP\Hangup	"ATH"	The hangup command.
PTP\In_Passwords	""	List of passwords that are accepted as valid from a peer device. If it is empty then any password is accepted.
PTP\Init	""	Initialization string.
PTP\Interval	1	Interval before to subsequent dial attempts, sec.
PTP\Mode	"9600,n,8,1"	
PTP\Modem	0	Use a modem.
PTP>Password	""	PTP password to establish an outgoing connection.
PTP\Phones	""	Phone numbers (space-separated).
PTP\Retries	-1	The number of retries.
PTP\Rings	0	Rings to allow before answering a call.

Each key in the above table has "N\Port_Table\EntryX" prefix, where X is the routing entry number.

Table 4-3. BACstac Application configuration parameters

Key	Default	Comments
-----	---------	----------

Key	Default	Comments
Srv\Cli_Tsm_Pool_Size	150	the maximum number of client TSMs, which determines the upper limit for the number of simultaneously concurrent requests that can be sent by one application
Srv\Srv_Tsm_Pool_Size	150	the maximum number of server TSMs, which determines the upper limit for the number of incoming requests that be processed simultaneously
Srv\A pdu_Length*	0	Maximum APDU length; 0 means the maximum supported value. For client and server applications, it is determined by the underlying data link. For gateway applications, 0 means 1476 (the maximum APDU length in BACnet). If the value specified is too large, then the maximum allowed value is used.
Srv\A pdu_Timeout*	6 000	in milliseconds, time to wait for the response PDU
Srv\Num_Retries*	3	number of retries if request fails
Srv\Segmentation*	0	0=both, 1=xmit, 2=rcv, 3=none
Srv\Max_Seg_Accepted*	32	maximum number of segments that can be received in a segmented message
Srv\Max_Seg_To_Send	0	Maximum number of segments that can be transmitted in a request 0 means the same value as for Max_Seg_Accepted
Srv\Max_Process_IDs	16	Maximum number of process identifiers that can be registered by one application
Srv\Seg_Window_Size*	16	Window size used for segmented requests and responses
Srv\Seg_Timeout*	5 000	APDU_Segmented_Timeout, in milliseconds
Srv\All_Process_IDs	0	Pass a confirmed request to the hook even if its ProcessID was not registered by the program: 0 — do not pass; 1 — pass all

Each set of keys stands for the corresponding type of an application. If changed, the new values take effect immediately after restarting the application for which the change was made.

Parameters marked with a star are default values for BACnet APDU Properties. These parameters:

- should be network-visible as properties in the Device object for a host
- can be queried and set by an application at runtime
- can be overridden on a per-request basis using the “raw” API

To send a larger segmented BACnet request (such as write file transfer request), increase Max_Seg_To_Send; to receive larger BACnet responses (such as read file transfer response), increase Max_Seg_Accepted. Increasing the Seg-Window-Size may speed up the transfer by reducing the number of segment acknowledgments required.

If incoming or outgoing packets are being dropped, increase DL\Socket-Buffer-Size and, if necessary, Tsm\PDU-Pool-Size (see below for the case of peak traffic handling). It may also be necessary to reduce the level of application processing done before resources are freed, such as in I-Am hooks.

If the application works through a slow data link, such as PTP, the default configuration may not work properly. You may need to reduce the segmented window size and/or increase the segmented and total TSM timeout. Also you may need reduce APDU length, because it is smaller for PTP than for Ethernet or BACnet/IP. However, reducing

APDU length in the registry is not always the best solution, because it will decrease APDU length for all requests regardless of their destination and make it impossible for the program to receive an APDU larger than the specified value. Alternatively, APDU length may be decreased on a per-request basis using APDU properties in the “raw” API.

If large packet traffic peaks can be expected on your network you can try to experiment with the parameters to determine the most suitable configuration for handling this problem. To begin with, you can configure all of the significant parameters (they are `TSML/PDU_Pool_Size`, `*/Cli_Tsm_Pool_Size`, `*/Srv_Tsm_Pool_Size`) to the number of packets expected in the traffic peak for a time unit (e.g. 250 packets for 0.5 second). If needed, some of the parameters can also be decreased. For example, if you prefer to save memory resources you can try to decrease the `TSML/PDU_Pool_Size` parameter, which consumes approximately 1.5kB for each PDU.

Appendix A. Object Database Default Sizes

The BACstac Object Database allocates fixed space for each property stored in the database. For some properties this size is defined by the maximum size allowed by the BACnet standard, but many BACnet data types (such as lists, arrays, character strings, etc) do not have any limit on how long they can be, so the BACstac has reasonable default sizes for those properties. Automatic properties (whose value is calculated based on other properties) are not stored in the object database, so the described limits are not applied to them.

The default size for non-array properties is determined by the property’s data type. For array properties, space is allocated for each array item separately using the same rules as for scalar properties. Table A-1 describes the default size for scalar and list properties based on their data type.

Note: A BACstac application can overwrite the default size during initialization, and specify how much space should be allocated for each property based on its property identifier and object type.

Table A-1. The default property sizes in the Object Database

Data Type	Scalar Size, in bytes	List Size, in bytes
AnyPrimitive	10	100
BACnetAccessAuthenticationFactorDisable	3	60
BACnetAccessCredentialDisable	3	60
BACnetAccessCredentialDisableReason	3	60
BACnetAccessEvent	3	60
BACnetAccessPassbackMode	2	40
BACnetAccessRule	39	780
BACnetAccessThreatLevel	2	40
BACnetAccessUserType	3	60
BACnetAccessZoneOccupancyState	3	60
BACnetAccumulatorRecord	25	500
BACnetAction	2	40
BACnetActionCommand	250	2500
BACnetActionList	250	2500
BACnetAddress	12	240
BACnetAddressBinding	17	500
BACnetAssignedAccessRights	14	280
BACnetAssignedLandingCalls	82	328
BACnetAuthenticationFactor	250	2500
BACnetAuthenticationFactorFormat	8	160
BACnetAuthenticationFactorType	2	40
BACnetAuthenticationPolicy	250	2500
BACnetAuthenticationStatus	2	40
BACnetAuthorizationExemption	2	40

Data Type	Scalar Size, in bytes	List Size, in bytes
BACnetAuthorizationMode	3	60
BACnetBackupState	2	40
BACnetBDTEntry	114	500
BACnetBinaryLightingPV	2	40
BACnetBinaryPV	2	40
BACnetCalendarEntry	12	500
BACnetChannelValue	104	500
BACnetClientCOV	5	100
BACnetCOVMultipleSubscription	50	1000
BACnetCOVSubscription	51	500
BACnetCredentialAuthenticationFactor	250	2500
BACnetDailySchedule	500	2500
BACnetDateRange	10	200
BACnetDateTime	10	200
BACnetDestination	37	500
BACnetDeviceObjectReference	10	500
BACnetDeviceStatus	3	60
BACnetDevObjPropReference	19	500
BACnetDevObjPropValue	48	480
BACnetDoorAlarmState	3	500
BACnetDoorSecuredStatus	2	40
BACnetDoorStatus	3	60
BACnetDoorValue	2	40
BACnetEngineeringUnits	3	60
BACnetEscalatorFault	3	60
BACnetEscalatorMode	3	60
BACnetEscalatorOperationDirection	3	60
BACnetEventLogRecord	50	0
BACnetEventNotificationSubscription	28	560
BACnetEventParameter	500	2500
BACnetEventState	3	60
BACnetEventTransitionBits	3	60
BACnetEventType	3	60
BACnetFaultParameter	500	2500
BACnetFaultType	2	40
BACnetFDTEEntry	14	140
BACnetFileAccessMethod	2	40
BACnetHostAddress	104	500
BACnetHostNPort	109	500
BACnetIPMode	2	40

Data Type	Scalar Size, in bytes	List Size, in bytes
BACnetLandingCallStatus	108	500
BACnetLandingDoorStatus	82	328
BACnetLifeSafetyMode	3	500
BACnetLifeSafetyOperation	3	60
BACnetLifeSafetyState	3	500
BACnetLiftCarCallList	42	168
BACnetLiftCarDirection	3	60
BACnetLiftCarDoorCommand	2	40
BACnetLiftCarDriveStatus	3	60
BACnetLiftCarMode	3	60
BACnetLiftFault	3	60
BACnetLiftGroupMode	2	40
BACnetLightingCommand	25	250
BACnetLightingInProgress	2	40
BACnetLightingTransition	2	40
BACnetLimitEnable	3	60
BACnetLockStatus	2	40
BACnetLoggingType	2	40
BACnetLogMultipleRecord	50	0
BACnetLogRecord	50	0
BACnetMaintenance	3	60
BACnetNameValue	208	2080
BACnetNameValueCollection	500	2000
BACnetNetworkNumberQuality	2	40
BACnetNetworkPortCommand	2	40
BACnetNetworkSecurityPolicy	4	80
BACnetNetworkType	2	40
BACnetNodeType	2	40
BACnetNotifyType	2	40
BACnetObjectIdentifier	5	100
BACnetObjectPropertyReference	14	280
BACnetObjectType	3	60
BACnetObjectTypesSupported	19	380
BACnetOptionalBinaryPV	2	40
BACnetOptionalCharacterString	104	500
BACnetOptionalReal	5	100
BACnetOptionalUnsigned	5	100
BACnetPolarity	2	40
BACnetPortPermission	4	80
BACnetPrescale	10	200

Data Type	Scalar Size, in bytes	List Size, in bytes
BACnetProcessIdSelection	5	100
BACnetProgramError	3	60
BACnetProgramRequest	2	40
BACnetProgramState	2	40
BACnetPropertyReference	9	90
BACnetPropertyAccessResult	48	480
BACnetPropertyStates	5	100
BACnetProperty Value	250	1250
BACnetProtocolLevel	2	40
BACnetRecipient	14	500
BACnetRelationship	3	60
BACnetReliability	3	60
BACnetRestartReason	2	40
BACnetRouterEntry	16	500
BACnetScale	5	100
BACnetSecurityKeySet	68	136
BACnetSecurityLevel	2	40
BACnetSecurityPolicy	2	40
BACnetSegmentation	2	40
BACnetServicesSupported	9	180
BACnetSessionKey	22	440
BACnetSetpointReference	16	320
BACnetShedLevel	5	100
BACnetShedState	2	40
BACnetSilencedState	3	60
BACnetSpecialEvent	250	1250
BACnetStatusFlags	3	60
BACnetTimerState	2	40
BACnetTimerStateChange Value	104	728
BACnetTimerTransition	2	40
BACnetTimeStamp	12	240
BACnetTime Value	15	150
BACnetVMACEntry	28	500
BACnetValueSource	14	500
BACnetVTClass	3	60
BACnetVTSession	16	320
BACnetWeekNDay	4	80
BACnetWriteStatus	2	40
Bit String	5	100
Boolean	1	20

Data Type	Scalar Size, in bytes	List Size, in bytes
Character String	104	500
Date	5	100
Double	10	200
Enumeration	5	100
Integer	5	100
Null	1	20
Octet String	100	500
ReadAccessResult	200	4000
ReadAccessSpecification	97	4000
Real	5	100
Time	5	100
Unsigned	5	100
Unsigned8	2	40
Unsigned16	3	60
Unsigned32	5	100

Note: The list size for BACnetEventLogRecord, BACnetLogMultipleRecord and BACnetLogRecord is 0, because the list of these types is used to define the Log_Buffer property, which usually is not stored in the BACstac database.

The space reserved for BACnetPriorityArray is equal to 16 elements of BACnetPriorityValue, where the size of the latter is determined by the data type of the present-value property.

Array properties can be two kinds: fixed-size and variable-size arrays. Fixed-size array properties cannot be resized and the number of elements in them is prescribed by the BACnet standard. Variable-size arrays can have any number of elements accordingly to the standard. The BACstac allocates a fixed size for each property. If the application has not provided its own property description with its own array sizes, the default values as defined in Table A-2 are used.

Table A-2. Default for the maximum number of elements in variable-size array properties.

Object Types	Properties	Number Of Elements
Access_Door	Door_Members	16
Access_Point	Authentication_Policy_List, Authentication_Policy_Names	16
Access_Point	Access_Doors	16
Access_Rights	Negative_Access_Rules	16
Access_Rights	Positive_Access_Rules	16
Access_Credential	Assigned_Access_Rights	16
Access_Credential	Authentication_Factors	16
CharacterString_Value	Alarm_Values, Fault_Values	40
BitString_Value	Alarm_Values	16
Command	Action, Action_Text	40

Object Types	Properties	Number Of Elements
Credential Data Input	Supported_Formats, Supported_Format_Classes	16
Device	Structured_Object_List	16
Device	Configuration_Files	16
Device	Slave_Proxy_Enable	16
Device	Auto_Slave_Discovery	16
Global_Group	Group_Members, Group_Member_Names, Present_Value	32
Load_Control	Shed_Levels, Shed_Level_Descriptions	40
Notification_Forwarder	Port_Filter	20
Multistate_Input, Multistate_Output, Multistate_Value	State_Text	40
Schedule	Exception_Schedule	40
Structured_View	Subordinate_List, Subordinate_Annotations	16
Trendlog_Multiple	Log_Device_Object_Property	16

Note: The Object_List property in the Device object is always automatic, therefore the number of elements is determined by the number of objects in the BACstac database.

Table A-3. Sample Data Type Instances

Data Type	Min..Max Size, bytes	Instance	Instance Size, bytes
BACnetActionCommand	12..unlimited	deviceIdentifier is not present, propertyArrayIndex is not present, propertyValue is REAL data type, priority is not present, postDelay is not present	16
Unsigned	2..5	255 < value < 65536	3
BACnetCalendarEntry	4..12	BACnetDateRange choice	12
BACnetCalendarEntry	4..12	BACnetWeekNDay choice	4
BACnetAddressBinding	9..18	network-number > 256, 6-byte MAC address	18
BACnetEventParameter	6..unlimited	out-of-range choice	24
BACnetSpecialEvent	9..unlimited	period is BACnetDateRange data type listOfTimeValues contains 16 REAL values	176
ReadAccessSpecification	9..unlimited	10-item specifications, propertyArrayIndex is not present	27
BACnetDeviceObjectProperty-Reference	7..19	propertyArrayIndex is not present, DeviceIdentifier is not present	7
BACnetDeviceObjectProperty-Reference	7..19	propertyArrayIndex is not present, DeviceIdentifier is present	12

Data Type	Min..Max Size, bytes	Instance	Instance Size, bytes
BACnetLogRecord	15..unlimited	logDatum is REAL data type, statusFlags are present	22
BACnetEventLogRecord	17..unlimited	logDatum is BACnetLogStatus data type	17
BACnetLogMultipleRecord	17..unlimited	logData is sequence of 10 BACSTAC_BOOLEAN values	26
ReadAccessResult	5..unlimited	10-item results, propertyArrayIndex is not present, propertyValue is REAL data type	97
BACnetDestination	23..37	255 < processIdentifier < 65536, recipient is BACnetObjectIdentifier choice	27
BACnetRecipient	2..13	BACnetObjectIdentifier choice	5
BACnetRecipient	2..13	BACnetAddress choice, network-number > 255, MAC address 6 bytes	13
BACnetTimeValue	8..unlimited	value is REAL data type	12
BACnetCOVSubscription	21..45	Object ID choice, Process ID < 256, Monitored Property Reference index is not present, Time Remaining is not present, COV Increment is not present	21
BACnetCOVSubscription	21..45	Address choice (DNET ≥ 256, MAC is 6 bytes), Process ID < 65536, Monitored Property Reference index is not present, Time Remaining < 65536, COV Increment is not present	33
BACnetAuthenticationPolicy	6..unlimited	Two policy items (with DeviceIdentifier, and index < 256), timeout < 256	34
BACnetAuthenticationFactor	5..unlimited	wiegand26 with format-class < 256	8
BACnetAccessRule	6..39	timeRange is specified with DeviceIdentifier, propertyIdentifier < 256, and without propertyArrayIndex; location is specified with DeviceIdentifier	32
BACnetAssignedAccessRights	9..14	DeviceIdentifier is not present	9
BACnetAuthenticationFactor-Format	2..8	vendor-id < 256; vendor-format < 256	6
BACnetCredential-AuthenticationFactor	9..unlimited	disable < 256, format-type = wiegand26, format-class < 256	12
BACnetPropertyAccessResult	10..unlimited	propertyIdentifier = Present_Value, no arrayIndex, no deviceIdentifier, propertyValue is the Real data type	14