# **SIEMENS**

# Data sheet

6ES7511-1AK02-0AB0

SIMATIC S7-1500, CPU 1511-1 PN, Central processing unit with working memory 150 KB for program and 1 MB for data, 1. interface: PROFINET IRT with 2 port switch, 60 NS bit-performance, SIMATIC memory card necessary



General information	
Product type designation	CPU 1511-1 PN
HW functional status	FS03
Firmware version	V2.8
Product function	
● I&M data	Yes; I&M0 to I&M3
• Isochronous mode	Yes; Distributed and central; with minimum OB $6x$ cycle of $625~\mu s$ (distributed) and 1 ms (central)
Engineering with	
<ul> <li>STEP 7 TIA Portal configurable/integrated as of version</li> </ul>	V16 (FW V2.8) / V15 (FW V2.5) or higher; with older TIA Portal versions configurable as 6ES7511-1AK01-0AB0
Configuration control	
via dataset	Yes
Display	
Screen diagonal [cm]	3.45 cm
Control elements	
Number of keys	8
Mode buttons	2

Supply voltage	
Type of supply voltage	24 V DC
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
Mains/voltage failure stored energy time	5 ms
Repeat rate, min.	1/s
Input current	
Current consumption (rated value)	0.7 A
Current consumption, max.	0.95 A
Inrush current, max.	1.9 A; Rated value
	0.02 A²·s
Power	
Infeed power to the backplane bus	10 W
Power consumption from the backplane bus	5.5 W
(balanced)	
Power loss	
Power loss, typ.	5.7 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
• integrated (for program)	150 kbyte
• integrated (for data)	1 Mbyte
Load memory	
Plug-in (SIMATIC Memory Card), max.	32 Gbyte
Backup	
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	60 ns
for word operations, typ.	72 ns
for fixed point arithmetic, typ.	96 ns
for floating point arithmetic, typ.	384 ns
CPU-blocks	
Number of elements (total)	2 000; Blocks (OB, FB, FC, DB) and UDTs
DB	
Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999

• Size, max.	1 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	
Number range	0 65 535
• Size, max.	150 kbyte
FC	
Number range	0 65 535
• Size, max.	150 kbyte
ОВ	
• Size, max.	150 kbyte
<ul> <li>Number of free cycle OBs</li> </ul>	100
<ul> <li>Number of time alarm OBs</li> </ul>	20
<ul> <li>Number of delay alarm OBs</li> </ul>	20
<ul> <li>Number of cyclic interrupt OBs</li> </ul>	20; With minimum OB 3x cycle of 500 μs
<ul> <li>Number of process alarm OBs</li> </ul>	50
<ul> <li>Number of DPV1 alarm OBs</li> </ul>	3
<ul> <li>Number of isochronous mode OBs</li> </ul>	2
<ul> <li>Number of technology synchronous alarm OBs</li> </ul>	2
<ul> <li>Number of startup OBs</li> </ul>	100
<ul> <li>Number of asynchronous error OBs</li> </ul>	4
<ul> <li>Number of synchronous error OBs</li> </ul>	2
<ul> <li>Number of diagnostic alarm OBs</li> </ul>	1
Nesting depth	
• per priority class	24
Counters, timers and their retentivity	
S7 counter	2 048
• Number	2 040
Retentivity	Yes
— adjustable  IEC counter	165
Number	Any (only limited by the main memory)
	Any (only limited by the main memory)
Retentivity — adjustable	Yes
— adjustable S7 times	165
• Number	2 048
Retentivity	2 0 10
— adjustable	Yes
— adjustable  IEC timer	
• Number	Any (only limited by the main memory)
Retentivity	, (,
— adjustable	Yes
— guiusiaule	

ata areas and their retentivity	
Retentive data area (incl. timers, counters, flags),	128 kbyte; In total; available retentive memory for bit memories,
max.	timers, counters, DBs, and technology data (axes): 88 KB
Extended retentive data area (incl. timers, counters, flags), max.	1 Mbyte; When using PS 6 0W 24/48/60 V DC HF
Flag	
Number, max.	16 kbyte
<ul> <li>Number of clock memories</li> </ul>	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	
Retentivity adjustable	Yes
Retentivity preset	No
Local data	
• per priority class, max.	64 kbyte; max. 16 KB per block
ddress area	
Number of IO modules	1 024; max. number of modules / submodules
I/O address area	
• Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
per CM/CP	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	
Number of subprocess images, max.	32
lardware configuration	
Number of distributed IO systems	32; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS i master modules or links (e.g. IE/PB-Link)
Number of DP masters	
• Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Number of IO Controllers	
• integrated	1
● Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Rack	
Modules per rack, max.	32; CPU + 31 modules
Number of lines, max.	1
PtP CM	

•	Number	of PtP	CMs
•	INUITIDE	OII II	CIVIS

the number of connectable PtP CMs is only limited by the number of available slots

Clock  • Type • Backup time • Deviation per day, max.    10 s: Typ.: 2 s	Time of day	
• Backup time • Deviation per day, max.  • Deviation per day, max.  Operating hours counter • Number • Number • Number • Number • Number • Sevices • One Ethernet via NTP  Interface  Interface  Interface types • Number of ports • Ru 4s (Ethernet) • PROFINET IO Controller • Media redundancy • Media redundancy • PROFINET IO Controller • Media redundancy • Yes • PROFINET IO Controller • Services  — PG/OP communication • Yes • Nescondance • PROFINET IO Controller • Services • PROFINET IO Controller • Yes • Media redundancy • Yes • Nescondance • Yes • Yes • Yes • Nescondance • Yes • Ye	Clock	
Deviation per day, max.  Operating hours counter  Number  Number  Supported	• Type	Hardware clock
Operating hours counter  Number 16  Clock synchronization  supported Yes  in AS, master Yes  on Ethernet via NTP Yes  Interfaces  Number of PROFINET interfaces 1  I. Interface Upes  Number of ports 2  integrated switch Yes; X1  Protocols  IP protocol Yes; X1  PROFINET IO Controller Yes  SIMATIC communication Yes  SIMATIC communication Yes  Media redundancy Yes  PROFINET IO Controller  Services  PG/OP communication Yes  PROFINET IO Controller  Services  PG/OP communication Yes  PROFINET IO Controller  Services  PG/OP communication Yes  Direct data exchange Yes; Requirement: IRT and isochronous mode (MRPD optional)  HRP Yes; MRP Automanager acc. to IEC 62439-2 Edition 2.0; MRP Manager; MRP Client; max. number of devices in the ring: 50  Yes; PROFILER max. number of devices in the ring: 50  Yes; Requirement: IRT  PROFIlenergy Yes; per user program	Backup time	6 wk; At 40 °C ambient temperature, typically
Number 16  Clock synchronization  supported Yes in AS, master Yes in AS, slave Yes on Ethernet via NTP  Interfaces  Number of PROFINET interfaces 1  1. Interface Interface types  Number of prots 2 integrated switch Yes; X1  Protocols  IP protocol Yes; IPv4 PROFINET IO Controller Yes SIMATIC communication Yes SIMATIC communication Yes SIMATIC communication Yes Media redundancy Yes Media redundancy Yes Media redundancy Yes PROFINET IO Controller Services  — PG/OP communication Yes — Isochronous mode — Direct data exchange Yes; Requirement: IRT and isochronous mode (MRPD optional) — IRT Yes — MRP — MRP — MRP — MRP — MRPD — Yes; Requirement: IRT — MRP — MRPD — Yes; Peruser program  Yes; per user program	<ul><li>Deviation per day, max.</li></ul>	10 s; Typ.: 2 s
Clock synchronization  • supported • in AS, master • in AS, slave • on Ethernet via NTP  / ves • in AS, slave • on Ethernet via NTP  / ves  • in AS, slave • on Ethernet via NTP  / ves  • in AS, slave • on Ethernet via NTP  / ves  • on Ethernet via NTP  / ves  • linterfaces  Number of PROFINET interfaces  1  1. Interface  Interface types • Number of ports • Number of ports • PA 45 (Ethernet)  / ves  • RJ 45 (Ethernet)  / ves; IPv4  • PROFINET IO Controller • PROFINET IO Device • PROFINET IO Device • PROFINET IO Device • SIMATIC communication • Ves • PROFINET IO Controller  • Web server • Media redundancy • Yes  PROFINET IO Controller  Services  - PG/OP communication - S7 routing - Isochronous mode - Direct data exchange - Direct data exchange - Direct data exchange - RRP - MRP - MRP - MRP - MRP - Manager; MRP Client; max. number of devices in the ring: 50 - Yes; Requirement: IRT - MRP - MRPD - PROFlenergy - Yes; per user program	Operating hours counter	
supported     in AS, master     in AS, slave     interfaces    Interfaces	• Number	16
• in AS, slave • in AS, slave • on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  1  1. Interface Interface types • Number of ports • RJ 45 (Ethernet)  Protocols • IP protocol • PROFINET IO Controller • PROFINET IO Device • SIMATIC communication • Open IE communication • Web server • Media redundancy • PROFINET IO Controller  Services  — PG/OP communication — S7 routing — Isochronous mode — Direct data exchange — Direct data exchange — IRT — MRP — MRP — MRP  Menager; MRP Client; max. number of devices in the ring: 50 — MRPD — PROFIenergy  Yes: per user program	Clock synchronization	
in AS, slave on Ethernet via NTP  res  Interfaces  Number of PROFINET interfaces  1  1. Interface  Interface Uppes  Number of ports integrated switch RJ 45 (Ethernet)  Protocols  IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Ves SIMATIC communication Ves Media redundancy PROFINET IO Controller  Wes Media redundancy PROFINET IO Controller  Services  PG/OP communication Yes PROFINET IO Controller  Services  PG/OP communication Yes PROFINET IO Controller  Services  PROFINET IO Controller  Yes PROFINET IO Controller  Services  PROFINET IO Controller  Yes PROFINET IO Controller  Services  PROFINET IO Controller  Services  PROFINET IO Controller  Services  PROFINET IO Controller  Yes PROFINET IO Controller  Services  PROFINET IO Controller  Yes PROFINET IO Controller  Services  PROFINET IO Controller  Services  PROFINET IO Controller  Yes PROFINET IO Controller  Services  PROFINET IO Controller  Number of Controller  Yes PROFINET IO Controller  Number of Controller  PROFINET IO Controller  PROFINET IO Controller  PROFINET IO Controller  Number of Controller  PROFINET IO Controller  Number of Controller  PROFINET IO Controll	<ul><li>supported</li></ul>	Yes
• on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  1  I. Interface Interface Upes  • Number of ports • Number of ports • Number of ports • RJ 45 (Ethernet)  Protocols  • IP protocol • IP protocol • PROFINET IO Controller • PROFINET IO Device • PROFINET IO Device • SIMATIC communication • Ves SIMATIC communication • Web server • Media redundancy  PROFINET IO Controller  Services  — PG/OP communication — S7 routing — Isochronous mode — Upes — Direct data exchange — IRT — MRP — MRP — MRPD — MRPD — MRPD — MRPD — PROFInergy  Yes: Proview Press  1  1  1  1  1  1  1  1  1  1  1  1	• in AS, master	Yes
Interfaces  Number of PROFINET interfaces  1. Interface types  • Number of ports • Number of ports • RJ 45 (Ethernet)  Protocols • IP protocol • PROFINET IO Controller • PROFINET IO Device • SIMATIC communication • Open IE communication • Web server • Media redundancy  PROFINET IO Controller  Services  — PG/OP communication — S7 routing — Isochronous mode — Direct data exchange — IRT — MRP — MRP — MRPD — MRPD — PROFINET IOT  1 Ves  1 Ves	• in AS, slave	Yes
Number of PROFINET interfaces  1. Interface Interface types  • Number of ports • Number of ports • Number of ports • RJ 45 (Ethernet)  Protocols  • IP protocol • PROFINET IO Controller • PROFINET IO Device • SIMATIC communication • Ves • SIMATIC communication • Web server • Media redundancy  PROFINET IO Controller  Services  - PG/OP communication  Yes - Isochronous mode - Direct data exchange - IRT - MRP - MRPD - PROFINET - MRPD - PROFInery  Yes; Requirement: IRT - MRP - Ves; Requirement: IRT - MRP - PROFInery - Ves; Requirement: IRT - MRP - PROFInery - Ves; Requirement: IRT - Ves; Requirement: IRT - Yes; PROFInergy	• on Ethernet via NTP	Yes
Interface Interface types  Interface typ		
Interface types  • Number of ports • integrated switch • RJ 45 (Ethernet)  Protocols  • IP protocol  • PROFINET IO Controller • Web server • Media redundancy • PROFINET IO Controller  Services  — PG/OP communication — S7 routing — Isochronous mode — Direct data exchange — IRT — MRP — MRPD — MRPD — MRPD — PROFINET WYes  • Ves  Yes  Yes  2  Yes  Yes  Yes  Yes  Yes	Number of PROFINET interfaces	1
<ul> <li>Number of ports</li> <li>integrated switch</li> <li>RJ 45 (Ethernet)</li> <li>Yes; X1</li> </ul> Protocols <ul> <li>IP protocol</li> <li>PROFINET IO Controller</li> <li>PROFINET IO Device</li> <li>SIMATIC communication</li> <li>Open IE communication</li> <li>Web server</li> <li>Media redundancy</li> <li>Yes</li> </ul> PROFINET IO Controller <ul> <li>Wes</li> <li>Agriculture</li> <li>Media redundancy</li> <li>Yes</li> </ul> PROFINET IO Controller <ul> <li>Services</li> <li>PG/OP communication</li> <li>Yes</li> <li>Sor routing</li> <li>Isochronous mode</li> <li>Direct data exchange</li> <li>Direct data exchange</li> <li>IRT</li> <li>MRP</li> <li>Yes; Requirement: IRT and isochronous mode (MRPD optional)</li> <li>IRT</li> <li>MRP</li> <li>Manager; MRP Automanager acc. to IEC 62439-2 Edition 2.0; MRP Manager; MRP Client; max. number of devices in the ring: 50</li> <li>MRPD</li> <li>Yes; Requirement: IRT</li> <li>Yes; Requirement: IRT</li> </ul>		
integrated switch RJ 45 (Ethernet)  Protocols  IP protocol  PROFINET IO Controller PROFINET IO Device PROFINET IO Device SiMATIC communication Open IE communication Wes; Optionally also encrypted Web server Media redundancy PROFINET IO Controller  Services  PROFINET IO Controller  Services  PROFINET IO Controller  Services  PROFINET IO Controller  Services  PROFINET IO Reproper Yes PROFINET IO Controller  Services  PROFICE IO Communication Yes PROFICE IO Communication Yes PROFICE IO Communication Yes PROFICE IO Communication Yes PROFICE IO CONTROLLER PROFICE IO CONTROLLER Yes PROFICE YES PROFICE IO CONTROLLER YES PROFICE IO CONTROLLER YES PROFICE YES PROFICE IO CONTROLLER YES PROFICE IO CONTROLLER YES PROFICE YES PROFICE IO CONTROLLER YES PROFICE IO CONTROLLER YES PROFICE		
RJ 45 (Ethernet)  Protocols  IP protocol  PROFINET IO Controller  PROFINET IO Device  SIMATIC communication  Open IE communication  Wes; Optionally also encrypted  Web server  Media redundancy  PROFINET IO Controller  Services  PROFICE IO Controller  Services  PROFICE IO Controller  Services  PROFICE IO Controller  Yes  PROFICE IO CONTROL  YES  PROFICE  PROFICE IO CONTROL  YES  PROFICE  PROFICE IO CONTROL  YES  PRO	•	
Protocols  IP protocol PROFINET IO Controller PROFINET IO Device PROFINET IO Device SIMATIC communication Open IE communication Web server Media redundancy PROFINET IO Controller  Services PROFINET IO Controller  Yes PROFILE IO CONTROLLER  YES	<ul><li>integrated switch</li></ul>	
IP protocol PROFINET IO Controller PROFINET IO Device SIMATIC communication Open IE communication Web server Media redundancy PROFINET IO Controller  Services  PROFINET IO Con	• RJ 45 (Ethernet)	Yes; X1
<ul> <li>PROFINET IO Controller</li> <li>PROFINET IO Device</li> <li>Yes</li> <li>SIMATIC communication</li> <li>Open IE communication</li> <li>Web server</li> <li>Media redundancy</li> <li>PROFINET IO Controller</li> <li>Services</li> <li>— PG/OP communication</li> <li>— S7 routing</li> <li>— Isochronous mode</li> <li>— Direct data exchange</li> <li>— IRT</li> <li>— MRP</li> <li>— MRP Automanager acc. to IEC 62439-2 Edition 2.0; MRP Manager; MRP Client; max. number of devices in the ring: 50</li> <li>— MRPD</li> <li>— PROFIenergy</li> <li>Yes; per user program</li> </ul>	Protocols	
<ul> <li>PROFINET IO Device</li> <li>SIMATIC communication</li> <li>Open IE communication</li> <li>Web server</li> <li>Media redundancy</li> <li>PROFINET IO Controller</li> </ul> Services <ul> <li>PG/OP communication</li> <li>Ser routing</li> <li>Isochronous mode</li> <li>Direct data exchange</li> <li>IRT</li> <li>MRP</li> <li>MRP</li> <li>MRPD</li> <li>MRPD</li> <li>PROFINET IO Controller</li> </ul> Yes <ul> <li>PG/OP communication</li> <li>Yes</li> <li>Services</li> <li>PG/OP communication</li> <li>Yes</li> <li>Services</li> <li>PG/OP communication</li> <li>Yes</li> <li>Services</li> <li>Yes</li> <li>Requirement: IRT and isochronous mode (MRPD optional)</li> <li>Yes</li> <li>Yes</li> <li>MRP Automanager acc. to IEC 62439-2 Edition 2.0; MRP Manager; MRP Client; max. number of devices in the ring: 50</li> <li>Yes; Requirement: IRT</li> <li>Yes; per user program</li> </ul>	• IP protocol	
<ul> <li>SIMATIC communication</li> <li>Open IE communication</li> <li>Web server</li> <li>Media redundancy</li> <li>PROFINET IO Controller</li> <li>Services</li> <li>— PG/OP communication</li> <li>— S7 routing</li> <li>— Isochronous mode</li> <li>— Direct data exchange</li> <li>— IRT</li> <li>— MRP</li> <li>— MRP</li> <li>— MRPD</li> <li>— MRPD</li> <li>— PROFIenergy</li> <li>Yes; Pequirement: IRT</li> <li>Yes; Requirement: IRT</li> <li>Yes; Per user program</li> </ul>	<ul> <li>PROFINET IO Controller</li> </ul>	Yes
Open IE communication  Yes; Optionally also encrypted  Web server  Media redundancy  Yes  PROFINET IO Controller  Services  — PG/OP communication — S7 routing — Isochronous mode — Direct data exchange — Direct data exchange — IRT — MRP  MRP  Yes; MRP Automanager acc. to IEC 62439-2 Edition 2.0; MRP Manager; MRP Client; max. number of devices in the ring: 50  Yes; per user program	<ul> <li>PROFINET IO Device</li> </ul>	Yes
<ul> <li>◆ Web server</li> <li>◆ Media redundancy</li> <li>Yes</li> <li>PROFINET IO Controller</li> <li>Services</li> <li>— PG/OP communication</li> <li>— S7 routing</li> <li>— Isochronous mode</li> <li>— Direct data exchange</li> <li>— Direct data exchange</li> <li>— IRT</li> <li>— MRP</li> <li>— MRP Manager; MRP Automanager acc. to IEC 62439-2 Edition 2.0; MRP Manager; MRP Client; max. number of devices in the ring: 50</li> <li>— MRPD</li> <li>— MRPD</li> <li>— Yes; Requirement: IRT</li> <li>Yes; Requirement: IRT</li> <li>Yes; Requirement: IRT</li> <li>Yes; Requirement: IRT</li> <li>Yes; Per user program</li> </ul>	<ul> <li>SIMATIC communication</li> </ul>	Yes
● Media redundancy  PROFINET IO Controller  Services	<ul> <li>Open IE communication</li> </ul>	Yes; Optionally also encrypted
PROFINET IO Controller  Services  - PG/OP communication Yes - S7 routing Yes - Isochronous mode Yes - Direct data exchange Yes; Requirement: IRT and isochronous mode (MRPD optional) - IRT Yes - MRP Yes; MRP Automanager acc. to IEC 62439-2 Edition 2.0; MRP Manager; MRP Client; max. number of devices in the ring: 50 - MRPD Yes; Requirement: IRT - PROFlenergy Yes; per user program	<ul><li>Web server</li></ul>	Yes
Services  - PG/OP communication Yes - S7 routing Yes - Isochronous mode Yes - Direct data exchange Yes; Requirement: IRT and isochronous mode (MRPD optional) - IRT Yes - MRP Yes; MRP Automanager acc. to IEC 62439-2 Edition 2.0; MRP Manager; MRP Client; max. number of devices in the ring: 50 - MRPD Yes; Requirement: IRT - PROFlenergy Yes; per user program	Media redundancy	Yes
<ul> <li>— PG/OP communication</li> <li>— S7 routing</li> <li>— Isochronous mode</li> <li>— Direct data exchange</li> <li>— IRT</li> <li>— MRP</li> <li>— MRP Automanager acc. to IEC 62439-2 Edition 2.0; MRP Manager; MRP Client; max. number of devices in the ring: 50</li> <li>— MRPD</li> <li>— PROFlenergy</li> <li>Yes</li> <li>Yes; Requirement: IRT</li> <li>Yes; Requirement: IRT</li> <li>Yes; per user program</li> </ul>	PROFINET IO Controller	
<ul> <li>S7 routing</li> <li>Isochronous mode</li> <li>Direct data exchange</li> <li>IRT</li> <li>MRP</li> <li>MRP Automanager acc. to IEC 62439-2 Edition 2.0; MRP Manager; MRP Client; max. number of devices in the ring: 50</li> <li>MRPD</li> <li>Yes; Requirement: IRT</li> <li>Yes; Requirement: IRT</li> <li>Yes; Requirement: IRT</li> <li>Yes; per user program</li> </ul>	Services	
<ul> <li>— Isochronous mode</li> <li>— Direct data exchange</li> <li>— IRT</li> <li>— MRP</li> <li>— MRP Manager; MRP Client; max. number of devices in the ring: 50</li> <li>— MRPD</li> <li>— PROFlenergy</li> <li>Yes</li> <li>Yes; MRP Automanager acc. to IEC 62439-2 Edition 2.0; MRP Manager; MRP Client; max. number of devices in the ring: 50</li> <li>— Yes; Requirement: IRT</li> <li>— Yes; per user program</li> </ul>	<ul><li>— PG/OP communication</li></ul>	Yes
<ul> <li>Direct data exchange</li> <li>IRT</li> <li>MRP</li> <li>MRP Automanager acc. to IEC 62439-2 Edition 2.0; MRP Manager; MRP Client; max. number of devices in the ring: 50</li> <li>MRPD</li> <li>PROFlenergy</li> <li>Yes; Requirement: IRT</li> <li>Yes; per user program</li> </ul>	— S7 routing	Yes
<ul> <li>— IRT</li> <li>— MRP</li> <li>— MRP Automanager acc. to IEC 62439-2 Edition 2.0; MRP Manager; MRP Client; max. number of devices in the ring: 50</li> <li>— MRPD</li> <li>— PROFlenergy</li> <li>Yes; Requirement: IRT</li> <li>— Yes; per user program</li> </ul>	— Isochronous mode	Yes
<ul> <li>MRP</li> <li>Yes; MRP Automanager acc. to IEC 62439-2 Edition 2.0; MRP Manager; MRP Client; max. number of devices in the ring: 50</li> <li>MRPD</li> <li>Yes; Requirement: IRT</li> <li>PROFlenergy</li> <li>Yes; per user program</li> </ul>	<ul> <li>Direct data exchange</li> </ul>	Yes; Requirement: IRT and isochronous mode (MRPD optional)
Manager; MRP Client; max. number of devices in the ring: 50  — MRPD  — PROFlenergy  Yes; Per user program	— IRT	Yes
— PROFlenergy Yes; per user program	— MRP	
	— MRPD	Yes; Requirement: IRT
— Prioritized startup Yes; Max. 32 PROFINET devices	— PROFlenergy	Yes; per user program
	— Prioritized startup	Yes; Max. 32 PROFINET devices

<ul> <li>Number of connectable IO Devices, max.</li> </ul>	128; In total, up to 256 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
— Of which IO devices with IRT, max.	64
<ul> <li>Number of connectable IO Devices for RT, max.</li> </ul>	128
— of which in line, max.	128
<ul> <li>Number of IO Devices that can be simultaneously activated/deactivated, max.</li> </ul>	8; in total across all interfaces
<ul> <li>Number of IO Devices per tool, max.</li> </ul>	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	
— for send cycle of 250 μs	$250~\mu s$ to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 625 $\mu s$ of the isochronous OB is decisive
— for send cycle of 500 μs	500 $\mu s$ to 8 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 625 $\mu s$ of the isochronous OB is decisive
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
<ul> <li>With IRT and parameterization of "odd" send cycles</li> </ul>	Update time = set "odd" send clock (any multiple of 125 $\mu s.$ 375 $\mu s.$ 625 $\mu s$ 3 875 $\mu s)$
Update time for RT	
— for send cycle of 250 μs	250 μs to 128 ms
— for send cycle of 500 μs	500 μs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— S7 routing	Yes
<ul><li>— Isochronous mode</li></ul>	No
— IRT	Yes
— MRP	Yes; MRP Automanager acc. to IEC 62439-2 Edition 2.0; MRP Manager; MRP Client; max. number of devices in the ring: 50
— MRPD	Yes; Requirement: IRT
— PROFlenergy	Yes; per user program
— Shared device	Yes
<ul> <li>Number of IO Controllers with shared device, max.</li> </ul>	4
<ul> <li>Asset management record</li> </ul>	Yes; per user program

Interface types	
RJ 45 (Ethernet)	
• 100 Mbps	Yes
<ul> <li>Autonegotiation</li> </ul>	Yes
<ul> <li>Autocrossing</li> </ul>	Yes
<ul> <li>Industrial Ethernet status LED</li> </ul>	Yes
Protocols	
Number of connections	
Number of connections, max.	96; via integrated interfaces of the CPU and connected CPs / CMs
<ul> <li>Number of connections reserved for ES/HMI/web</li> </ul>	10
<ul> <li>Number of connections via integrated interfaces</li> </ul>	64
<ul> <li>Number of S7 routing paths</li> </ul>	16
Redundancy mode	
H-Sync forwarding	Yes
SIMATIC communication	
S7 communication, as server	Yes
<ul> <li>S7 communication, as client</li> </ul>	Yes
<ul> <li>User data per job, max.</li> </ul>	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
<ul> <li>several passive connections per port, supported</li> </ul>	Yes
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
— UDP multicast	Yes; Max. 5 multicast circuits
• DHCP	No
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Web server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
OPC UA	
Runtime license required	Yes
OPC UA client	Yes
Application authentication	Yes
ppsanon admonitoditon	

— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
— User authentication	"anonymous" or by user name & password
— Number of connections, max.	4
— Number of nodes of the client interfaces,	1 000
max.	
— Number of elements for one call of	300
OPC_UA_NodeGetHandleList/OPC_UA_Rea dList/OPC_UA_WriteList, max.	
Number of elements for one call of	20
OPC_UA_NameSpaceGetIndexList, max.	
— Number of elements for one call of	100
OPC_UA_MethodGetHandleList, max.	
— Number of simultaneous calls of the client	1
instructions per connection (except OPC_UA_ReadList,OPC_UA_WriteList,OPC_	
UA_MethodCall), max.	
Number of simultaneous calls of the client	5
instructions	
OPC_UA_ReadList,OPC_UA_WriteList and	
OPC_UA_MethodCall, max.	5 000
<ul><li>— Number of registerable nodes, max.</li><li>— Number of registerable method calls of</li></ul>	100
OPC_UA_MethodCall, max.	100
<ul> <li>Number of inputs/outputs when calling</li> </ul>	20
OPC_UA_MethodCall, max.	
OPC UA server	Yes; Data access (read, write, subscribe), method call, custom
	address space
— Application authentication	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
— User authentication	"anonymous" or by user name & password
— Number of sessions, max.	32
<ul> <li>Number of accessible variables, max.</li> </ul>	50 000
<ul> <li>Number of registerable nodes, max.</li> </ul>	10 000
— Number of subscriptions per session, max.	20
— Sampling interval, min.	100 ms
— Publishing interval, min.	500 ms
Number of server methods, max.	20
<ul> <li>Number of inputs/outputs per server method, max.</li> </ul>	20
— Number of monitored items, max.	1 000; for 1 s sampling interval and 1 s send interval
<ul> <li>Number of server interfaces, max.</li> </ul>	10; or 20, depending on type of server interface
<ul> <li>Number of nodes for user-defined server interfaces, max.</li> </ul>	1 000

Yes; MODBUS TCP
200 ms; For MRP, bumpless for MRPD
50
V P: 1:1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
Yes; Distributed and central; with minimum OB 6x cycle of 625 μs (distributed) and 1 ms (central)
Yes
165
32
Yes
5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
2 500
300
100
80
Yes; Parallel online access possible for up to 5 engineering systems
Yes; Up to 8 simultaneously (in total across all ES clients)
No
8
Yes
Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
counters
counters 200; per job
counters 200; per job
counters  200; per job  200; per job
counters  200; per job  200; per job  Peripheral inputs/outputs
counters  200; per job  200; per job  Peripheral inputs/outputs
counters  200; per job  200; per job  Peripheral inputs/outputs  200
counters  200; per job  200; per job  Peripheral inputs/outputs 200  Yes

Yes; Note: The number of axes affects the cycle time of the PLC

## Interrupts/diagnostics/status information

Diagnostics	indication	LED
-------------	------------	-----

• RUN/STOP LED Yes

ERROR LEDMAINT LEDYes

• STOP ACTIVE LED Yes

Connection display LINK TX/RX

## Supported technology objects

Motion Control

	program; selection guide via the TIA Selection Tool or SIZER
<ul> <li>Number of available Motion Control resources</li> </ul>	800

for technology objects (except cam disks)

Required Motion Control resources
 per speed-controlled axis

— per positioning axis

— per synchronous axis

— per external encoder

— per output cam

— per cam track 160

— per probe 40

Positioning axis

 Number of positioning axes at motion control cycle of 4 ms (typical value)

— Number of positioning axes at motion control cycle of 8 ms (typical value)

5

Yes

40

80

80

10

# Controller

PID\_Compact
 PID\_3Step
 Yes; Universal PID controller with integrated optimization
 Yes; PID controller with integrated optimization for valves

PID-Temp
 Yes; PID controller with integrated optimization for temperature

#### Counting and measuring

High-speed counter

Yes

## Ambient conditions

#### Ambient temperature during operation

• horizontal installation, min. -25 °C; No condensation

• horizontal installation, max. 60 °C; Display: 50 °C, at an operating temperature of typically 50

°C, the display is switched off

• vertical installation, min. -25 °C; No condensation

• vertical installation, max. 40 °C; Display: 40 °C, at an operating temperature of typically 40

°C, the display is switched off

### Ambient temperature during storage/transportation

• min.	-40 °C
• max.	70 °C
Altitude during operation relating to sea level	
• Installation altitude above sea level, max.	5 000 m; Restrictions for installation altitudes > 2 000 m, see manual

Configuration		
Programming		
Programming language		
— LAD	Yes	
— FBD	Yes	
— STL	Yes	
— SCL	Yes	
— GRAPH	Yes	
Know-how protection		
User program protection/password protection	Yes	
<ul> <li>Copy protection</li> </ul>	Yes	
<ul> <li>Block protection</li> </ul>	Yes	
Access protection		
Password for display	Yes	
<ul> <li>Protection level: Write protection</li> </ul>	Yes	
<ul> <li>Protection level: Read/write protection</li> </ul>	Yes	
<ul> <li>Protection level: Complete protection</li> </ul>	Yes	
Cycle time monitoring		
• lower limit	adjustable minimum cycle time	
• upper limit	adjustable maximum cycle time	
Dimensions		
Width	35 mm	
Height	147 mm	
Depth	129 mm	

Weight, approx.	405 g
last modified:	02/04/2020

Weights