

TEST CERTIFICATE No.: INZ77307-01

Client: Project Floors (NZ) Limited
 Order No.: 104243
 Sample Description: Vinyl Plank
 Identification: Parquet
 Material Specification: Not specified
 Tested in accordance with: Client Instruction

Scope: SGS was engaged to test the leakage potential of flooring sample supplied.

Methodology: The sample was prepared by the client and sent to SGS. Two 5cm diameter areas (tee and line intersection between plank) were selected and sealed off by SGS then exposed to 5cm³ water with coloured food dye and left to soak for 24 hour at 23°C and 75% R.H. No refill required if dyed water evaporated or drained. After 24 hour duration, any remaining dyed water was removed and the underside of the flooring visually inspected for signs of leakage.

Results: No leaking was observed from the underside of the plank



Fig 1. Sample as supplied

Acceptance Criteria: Report findings

Tested by: C.Cheng	Reviewed By: Alistair Remmington	Authorised By: Kelvin Chin
Date: 2-Mar-23	08-Mar-23 <i>Alistair Remmington</i>	13-Mar-23 <i>Kelvin Chin</i>

This document is issued by the Company under its General Conditions of Service accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
 WARNING: The sample(s) to which the findings recorded herein (the "Findings") relate was(were) drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample(s). The Company accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted unless otherwise stated the results shown in this test report refer only to the sample(s) tested. Samples will be retained for two (2) weeks after test date before disposal at SGS New Zealand Limited's discretion. Returning of samples to be advised in writing. Storage (when agreed by SGS New Zealand Limited) or return of samples at client's expense.