

# VOC Content Test Certificate

Tuesday July 21<sup>st</sup>, 2009

Manufacturer: RLA Polymers Pty Ltd (67 Dalgety Drive, Manukau City Auckland New Zealand 2104)

Sample Description: ProjectBond carpet adhesive

Date Tested: July 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<h2>Specification</h2> <p><b>New Zealand Green Building Council Green Star NZ Office 2009 IEQ-3 Green Star NZ Office Interiors IEQ-3</b></p>	<h2>ProjectBond</h2>
<p>Indoor Carpet Adhesive 50 grams per Litre as VOC content material</p>	<p><b>46 grams per Litre as VOC content material</b></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F0907-16