



VOC Content Test Certificate

Issue Date: Friday November 30th 2018

Manufacturer: RLA Polymers NZ Ltd. (24 – 28 Lady Ruby Dr. Auckland, New Zealand)

Sample Descripton: Projectstick 3

Standard: SCAQMD Method 304-91 Determination of Volatile Organic Compound (VOC) in various materials as referenced by South Coast Air Quality Management Division.

Test Result:

<u>Specification</u> SCAQMD Method 304 – 91 Rule 1168	Projectstick 3 Adhesive
Indoor Adhesive 50 grams per Litre as VOC content material	VOC Content material (g/L) 13

Calculation based on the above standard by RLA Polymers NZ Ltd.

John Harvie (BSc)
Director
RLA Polymers NZ Ltd



RLA Polymers NZ Ltd. 24 – 28 Lady Ruby Drive. East Tamaki. Auckland. New Zealand.

P: (09) 267 2772 F: (09) 268 0305 E: info@rlapolymers.co.nz W: www.rlapolymers.co.nz