

Anatek Labs, Inc.

1282 Alturas Drive • Moscow, ID 83843 • (208) 883-2839 • Fax (208) 882-9246 • email moscow@anateklabs.com
504 E Sprague Ste. D • Spokane WA 99202 • (509) 838-3999 • Fax (509) 838-4433 • email spokane@anateklabs.com

Client: HIGHWATER FILTERS
Address: 325 S. ALDER ST.
COLVILLE, WA 99114

Batch #: 150729058
Project Name: FLUORIDATED WATER

Attn:

Analytical Results Report


Sample Number	150729058-001	Sampling Date	7/2/2015	Date/Time Received	7/29/2015 10:20 AM
Client Sample ID	H OHM	Sampling Time	8:32 AM	Extraction Date	
Matrix	Drinking Water	Sample Location			
Comments					

Parameter	Result	Units	PQL	Analysis Date	Analyst	Method	Qualifier
Fluoride	1.30	mg/L	0.1	7/30/2015 9:15:00 AM	MJL	EPA 300.0	

Sample Number	150729058-002	Sampling Date	7/2/2015	Date/Time Received	7/29/2015 10:20 AM
Client Sample ID	H OHM	Sampling Time	8:39 AM	Extraction Date	
Matrix	Drinking Water	Sample Location			
Comments					

Parameter	Result	Units	PQL	Analysis Date	Analyst	Method	Qualifier
Fluoride	0.485	mg/L	0.1	7/30/2015 9:30:00 AM	MJL	EPA 300.0	

Authorized Signature


Kathy Sattler, Lab Manager

MCL EPA's Maximum Contaminant Level
ND Not Detected
PQL Practical Quantitation Limit

This report shall not be reproduced except in full, without the written approval of the laboratory.
The results reported relate only to the samples indicated.
Soil/solid results are reported on a dry-weight basis unless otherwise noted.

Anatek Labs, Inc.

1282 Alturas Drive • Moscow, ID 83843 • (208) 883-2839 • Fax (208) 882-9246 • email moscow@anateklabs.com
504 E Sprague Ste. D • Spokane WA 99202 • (509) 838-3999 • Fax (509) 838-4433 • email spokane@anateklabs.com

Login Report

Customer Name: HIGHWATER FILTERS

325 S. ALDER ST.

COLVILLE

WA

99114

Order ID: 150729058

Order Date: 7/29/2015

Contact Name:

Project Name: FLUORIDATED WATER

Comment:

Sample #: 150729058-001 **Customer Sample #:** H OHM

Recv'd: **Matrix:** Drinking Water **Collector:** HILARY OHM

Date Collected: 7/2/2015

Quantity: 1 **Date Received:** 7/29/2015 10:20:00 AM

Time Collected: 8:32 AM

Comment:

Test	Lab	Method	Due Date	Priority
FLUORIDE	S	EPA 300.0	8/5/2015	<u>Normal (~10 Days)</u>

Sample #: 150729058-002 **Customer Sample #:** H OHM

Recv'd: **Matrix:** Drinking Water **Collector:** HILARY OHM

Date Collected: 7/2/2015

Quantity: 1 **Date Received:** 7/29/2015 10:20:00 AM

Time Collected: 8:39 AM

Comment:

Test	Lab	Method	Due Date	Priority
FLUORIDE	S	EPA 300.0	8/5/2015	<u>Normal (~10 Days)</u>

SAMPLE CONDITION RECORD

Samples received in a cooler?	USPS
Samples received intact?	Yes
What is the temperature of the sample(s)? (°C)	21.4
Samples received with a COC?	Yes
Samples received within holding time?	Yes
Are all sample bottles properly preserved?	Yes
Are VOC samples free of headspace?	N/A
Is there a trip blank to accompany VOC samples?	N/A
Labels and chain agree?	Yes

