#### **Autonics**

# **TEMPERATURE CONTROLLER** TC3YT SERIES



Thank you very much for selecting Autonics products. For your safety, please read the following before using.

#### Caution for your safety

\*Please keep these instructions and review them before using this unit.

\*Please observe the cautions that follow

⚠ Warning Serious injury may result if instructions are not followed. ⚠ Caution Product may be damaged, or injury may result if instructions are not followed.

\*The following is an explanation of the symbols used in the operation manual.

\$\triangle \tau \text{caution: Injury or danger may occur under special conditions.}\$

#### **⚠** Warning

- In case of using this unit with machineries(Nuclear power control, medical equipment, vehicle, train, airplane, combustion apparatus, entertainment or safety device etc), it requires installing fail-safe device, or contact us for information on
- type required.
  It may result in serious damage, fire or human injury
  2. It must be mounted on Panel.
- It may give an electric shock.

  3. Do not connect terminals when it is power on.
- It may give an electric shock.

  4. Before connecting power, check the terminal number.
- It may give an electric shock and cause a fire.

  1. It may give an electric shock and cause a fire.

# **⚠** Caution

- This unit shall not be used outdoors.
  It might shorten the life cycle of the product or give an electric shock.
  For wire connection, No.12-28AWG should be used and screw bolt on terminal block with 0.3N·m to 0.4N·m strength.
- It may result in malfunction or fire due to contact failure
- 3. Please observe specification rating.
  It might shorten the life cycle of the product and cause a fire

- It might shorten the life cycle of the product and cause a fire.

  4. Do not use the load beyond rated switching capacity of Relay contact.

  It may cause insulation failure, contact melt, contact failure, relay broken, fire etc.

  5. In cleaning the unit, do not use water or an oil-based detergent

  It might cause an electric shock or fire that will result in damage to the product.

  6. Do not use this unit at place where there are flammable or explosive gas, humidity, direct ray the sun, radiant heat, vibration, impact etc.
- It may cause explosion.


  7. Do not inflow dust or wire dregs into inside of this unit.
- It may cause a fire or mechanical trouble.

  8. Before connecting wires, check the terminal polarity.
  It may cause a fire or explosion.


### Front panel identification



- 1 PV(Process value) display(Red)
- 2 Minus display(Red)
- 3 Controlling a set value(MD, UP, DOWN) 4 Display an operation of control output (Red)
- 5 Display a deviation between PV(Process value) and SV(Set value) : ▲, ▼(Red) /
- ☐(Green) 6 PV(Process value) °C/°F unit display(Yellow)




## Connections



## Set and change a SV

## **○Display for power ON**

For power ON, it displays current temperature after temperature sensor and the type of control output flicker twice(every 1 sec). In case of error, Error signal flickers instead of current temperature.



## ○Check and set a SV(Setting Value)

- •SV can be checked and set on operation mode Press MD key on operation mode.
- ①Operation mode(display a current temperature)

- 250 Press (mus) Flicker(every 1 sec)

②SV is flicker(2 times) Flicker(every 1 sec)

○Set by

▲ (▼ key Press MD one time Flicker(every 1 sec) <u>- 300</u> Display a set value or an initial value MD ⑤ Setting MD ③To check a SV

①PV is displayed on operation mode,

②Press MD key, the SV is indicated after "5" is flickering 2 times.

③In case of checking the SV only, after check it pressing MD key, then it returned to the drive mode.

 ⊕In case of changing and setting the SV, set it with ▲ ,▼ keys. If you press ▲ ,▼ keys continuously, the SV is increased/decreased with high-speed. (3) If press MD key after setting, the set value is saved and the mode returns to operation

\*When there is no input for 1 min. for setting operation, it returns to operation mode and the parameter set value is not changed the prior value is saved.

## Input specification and range

Input		Using range		
Sensor	Parameter	°C	°F	
K	F.C.B	0 ~ 999	32 ~ 999	
J	JI E	0 ~ 400	32 ~ 752	
Pt H	PEH	0 ~ 400	32 ~ 752	
Pt L	PE!	-99 ~ 199	-146 ~ 390	

- \*\*A temperature sensor converts temperature into electrical signal so that a controller can do ON/OFF the control output.

  \*\*The setting is available with the using range.

  \*\*The setting range of the SV is limited within the using temperature range.

  \*\*Using temperature: It can be set as "C, "F are displayed on the front side.

- \*The above specification are changeable without notice anytime


### Ordering information

<u>TC 3 Y</u>	T - B 4 R 3
1 2 3	<u>(4)</u> <u>(5)</u> <u>(6)</u> <u>(7)</u> <u>(8)</u>
① Item TC	Temperature Controller
② Digit 3	3 Digit
③ Size Y	DIN W72×H36mm
Setting type  T	Touch S/W single setting type
⑤ Control mode B	ON/OFF and proportional control(common use)
Power supply 4	100-240VAC 50/60Hz
① Control output R	Relay output
Relay capacity	250VAC 3A 1c
16	250VAC 16A 1c

### Specifications

Model		TC3YT-B4R3	TC3YT-B4R16	
Power supply		100-240VAC 50/60Hz		
Allowable	voltage range	90 to 110% of rated voltage		
Power co	nsumption	Approx. 4VA		
Display method		7Segment Red LED Display [Deviation "□" signal(Green), unit display(Yellow)]		
Character size		W7.4 × H15mm		
Input type	9(※)	TC:K(CA), J(IC), RTD: Pt100Q(DIN)		
Control o	utput	Relay output 250VAC 3A 1c	Relay output 250VAC 16A 1c	
Control m	nethod	ON/OFF and proportional control (common use)		
Hysteresi	S	1 ~ 100°C		
Proportio	nal band	0 ~ 100%		
Offset co	rrection	0 ~ 100%		
Control period		1 ~ 120sec		
Display method		±1digit with a bigger one of ±0.5% of PV or ±1℃		
Setting type		Setting by front push buttons		
Sampling period		500ms		
Dielectric strength		2000VAC 60Hz for 1 minute(between external terminal and case)		
Vibration		0.75mm amplitude at frequency of 10 to 55Hz in each of X, Y, Z directions for 1 hours		
D-1	Mechanical	Min.10,000,000 times		
Relay life cycle	Malfunction	Min.100,000 times (250VAC 3A resistive load)	Min.100,000 times (250VAC 16A resistive load)	
Insulation	resistance	Min. 100MΩ (at 500VDC)		
Noise stre	ength	±2kV R-phase and S-phase (pulse width 1 μs)		
Memory retention		Approx. 10 years (When using non-volatile semiconductor memory type)		
Ambient temperature		-10 ~ 50°C (at non-freezing status)		
Storage temperature		-20 ~ 60°C (at non-freezing status)		
Ambient h		35 ~ 85%RH		
Protection		IP65		
Weight		Approx. 99g	Approx. 103g	
₩NTC se	ensor input is	s optional.		

## Flow chart for first setting group




- •In operation mode, if press MD key for 2 sec., it enters setting group 1.

  At the beginning of MD key input, 5 υ signal is displayed. And then ρ signal, the first mode of group 1 is displayed for 2~3 sec. It enters the first mode of group 1 for finishing press MD.
- Parameter will be displayed when entering setting mode.
- Press MD key one time, parameter move to the next. Moreover for changing a set value, press key. (Set value is flickering every one sec.)
- •Press a MD key after changing a set value or for the statue of setting change, the setting value is saved and the parameter is changed to the next.
- ●In any moment during the setting operation, if press MD key for 3 sec., the changed
- value is saved and the mode is changed to operation mode. •When there is no input for 1 min. for setting operation, it returns to operation mode and the parameter set value is not changed the prior value is saved.

  •When P is not "0", [ HYS ] parameter is not displayed.
- •When P is "0", ON/OFF control, [£] and [-5£] parameter is not displayed.

  \*When it is entered to the setting mode for all cases, applicable parameters will be

## Flow chart for second setting group



- ●In operation mode, if press MD key for 4 sec., it enters setting group 2 At the beginning of  $\overline{MD}$  key input,  $5 \omega$  signal is displayed. And then P signal, the first mode of group 1, is displayed for  $2\sim3$  sec. for the moment of 4 sec past,  $I \cap L$ , the first mode of setting group 2, is displayed. It enters the first mode of group 2 for finishing
- Parameter will be displayed when entering setting mode
- •Press MD key one time, parameter move to the next. Moreover for changing a set value, press Akey. (Set value is flickering every one sec.)

  •Press a MD key after changing a set value or for the statue of setting change, the
- setting value is saved and the parameter is changed to the next. •In any moment during the setting operation, if press MD key for 3 sec., the changed
- value is saved and the mode is changed to operation mode.

  •When there is no input for 1 min. for setting operation, it returns to operation mode
- and the parameter set value is not changed the prior value is saved. \*When it is entered to the setting mode for all cases, applicable parameters are displayed. ₩When the unit of the using temperature is changed, the SV is changed as 0°C

#### Functions

### OInput correction [In.b]

- •Input revise corrects the deviation, occurred from temperature sensor such as
- thermocouples, RTD, Analogue sensor etc.

  There are grades for temperature sensor and high accuracy one is a high price,
- normal products are usually used. Check the deviation of every thermo sensor precisely to measure temperature accurately.

  •Use this mode after measuring deviation occurred from temperature sensor exactly
- because if measured deviation value is not correct, displayed temperature will be too
- high or too low.
  •Setting range: -49 ~ 50°C (Factory default: 0°C)
  Ex)When even though current temperature is 80°C, display value is 78°C, input correction value should be 2 to display 80℃. ©Hysteresis [ ਮੁਪੁ5 ]

- In the ON/OFF control, the ON/OFF interval of the output is required, this interval is hysteresis. When this interval is too narrow, it causes hunting such as chattering by external noise.
   For ON/OFF control, even when control is stable, there is hunting.
- Because the hunting is generated by combined cause, HY5 set value, response spec, sensor position, etc., it is not regular. To minimize it, proper HY5 value, the capacity and characteristic of heater, and response and position of sensor need to be considered.

  Setting range: 1 ~ 100°C (Factory default: 2°C)
- Proportional band[P]
   If current temperature(PV) is within the proportional control, it controls the ratio of ON and OFF during proportional control. At this moment the term of proportional control
- for set value is called proportional band

  •Setting range: 0 ~ 100%(Factory default: 0%)

- The set time is called proportional control period.
  Setting range: 1 ~ 120s(Factory default: 10s)

## **⊘Setting** range

- ♦ Hysteresis / proportional band / proportional period is set on parameter
   ♦ Setting range of hysteresis [ № 5 ] : 1 ~ 100 °C
   ♦ Setting range of proportional band [ P ] : 0 ~ 100%
   ♦ Setting range of control period [ £ ] : 1 ~ 120sec
   ♦ ON/OFF control → Proportional control conversion: When P is 0%, it is ON/OFF control:
- if there is a value for P, is proportional control. The parameter of hysteresis [HY5] appears when [P], proportional band, is 0%.

### Offset correction / Manual reset [ -5]

- •When use the proportional control, even when it is stable statue, deviation can occur
- when use in epoportional control, even when it is stable statue, deviation can occur because of heat capacity and heater capacity. It is called offset.


   Offset is set on the parameter of inner manual reset [r5t].

   Offset correction is used only for proportional control. (Not for [P]=0%). Therefore if proportional band [P] is set as 0%, manual reset parameter [r5t] is not shown.

   Setting range: 0~100% (Factory default: 50%)

   Set a value as 50% when PV is equal to SV. After control is stable, if measured temperature is lower than SV, set value is over than 50%, otherwise lower than 50%.

   Controlling a manual reset[r5t] by control result
- ●Controlling a manual reset[ -5₺] by control result Set a reset lower than 50



#### OControl mode switch

- ON/OFF control Proportional control.
  ON/OFF control Proportional control conversion:
  When P is 0%, it is ON/OFF control: if there is a value for P, is proportional control.
  Factory default: ON/OFF control(P: 0%)

#### OThe conversion of temperature unit(°C / °F)[ Unt ] •By choosing °[ or °F on temperature unit setting parameter, [Unc] conversion is available.

- After choosing a temperature unit, LED is ON.
   Factory default : °C Cooling / Heating operation
- •Generally there are two ways to control temperature, one(heat-function) is to heat when PV is getting down(heater). The other(cool-function) is to cool when PV is getting

#### high refrigerator). •Setting range: HEt(Heat) / Col(Cool) (factory default : HEt)

- ODisplay a PV deviation
- Display a PV deviation
  It displays the deviation between the PC and the SV.
  When the PV is higher than the SV(PV > SV+2°), △ is lighted.
  When the PV is lower than the SV(PV < SV-2°), ▽ is lighted.</li>
  When the deviation of the PV is within ±2°c, □ is lighted.
- OHigh/low limit setting for using temperature •Set a high/low limit of temperature and the set range is within using range.
- ●If setting a high-limit of temperature on [H.5E], it is a high-limit SV
  ●If setting a low-limit of temperature on [L.5E], it is a low-limit SV.
  ●L.SC ≤ SV ≤ H.SC. In case of L.SC= SV = H.SC, the output is OFF.
  ●If change L.SC and H.SC, the using range and proportional band also are changed.
- OError display
- •If Error occurs during the operation, error signal flickers every one sec. Display Description oPn When the input sensor is not connected or its wire is cut. (Normal operation after connecting a sensor) LLL When the measured input temperature is lower than input range of the sensor. When the measured input temperature is higher than input range of the sensor.
- •When error [ oPn] / [LLL] / [ HHH ] occur After the causes of error is solved, it operates normally.

## •The priority of 'Error' display : □Pn → HHH, LLL

- Output setting for error[ o.E r ] For error, the statue of output is set by [o.Er.] of setting group 2.

  For setting OFF: Output is always OFF for error.

  For setting ON: Output is always ON for error.

  Factory default: OFF

- OLock setting[Lo[]
- •This function limits the change of parameters on each setting group.
- It can be set setting group 2.

  •For setting [LE1], changing the parameter, "Setting group 2", is not available.

  •For setting[LE2], changing the parameter, "Setting group 1 + Setting group 2", is
- For setting [L[3], changing the parameter, "Setting group 1 + Setting group 2 + SV setting parameter", is not available.
  •For setting [oFF], Lock off for all setting group

## Factory default

	ting group			
Parameter	Description	Setting range	Unit	Factory default
Ρ	Proportional band	0 ~ 100	%	0
Ł	The period of proportional control	1 ~ 120	sec	10
r 5 Ł	The correction value of offset for proportional control	0 ~ 100	%	50
HYS	Hysteresis for ON/OFF control	2 ~ 100	°C	2
1 0.6	Input correction value	-30 ~ 30	°C	Π

Second	setting group			
Parameter	Description	Setting range	Unit	Factory default
1 0.5	Temperature sensor	ECA, JI C, PEH, PEL	-	JI E
H.5 [	High-limit value of using temperature	See "Input specifications	°C	400
L.5 C	Low-limit value of using temperature	and range"		0
o.F E	Cooling/Heating operation	HEŁ <b>←→</b> [ol	1-	HEL
o.E r	Output for error	on★≯oFF	-	oFF
Unt	Temperature unit	o[ <b>←→</b> ot	-	٥٢
1.05	Lock	-EE 1 [ 1 1 [ 2 1 [ 2	_	- C C

## Caution for using

- Installation environment
  Olt shall be used indoor.
  ②Altitude Max. 2000m.
  ③Pollution Degree 2.
  ②Altitude Max. 2000m.
  ④Installation Category II.
  3. The switch or circuit—breaker should be installed near by users.
  4. Do not use this product as Volt—meter or Ampere—meter, this is a temperature controller.
  5. Be sure to use compensating wire when extends wire from controller to thermocouple, otherwise the temperature deviation will be occurred at the part where wires are connected to each other.
  6. In case of using RTD sensor, 3wire type must be used. If you need to extend the line, 3wires must be used with the same thickness as the line. It might cause the deviation of temperature if the resistance of line is different.
  7. In case of making power line and input signal line closely, line filter for noise protection should be installed at power line and input signal line should be shelieded.
  8. Keep away from the high frequency instruments. (High frequency welding machine, large capacity SCR controller)

  \*\*It may cause malfunction if above instructions are not followed.
- \*It may cause malfunction if above instructions are not followed.

## Main products

- COUNTER
  TIMER
  - TIMER TEMPERATURE CONTROLLER PANEL METER TACHO/LINE SPEED/PULSE METER
- TACHO/LINE SPEED/PULSE METER

  DISPLAY UNIT
  PROXIMITY SENSOR
  PHOTOELECTRIC SENSOR
  FIBER OPTIC SENSOR
  PRESSURE SENSOR
  ROTARY ENCODER
  SENSOR CONTROLLER
  POWER CONTROLLER
  STEPPING MOTOR & DRIVER & CONTROLLER
  LASER MARKING SYSTEM(CO2, NG:YAG)

- Bidg. 402 3rd Fl., Bucheon Techno Park, 193, Yakdae-dong, Wonmi-gu, Bucheon-si, Gyeonggi-do, 420-734, Korea TEL:82-32-610-2730 FAX:82-32-329-0728 ■E-mail: sales@autonics.net

HEADQUARTERS

■INTERNATIONAL SALES :

Autonics Corporation

http://www.autonics.com

Satisfiable Partner For Factory Automation

41-5, Yongdang-ri, Ungsang-eup, Yangsan-si, Gyeol 626-847, Korea

EP-KE-03-0310