



REMARK:
 1.HDGS:Hot Dip Galvanized Steel.
 2.A.C:Aluminum Alloy Cast.
 3.ST.S:Stainless Steel.

Item	Description	M.T	Specification	Qt'y
1	Fan Motor		10HP*6P	1 pcs
2	Belt Reducer		VBA-075-B	1 set
3	Motor Frame Ass'y	HDGS		1 set
4	Fan	A.C	LSF-240	1 set
5	Fan Guard	HDGS		1 set
6	Casing	F.R.P		8 pcs
7	Hand Hole	E.V.A		1 pcs
8	Sprinkler Head	A.C	LSH-200	1 set
9	Sprinkler Pipe	P.V.C		6 pcs
10	Eliminator	F.R.P		6 pcs
11	Tension Device	HDGS		6 set
12	Stand Pipe	P.V.C		1 set
13	Filling	P.V.C		1 set
14	Stopper or Column	HDGS		1 set
15	Filling Supportor	HDGS		1 set
16	Casing Supportor	HDGS		8 pcs
17	Inlet Louver	P.V.C		1 set
18	Frame Ass'y	HDGS		1 set
19	Water Basin	F.R.P		8 pcs
20	Water Sump	F.R.P		1 pcs
21	Ladder&Safety Cage/Handrail	HDGS	OSHA	1 set
22	Strainer	ST.S		1 pcs
23				

Drain	50 A(2 ")	Over Flow	50 A(2 ")
Outlet	200A(8 ")	Quick Filler	32A(1-1/4")
Inlet	200A(8 ")	Automatic Filler	32A(1-1/4")
Pipe Connections			
Dry Weight	2,996 LBS	Operating Weight	10,164 LBS
Loading Data			
Ambient Wetbulb	80.6°F	Air Volume	77,020 Ft ³ /MIN
Outlet Water Temp	89.6°F	Water Flow	1202 GPM
Inlet Water Temp	98.6°F	Cooling Capacity	5409000 BTU/HR
Design Condition			
Modified No.	Date	Modifier	Approver
	T-2350		
TITLE	Cooling Tower Outline Drawing		C.T.S
	IN	✗	'21.04.09
	DWG NO.		