

MITSUBISHI W001CP R61Y23304 Reverse EngineeringVersion 1.0 Mar 21st, 2018.


<https://github.com/bt4wang/HVAC-IR-Control>

Exploration of a frame:


HVAC MITSUBISHI_ DEFINE	LIB VALUE μs	INDEX
HVAC_MITSUBISHI_HDR_MARK	3400	A
HVAC_MITSUBISHI_HDR_SPACE	1750	B
HVAC_MITSUBISHI_BIT_MARK	450	C
HVAC_MITSUBISHI_ONE_SPACE	1300	D
HVAC_MISTUBISHI_ZERO_SPACE	420	E
HVAC_MITSUBISHI_RPT_MARK	440	F
HVAC_MITSUBISHI_RPT_SPACE	17100	G

Note: You don't need to repeat the frame for this model.

Trame start:



Trame end:



This article is based on Vincent(r45635)'s former works. His works can be reached <https://github.com/r45635/HVAC-IR-Control>

HVAC Remote protocol data information:

BYTE0								BYTE1								BYTE2								BYTE3								BYTE4								BYTE5								BYTE6								BYTE7								BYTE8							
Constant								Constant								Constant								Constant								Constant								On/Off								Temperature/Mode								Vanne/Fan								Timer Mode							
0x23								0xCB								0x26								0x21								0x0								0x40								0x52								0x35								0x4							
0	1	2	3	4	5	6	7	0	1	2	3	4	5	6	7	0	1	2	3	4	5	6	7	0	1	2	3	4	5	6	7	0	1	2	3	4	5	6	7	0	1	2	3	4	5	6	7	0	1	2	3	4	5	6	7	0	1	2	3	4	5	6	7								
Header																																On=1 / Off=0								T=X+16				Mode				Vanne				Fan				Timer Mode															
0 0 1 0 0 0 1 1 1 1 0 0 1 0 1 1 0 0 1 0 0 1 1 0 0 0 1 0																																																																							