



System Tested and Certified by NSF International against NSF/ANSI Standard 177 for the reduction of free available Chlorine.



Model: SF-7C

PERFORMANCE DATA SHEET

NSF/ANSI STANDARD 177

This System has been tested according to NSF/ANSI Standard 177 for the reduction of free available chlorine. The concentration of free available chlorine in water entering the System was reduced to a concentration less than or equal to the permissible limit for water leaving the System, as specified by NSF/ANSI Standard 177. The System has not been evaluated for free

available chlorine reduction performance in the presence of chloramines. Free available chlorine reduction performance may be impacted by the presence of chloramines in the water supply. Please contact your local water utility to determine if chloramines are used in treating your water.

SPECIFICATIONS (SF-7C)

Installation Shower
 EPA Establishment Number 63018-NV-001
 Rated Capacity (per Cartridge) 10,000 gallons (37,854 L)
 Replacement Filter Cartridge RCSF-7
 Rated Service Flow @ 80 psi 2.5 gal/min (9.46 L/min)
 Housing Construction High Impact ABS

Maximum Working Pressure 100 psig (689.5 kPa)
 Minimum Working Pressure 30 psig (206.8 kPa)
 Maximum Operating Temperature 140° F (60° C)
 Minimum Operating Temperature 34° F (1° C)

U.S. Patent Number: 5,545,314

1. Minimum chlorine reduction per NSF/ANSI 177: ≥50% of free available chlorine (FAC) when used with an influent challenge water of 2 mg/L FAC. Average chlorine reduction of this System per NSF/ANSI 177: 94.8%.
2. For this System to continue to perform as tested and represented, use only genuine, NSF certified WaterChef® RCSF-7 filter cartridges.
3. The actual capacity of your filter cartridge may vary from the rated capacity. This may be due to the volume of contaminants actually present in your water supply. Replace the filter cartridge when the first of the following occurs:
 - Every six months
 - When you notice an odor recurrence
 - When the rated capacity of the filter cartridge has been reached
4. Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the System.
5. Installation of this product must comply with all state and local laws and regulations. Refer to your local agencies for details.

6. The contaminants or other substances removed or reduced by this System are not necessarily in all users' water.
7. The approximate cost for a shower filter cartridge is \$27.00 or less.
8. For limited warranty and installation and operating instructions, please refer to the Installation, Use & Care Guide.
9. For more information regarding the purchase of genuine, NSF certified WaterChef® filter cartridges and replacement parts, contact:

WaterChef Customer Care
 3760 Barron Way
 Reno, NV 89511
 tel: 1.800.879.8909
 email: customercare@waterchef.com
 web: www.waterchef.com

