# Power. Sheet.

CR-185 Commercial Deep Cycle






Crown Battery Manufacturing's team of research and development engineers welcome the opportunity to discuss your technical requirements during the design and specification stage. To access this technical assistance, please contact:

**Crown Battery Manufacturing's Product Support Department** +1.419.334.7181 | sales@crownbattery.com | Fax +1.419.334.7124

#### **AVAILABLE TERMINAL STYLES:**



#### **VENT CAP OPTIONS:**







#### **PHYSICAL SPECIFICATIONS**

BCI Group	Model Description	Nominal Voltage	Length							erminal Height		ight	Cover & Container Material	Case to Cover Seal Method
Size			in	mm	in	mm	in	mm	in	mm	lbs	kgs	Container Material	Scal Mctilou
921	CR-185	12	15.50	394	7.00	178	13.52	343	14.63	372	107	48.5	Polypropylene Plastic	Heat Seal

#### **ELECTRICAL SPECIFICATIONS**

Ampere Hour Capacity (Ah)						Discharge Capacity Minutes					KWH (kWh)	Internal Resistance	
100 Hr	72 Hr	48 Hr	20 Hr	10 Hr	5 Hr	2 Hr	100A	75A	50A	25A	10A	100 Hr	80°F/27°C
226	218	202	185	157	150	113	59	85	139	326	1000	2.712	9.1mΩ

#### **CHARGING INSTRUCTIONS:**

Crown Battery Manufacturing Company specifies the following standard battery charge profile for the CR-185 deep cycle battery when used in an electric vehicle service:

**Phase 1: Constant Current (I1)** I1 = highest amperage available < 55 amps

**Phase 1: Constant Current (I1)** I1 = minimum amperage available > 20 amps Normal transition to Phase 2 at 2.37 Volts Per Cell.

Safety transition to END OF CHARGE of dV / dt < 0V / 1 hr, dt = 1 hr. (NEGATIVE SLOPE).

Timeout for Phase 1 = 10 hours.

Phase 2: Constant Voltage (U2) U2 = 2.37 VPC

Normal Transition to Phase 3 at 12 = 5.0 amps or approximate. Safety transition to END OF CHARGE of  $1 \, dI/dt \, I < 0.4$  amp  $/ 1 \, hr$ ,  $dt = 1 \, hr$ . **Phase 3: Constant Current (I3)** 13 = 5.0 amps or approximate

Normal transition to END OF CHARGE at 115 - 118% of AH returned.

PLEASE CONTACT CROWN BATTERY MANUFACTURING COMPANY TO ADVISE THE SPECIFIC CHARGE TERMINATION METHOD USED.

Timeout for charging phases 1 - 3 at 16 hours.

Temperature compensation coefficient = +/- 3 mV / °C.

Recommended Equalization Charge: Every seven (7) days. 4 additional hours at normal finish rate of 5.0 amps.

Safety transition to END OF CHARGE at maximum voltage of 2.7 VPC.

1445 Majestic Drive | P.O. Box 990 | Fremont, OH USA | 419.334.7181 | Fax 419.334.7124 | www.crownbattery.com | Made in U.S.A.


## **CR-185 Commercial Deep Cycle Battery**


#### **APPLICATION RECOMMENDATIONS**


Specific Gravity	Operating Temperature Range	Self Discharge	Terminal Torque Specifications
Fully charged battery specific gravity (100% state-of-charge) is 1.275  Fully discharged battery specific gravity (100% depth-of-discharge) is 1.125	-40°F to 120°F (-40°C to 49°C). Flooded lead acid battery capacities are temperature sensitive: refer to the temperature / capacity projection chart below to identify available capacity at the application operating temperature. <b>Application Note:</b> Maintain a state of charge greater than 60 percent when operating flooded lead acid batteries at temperatures below 32°F (0°C).	Fully charged batteries that are stored at a temperature of 80°F (27°C) will self-discharge at a rate of 3.5% per week.	SAE / Automotive Terminal Style: 50 to 70 in-lbs / 6 to 8 Nm Stainless Threaded Terminal (Types C, S, Z): 100 to 120 in-lbs / 11 to 14 Nm

Application Note: Lead acid batteries contain corrosive battery electrolyte and generate highly flammable hydrogen gas. When working near batteries wear protective clothing, gloves, and safety glasses when handling batteries and electrolyte and always work in a well-ventilated area. Do not over-torque terminals. Over-torque can result in terminal damage, breakage, terminal meltdown or fire.

Crown Battery's flooded lead acid deep cycle batteries require periodic preventative maintenance and effective charging service to ensure dependable service life. Customers can find Crown Battery's recommended best practices for deep cycle battery care, maintenance and application at www.crownbattery.com/en/wp-content/uploads/2012/10/SafetyFirst-DeepCycle2.pdf or by contacting Crown Battery to request this information.







#### TYPICAL BATTERY CYCLE LIFE / DEPTH OF DISCHARGE

Battery Model	100% DOD Cycles			End-Cycle Voltage			_	End-Cycle Voltage
CR-185	450	1.75 VPC	1050	1.94 VPC	1310	1.97 VPC	2600	2.05 VPC

The battery life references presented above are estimations based upon stationary life cycle testing conducted at Crown Battery Manufacturing's Testing Center in Fremont, Ohio USA. The data references are nominal and should not be construed as maximum or minimum values for specifications or for final design. Data for this product type may vary from that shown herein, and Crown Battery makes no warranties — expressed or implied — based upon the data shown above.

### **Effect of Battery Temperature on Battery Life**

Lead acid batteries are electrochemical storage devices that store and release chemical energy upon demand in the form of electricity. By virtue of their design lead acid batteries are highly reactive to temperature — with the rate of chemical reactions that occur within the battery being affected by the operating temperature where the battery is used. Higher operating temperatures will result in faster chemical reactions within the battery — delivering improved discharge performance; conversely, cooler operating temperatures will result in slower internal chemistry. However, higher operating temperatures also result in shortened battery life as the increased rate of chemical reactions will accelerate the rate of deterioration of internal components.

Typical battery life is based upon a baseline operating temperature of  $80^{\circ}F/27^{\circ}C$ . Temperature increases of  $15^{\circ}F/10^{\circ}C$  over the baseline will cause the battery's rate of internal chemical reactions to double — something that will reduce battery life due to the accelerated deterioration of internal components. Please contact Crown Battery to discuss any minimal requirements for battery life when operating batteries in temperatures greater than  $80^{\circ}F/27^{\circ}C$ .



1445 Majestic Drive | P.O. Box 990 Fremont, OH 43420-0990 USA +1.419.334.7181 | Fax +1.419.334.7124 www.crownbattery.com sales@crownbattery.com

The data shown are nominal and should not be construed as maximum or minimum values for specification or final design. Data for this product type may vary from that shown herein.

Visit our website at www.crownbattery.com

©2013 Crown Battery Manufacturing Company