



NOTES:

1. CONNECT LINE LEADS TO L1 AND L2.
 LOW VOLTAGE: CONNECT AS SHOWN.
 HIGH VOLTAGE: MOVE LEAD J TO TERM. 3.
 MOVE LEAD 2 TO TERM. 4.
2. CONNECTIONS ARE SHOWN FOR OPPOSITE STANDARD ROTATION (CW FACING END OPPOSITE SHAFT EXTENSION). INTERCHANGE 5 AND 8 INTERNALLY FOR STANDARD ROTATION.
3. MULTIPLE CAPACITORS ARE CONNECTED IN PARALLEL UNLESS OTHERWISE SPECIFIED.
4. LEAD COLORS ARE OPTIONAL. LEADS MUST ALWAYS BE NUMBERED AS SHOWN.

| | | | |
|---|----------------------|--------------------------------|--|
| REV. DESC: REMOVE OPTIONAL THERMAL CONNECTION | | | |
| REV. LTR: F | VERSION: 01 | TDR: 000000373039 | |
| ∟03000 | FILE: \AAA\00007\308 | REVISED: 11: 45: 00 08/11/2005 | |
| | MTL: - | BY: ENJOEPO | |

BALDOR ELECTRIC Co.

TYPE L, DV, FIX ROT, THERMAL, TERMINAL PLATE (OPP STD)