



CUSTOMER ONLY NOTE: FOR VERTICAL SHAFT UP LIFTING, REMOVE EYEBOLT FROM TOP OF MOTOR AND SCREW INTO END OF SHAFT.

CUSTOMER IS RESPONSIBLE FOR DETERMINING THAT BALDOR'S PRODUCT WILL PERFORM SUITABLY IN THE INTENDED APPLICATION.

REV. DESC: REMOVED LOCKNUT		
REV. LTR: A	VERSION: 01	TDR: 000001108985
FILE: \AAA\00220\838	REVISED: 11:01:33 06/19/2019	BY: ENSHABO
MTL: -		

BALDOR - RELIANCE®

HOR TEAO 284-6T CP COOLING TOWER W/SLD BRGS,VER LIF, LIP SL

SH 1 of 1

