

# IAPMO RESEARCH AND TESTING, INC.

5001 E. Philadelphia Street, Ontario, CA 91761-2816 • (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



## CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body which tests and inspects samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at [pld.iapmo.org](http://pld.iapmo.org)

*Issued to:*

**EPIC LIFE INC. DBA EPIC WATER FILTERS**

1630 30<sup>th</sup> STREET, BOULDER, CO 80301

*Product:*

**Water Treatment Product - Health Effects**

*Products are in compliance with the following code(s):*

**Uniform Plumbing Code (UPC®)**

*Products are in compliance with the following standard(s):*

**NSF/ANSI 53-2018**

File Number: WP-10570

Effective Date: August 2019

Void After Date: August 2024

  
Chairman, Product Certification Committee



  
CEO, The IAPMO Group

This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.

# IAPMO RESEARCH AND TESTING, INC.

## CERTIFICATE OF LISTING



Issued To: EPIC LIFE INC. DBA EPIC WATER FILTERS

Effective Date: August 2019

File Number: WP-10570

Void After: August 2024

Product: Water Treatment Product - Health Effects

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at [pld.iapmo.org](http://pld.iapmo.org)

### Identification:

The product or packaging shall be marked with the model number, name and address of manufacturer, functional description of system, max operating temperature, max working pressure, a statement noting that the system conforms to NSF/ANSI 53 for the specific performance claims verified and substantiated by test data, as well as the IAPMO UPC® Shield certification mark. In the case of private labelling, the product packaging shall be marked with the model number and the name, trademark, or other mark of the customer for whom the fitting was manufactured.

### Characteristics:

The point-of-use and point-of-entry systems addressed by this Standard are designed to be used for the reduction of specific substances that may be present in drinking water (public or private) which are considered health hazards. Certification demonstrates that all materials safety and structural integrity (as applicable) requirements have been met. To be used in accordance with the manufacturer's instructions An elective claim per NSF/ANSI 53 (or P473) is PFOA and PFOS. Levels of PFOA and PFOS vary across different regions. When a product has been certified for PFOA/PFOS, the current acceptance level under NSF/ANSI 53 (or P473) is 70 ppt for both PFOA and PFOS. The combination of PFOS and PFOA cannot exceed the total. Below are specific levels established by specific AHJs: US EPA, Alabama, Alaska, California, Colorado, Connecticut, Florida, Idaho Maine, Massachusetts, Michigan and West Virginia: 70 ppt for both PFOA and PFOS. The combination of PFOS and PFOA cannot exceed the total. Minnesota: 35 ppt for PFOA and 15 ppt for PFOS Nevada: 667 ppt for both PFOA and PFOS. New Hampshire: 12 ppt for PFOA and 15 ppt for PFOS. New Jersey: 14 ppt for PFOA and 13 ppt for PFOS. Vermont: 20 ppt for both PFOA and PFOS. The combination of PFOS and PFOA cannot exceed the total. Canada: 200 ppt for PFOA and 600 ppt for PFOS.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

# IAPMO RESEARCH AND TESTING, INC.

## CERTIFICATE OF LISTING



Issued To: EPIC LIFE INC. DBA EPIC WATER FILTERS

Effective Date: August 2019

File Number: WP-10570

Void After Date: August 2024

Product: Water Treatment Product - Health Effects

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at [pld.iapmo.org](http://pld.iapmo.org)

<u>Model Number</u>	<u>Flow Rate (GPM)</u>	<u>Capacity (Gallons)</u>	<u>Replacement Component</u>	<u>Reduction Claims</u>
EWFESS4-DC	1.25	651	EWFESS4	Asbestos, Cyst, Lead, Mercury, MTBE, Turbidity, VOC