CERTIFICATE OF CONFORMITY

Certificate No.: LC12952-1 Date Issued: August 1, 2023

Project No.: 12952B **Certification System: Type 3** (ISO / IEC 17067)

Client No.: LC1225771

Applicant: Elmec Inc.

1141 2e Ave, Grand-Mère

QC G9T 2X9 Canada



Issued by:

Certification Manager

Products:

Electric Vehicle Charger (portable or permanently connected type)

Model Nos.: EVC30-xxxx-yyyy, EVC40-xxxx-yyyy, EVC48-xxxx-yyyy

> Example: EVC30-25 30-0 0 0 0 0 Current capacity: 30 or 48 Output cable length (ft): 15 or 25 Output current (A): 16, 20, 24 or 30 Option#1* Option#2* Option#3* Option#4* Option#5* Option #1: N/A (reserved for future, default as "0") Option #2: N/A (reserved for future, default as "0") Option #3: Communication module 0 = None 1 = Smart-Home Module

2 = Smart-Pro Module

Option #4: Power Input Type: 0 = Plug

1 = Wiring leads

Option #5: Input Plug Type: 0 = NEMA 6-50P (available only for EVC30)

> 1 = NEMA 14-50P (available only for EVC30) 2 = None (only available if Option #4 is 1)

EVC30: 208-240Vac, 30 A, 7200W, 50/60 Hz, -40°C to 40°C Ratings:

> EVC40: 208-240Vac, 40 A, 9600W, 50/60 Hz, -40°C to 40°C EVC48: 208-240Vac, 48 A, 11520W, 50/60 Hz, -40°C to 40°C

The 'C' and 'US' indicators adjacent to the LabTest Certification Mark shall signify that the product has been evaluated by an accredited laboratory to the applicable Canadian and US Standards. The subject area shall be displayed with the LabTest Certification Mark to identify the Standard Number, and Revision Level.

Applicable requirements:

- CSA-C22.2 No. 281.1-12 / UL2231-1 (Edition 2) (2012)
- > CSA-C22.2 No. 281.2-12 / UL2231-2 (Edition 2) (2012)
- CSA-C22.2 No. 280-16 / UL 2594 (Edition 2) 2016

Conditions of acceptability:

None

General Note:

Refer to LC Listing Report No. 10.00.12952-1_Rev.B

Page 2 of 2

Certificate No.: LC12952-1