

System Parameters - Read Only

Modbus Address	Name	Format	Scale	Default	Description/Format
40001	Serial Number Low	UINT16	x1		This is consistent with the original document. This is effectively little Endian UINT32
40002	Serial Number High	UINT16	x1		This is consistent with the original document. This is effectively little Endian UINT32
40003	Firmware Version	UINT16	x1		
40004	OEM Identification	UINT16	x1		"PT" in ASCII
40005	Meter Model	UINT16	x1	45	{109, 431, 636, 45, 888}
40014	Number of Curent Element on Unit	UINT16	x1	45	This is a maximum of 45 on the iMeter45
40015	Number of Meters on Unit	UINT16	x1		For the MP636, this will be 6, 8, or 16, for the 5x3 phase (+1x1phase), 8x2phase, or 16x1 phase
40016	Modbus Uptime	UINT32	x1		This is the number of seconds since the last power cycle on the modbus module.
40019	Meter Config	UINT16	x1		The configuration of the meter

Configuration Parameters

Modbus Address	Name	Format	Access	Default	Description/Format
41000	PTRatio	UINT16	R/W	1	The PT ratio that will be used in calculations. It does not affect meter operation.
41001					Changes to the Modbus address take effect immediately. The next command must use the changed address, otherwise the module will not respond
41002	Address	UINT16	R/W	1	address, otherwise the module will not respond
41003	Baud Rate	Enumerated	R/W	3 = 9600 bps 3 = 9600 bps 4 = 19200 bps 5 = 38400 bps 6 = 57600 bps 7 = 115200 bps	
41004	CT Ratio - Meter 1	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41005	CT Ratio - Meter 2	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41006	CT Ratio - Meter 3	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41007	CT Ratio - Meter 4	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41008	CT Ratio - Meter 5	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41009	CT Ratio - Meter 6	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41010	CT Ratio - Meter 7	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41011	CT Ratio - Meter 8	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41012	CT Ratio - Meter 9	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41013	CT Ratio - Meter 10	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41014	CT Ratio - Meter 11	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41015	CT Ratio - Meter 12	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41016	CT Ratio - Meter 13	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41017	CT Ratio - Meter 14	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41018	CT Ratio - Meter 15	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41019	CT Ratio - Meter 16	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41020	Demand Intervals	Enumerated	R/W	2	0 = 1 minute 1 = 5 minutes 2 = 15 minutes 3 = 30 minutes 4 = 60 minutes 5 = Disabled
41050	CT Ratio - Meter 1	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41051	CT Ratio - Meter 2	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41052	CT Ratio - Meter 3	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41053	CT Ratio - Meter 4	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41054	CT Ratio - Meter 5	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41055	CT Ratio - Meter 6	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41056	CT Ratio - Meter 7	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41057	CT Ratio - Meter 8	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41058	CT Ratio - Meter 9	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41059	CT Ratio - Meter 10	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41060	CT Ratio - Meter 11	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41061	CT Ratio - Meter 12	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41062	CT Ratio - Meter 13	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41063	CT Ratio - Meter 14	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41064	CT Ratio - Meter 15	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41065	CT Ratio - Meter 16	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41066	CT Ratio - Meter 17	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41067	CT Ratio - Meter 18	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41068	CT Ratio - Meter 19	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41069	CT Ratio - Meter 20	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41070	CT Ratio - Meter 21	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41071	CT Ratio - Meter 22	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41072	CT Ratio - Meter 23	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41073	CT Ratio - Meter 24	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41074	CT Ratio - Meter 25	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41075	CT Ratio - Meter 26	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41076	CT Ratio - Meter 27	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41077	CT Ratio - Meter 28	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41078	CT Ratio - Meter 29	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41079	CT Ratio - Meter 30	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41080	CT Ratio - Meter 31	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41081	CT Ratio - Meter 32	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41082	CT Ratio - Meter 33	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41083	CT Ratio - Meter 34	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41084	CT Ratio - Meter 35	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41085	CT Ratio - Meter 36	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41086	CT Ratio - Meter 37	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41087	CT Ratio - Meter 38	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41088	CT Ratio - Meter 39	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41089	CT Ratio - Meter 40	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41090	CT Ratio - Meter 41	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41091	CT Ratio - Meter 42	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
41092	CT Ratio - Meter 43	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.

Meter 1 Information

Modbus Address	Name	Format	Unit	Default	Description/Format
41100	Active Phases	Bit map	x1		0x0001 - Meter uses phase A 0x0002 - Meter uses phase B 0x0004 - Meter uses phase C
41101	Voltage A	UINT32	mV		The value will be the reported voltage * PT Ratio
41103	Voltage B	UINT32	mV		The value will be the reported voltage * PT Ratio
41105	Voltage C	UINT32	mV		The value will be the reported voltage * PT Ratio
41107	Current A	UINT32	mA		The value will be the reported current * CT Ratio/5
41109	Current B	UINT32	mA		The value will be the reported current * CT Ratio/5
41111	Current C	UINT32	mA		The value will be the reported current * CT Ratio/5
41113	Watts A	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
41115	Watts B	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
41117	Watts C	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
41119	Volt-Amp A	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5
41121	Volt-Amp B	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5
41123	Volt-Amp C	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5

41125					
41127					
41129					
41131	Power Factor A	INT32	0.001 Units		
41133	Power Factor B	INT32	0.001 Units		
41135	Power Factor C	INT32	0.001 Units		
41137					
41139					
41141					
41143	kWh	UINT32	Wh		
41145	kVAh	UINT32	VAh		
41147					
41149	Frequency	UINT32	0.01 Hz		
41151					
41153					
41155	Voltage Average	UINT32	mV		Average of the voltage from each phase
41157	Meter Total Current	UINT32	mA		Average of the current from each phase
41159					
41161	Meter Total Watts	UINT32	0.01 W		
41163	Meter Total VA	UINT32	0.01 VA		

Meter 2 Information

Modbus Address	Name	Format	Unit	Default	Description/Format
41200	Active Phases	Bit map	x1		0x0001 - Meter uses phase A 0x0002 - Meter uses phase B 0x0004 - Meter uses phase C
41201	Voltage A	UINT32	mV		The value will be the reported voltage * PT Ratio
41203	Voltage B	UINT32	mV		The value will be the reported voltage * PT Ratio
41205	Voltage C	UINT32	mV		The value will be the reported voltage * PT Ratio
41207	Current A	UINT32	mA		The value will be the reported current * CT Ratio/5
41209	Current B	UINT32	mA		The value will be the reported current * CT Ratio/5
41211	Current C	UINT32	mA		The value will be the reported current * CT Ratio/5
41213	Watts A	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
41215	Watts B	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
41217	Watts C	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
41219	Volt-Amp A	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5
41221	Volt-Amp B	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5
41223	Volt-Amp C	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5
41225					
41227					
41229					
41231	Power Factor A	INT32	0.001 Units		
41233	Power Factor B	INT32	0.001 Units		
41235	Power Factor C	INT32	0.001 Units		
41237					
41239					
41241					
41243	kWh	UINT32	WH		
41245	kVAh	UINT32	VA		
41247					
41249	Frequency	UINT32	0.01 Hz		
41251					
41253					
41255	Voltage Average	UINT32	mV		Average of the voltage from each phase
41257	Meter Total Current	UINT32	mA		Average of the current from each phase
41259					
41261	Meter Total Watts	UINT32	0.01 W		
41263	Meter Total VA	UINT32	0.01 VA		
41265					

Meter x Information

where x = 1 ... 43

Meter Id	Start Address
1	41100
2	41200
3	41300
4	41400
5	41500
6	41600
7	41700
8	41800
9	41900
10	42000
11	42100
12	42200
13	42300
14	42400
15	42500
16	42600
17	42700
18	42800
19	42900
20	43000
21	43100
22	43200
23	43300
24	43400
25	43500
26	43600
27	43700
28	43800
29	43900
30	44000
31	44100

32	44200
33	44300
34	44400
35	44500
36	44600
37	44700
38	44800
39	44900
40	45000
41	45100
42	45200
43	45300

The start address for the meter is listed in the table above

Modbus Address	Name	Format	Unit	Default	Description/Format
41x00	Active Phases	Bit map	x1		0x0001 - Meter uses phase A 0x0002 - Meter uses phase B 0x0004 - Meter uses phase C
41x01	Voltage A	UINT32	mV		The value will be the reported voltage * PT Ratio
41x03	Voltage B	UINT32	mV		The value will be the reported voltage * PT Ratio
41x05	Voltage C	UINT32	mV		The value will be the reported voltage * PT Ratio
41x07	Current A	UINT32	mA		The value will be the reported current * CT Ratio/5
41x09	Current B	UINT32	mA		The value will be the reported current * CT Ratio/5
41x11	Current C	UINT32	mA		The value will be the reported current * CT Ratio/5
41x13	Watts A	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
41x15	Watts B	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
41x17	Watts C	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
41x19	Volt-Amp A	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5
41x21	Volt-Amp B	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5
41x23	Volt-Amp C	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5
41x25					
41x27					
41x29					
41x31	Power Factor A	INT32	0.001 Units		
41x33	Power Factor B	INT32	0.001 Units		
41x35	Power Factor C	INT32	0.001 Units		
41x37					
41x39					
41x41					
41x43	kWh	UINT32	Wh		
41x45	kVAh	UINT32	VAh		
41x47					
41x49	Frequency	UINT32	0.01 Hz		
41x51		INT32	W		
41x53		INT32	W		
41x55	Voltage Average	UINT32	mV		Average of the voltage from each phase
41x57	Meter Total Current	UINT32	mA		Average of the current from each phase
41x59					
41x61	Meter Total Watts	UINT32	0.01 W		
41x63	Meter Total VA	UINT32	0.01 VA		
41x65		INT32	W		Sets the kW threshold that sets the demand flag.

Mini Register Map

Modbus Address	Name	Format	Unit	Default	Description/Format
Meter 1	48000 kWh	UINT32	Wh		
	48002				
	48004				
	48006 Voltage Average	UINT32	mV		Average of the voltage from each phase
	48008 Meter Total Current	UINT32	mA		Average of the current from each phase
Meter 2	48010 kWh	UINT32	Wh		
	48012				
	48014				
	48016 Voltage Average	UINT32	mV		Average of the voltage from each phase
	48018 Meter Total Current	UINT32	mA		Average of the current from each phase
Meter 3	48020 kWh	UINT32	Wh		
	48022				
	48024				
	48026 Voltage Average	UINT32	mV		Average of the voltage from each phase
	48028 Meter Total Current	UINT32	mA		Average of the current from each phase
Meter 4	48030 kWh	UINT32	Wh		
	48032				
	48034				
	48036 Voltage Average	UINT32	mV		Average of the voltage from each phase
	48038 Meter Total Current	UINT32	mA		Average of the current from each phase
Meter 5	48040 kWh	UINT32	Wh		
	48042				
	48044				
	48046 Voltage Average	UINT32	mV		Average of the voltage from each phase
	48048 Meter Total Current	UINT32	mA		Average of the current from each phase
Meter 6	48050 kWh	UINT32	Wh		
	48052				
	48054				
	48056 Voltage Average	UINT32	mV		Average of the voltage from each phase
	48058 Meter Total Current	UINT32	mA		Average of the current from each phase
Meter 7	48060 kWh	UINT32	Wh		
	48062				
	48064				
	48066 Voltage Average	UINT32	mV		Average of the voltage from each phase
	48068 Meter Total Current	UINT32	mA		Average of the current from each phase
Meter 8	48070 kWh	UINT32	Wh		
	48072				
	48074				
	48076 Voltage Average	UINT32	mV		Average of the voltage from each phase
	48078 Meter Total Current	UINT32	mA		Average of the current from each phase
Meter 9	48080 kWh	UINT32	Wh		
	48082				
	48084				

Meter 10	48086	Voltage Average	UINT32	mV	Average of the voltage from each phase
	48088	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 11	48090	kWh	UINT32	Wh	
	48092				
Meter 12	48094				
	48096	Voltage Average	UINT32	mV	Average of the voltage from each phase
Meter 13	48098	Meter Total Current	UINT32	mA	Average of the current from each phase
	48100	kWh	UINT32	Wh	
Meter 14	48102				
	48104				
Meter 15	48106	Voltage Average	UINT32	mV	Average of the voltage from each phase
	48108	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 16	48110	kWh	UINT32	Wh	
	48112				
Meter 17	48114				
	48116	Voltage Average	UINT32	mV	Average of the voltage from each phase
Meter 18	48118	Meter Total Current	UINT32	mA	Average of the current from each phase
	48120	kWh	UINT32	Wh	
Meter 19	48122				
	48124				
Meter 20	48126	Voltage Average	UINT32	mV	Average of the voltage from each phase
	48128	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 21	48130	kWh	UINT32	Wh	
	48132				
Meter 22	48134				
	48136	Voltage Average	UINT32	mV	Average of the voltage from each phase
Meter 23	48138	Meter Total Current	UINT32	mA	Average of the current from each phase
	48140	kWh	UINT32	Wh	
Meter 24	48142				
	48144				
Meter 25	48146	Voltage Average	UINT32	mV	Average of the voltage from each phase
	48148	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 26	48150	kWh	UINT32	Wh	
	48152				
Meter 27	48154				
	48156	Voltage Average	UINT32	mV	Average of the voltage from each phase
Meter 28	48158	Meter Total Current	UINT32	mA	Average of the current from each phase
	48160	kWh	UINT32	Wh	
Meter 29	48162				
	48164				
Meter 30	48166	Voltage Average	UINT32	mV	Average of the voltage from each phase
	48168	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 31	48170	kWh	UINT32	Wh	
	48172				
Meter 32	48174				
	48176	Voltage Average	UINT32	mV	Average of the voltage from each phase
Meter 33	48178	Meter Total Current	UINT32	mA	Average of the current from each phase
	48180	kWh	UINT32	Wh	
Meter 34	48182				
	48184				
Meter 35	48186	Voltage Average	UINT32	mV	Average of the voltage from each phase
	48188	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 36	48190	kWh	UINT32	Wh	
	48192				
Meter 37	48194				
	48196	Voltage Average	UINT32	mV	Average of the voltage from each phase
Meter 38	48198	Meter Total Current	UINT32	mA	Average of the current from each phase
	48200	kWh	UINT32	Wh	
Meter 39	48202				
	48204				
Meter 40	48206	Voltage Average	UINT32	mV	Average of the voltage from each phase
	48208	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 41	48210	kWh	UINT32	Wh	
	48212				
Meter 42	48214				
	48216	Voltage Average	UINT32	mV	Average of the voltage from each phase
Meter 43	48218	Meter Total Current	UINT32	mA	Average of the current from each phase
	48220	kWh	UINT32	Wh	
Meter 44	48222				
	48224				
Meter 45	48226	Voltage Average	UINT32	mV	Average of the voltage from each phase
	48228	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 46	48230	kWh	UINT32	Wh	
	48232				
Meter 47	48234				
	48236	Voltage Average	UINT32	mV	Average of the voltage from each phase
Meter 48	48238	Meter Total Current	UINT32	mA	Average of the current from each phase
	48240	kWh	UINT32	Wh	
Meter 49	48242				
	48244				
Meter 50	48246	Voltage Average	UINT32	mV	Average of the voltage from each phase
	48248	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 51	48250	kWh	UINT32	Wh	
	48252				
Meter 52	48254				
	48256	Voltage Average	UINT32	mV	Average of the voltage from each phase
Meter 53	48258	Meter Total Current	UINT32	mA	Average of the current from each phase
	48260	kWh	UINT32	Wh	
Meter 54	48262				
	48264				
Meter 55	48266	Voltage Average	UINT32	mV	Average of the voltage from each phase
	48268	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 56	48270	kWh	UINT32	Wh	
	48272				
Meter 57	48274				
	48276	Voltage Average	UINT32	mV	Average of the voltage from each phase
Meter 58	48278	Meter Total Current	UINT32	mA	Average of the current from each phase
	48280	kWh	UINT32	Wh	
Meter 59	48282				
	48284				
Meter 60	48286	Voltage Average	UINT32	mV	Average of the voltage from each phase
	48288	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 61	48290	kWh	UINT32	Wh	
	48292				
Meter 62	48294				
	48296	Voltage Average	UINT32	mV	Average of the voltage from each phase

Meter 31	48298	Meter Total Current	UINT32	mA	Average of the current from each phase
	48300	kWh	UINT32	Wh	
	48302				
	48304				
Meter 32	48306	Voltage Average	UINT32	mV	Average of the voltage from each phase Average of the current from each phase
	48308	Meter Total Current	UINT32	mA	
	48310	kWh	UINT32	Wh	
	48312				
Meter 33	48314				Average of the voltage from each phase Average of the current from each phase
	48316	Voltage Average	UINT32	mV	
	48318	Meter Total Current	UINT32	mA	
	48320	kWh	UINT32	Wh	
Meter 34	48322				Average of the voltage from each phase Average of the current from each phase
	48324				
	48326	Voltage Average	UINT32	mV	
	48328	Meter Total Current	UINT32	mA	
Meter 35	48330	kWh	UINT32	Wh	Average of the voltage from each phase Average of the current from each phase
	48332				
	48334				
	48336	Voltage Average	UINT32	mV	
Meter 36	48338	Meter Total Current	UINT32	mA	Average of the voltage from each phase Average of the current from each phase
	48340	kWh	UINT32	Wh	
	48342				
	48344				
Meter 37	48346	Voltage Average	UINT32	mV	Average of the voltage from each phase Average of the current from each phase
	48348	Meter Total Current	UINT32	mA	
	48350	kWh	UINT32	Wh	
	48352				
Meter 38	48354				Average of the voltage from each phase Average of the current from each phase
	48356	Voltage Average	UINT32	mV	
	48358	Meter Total Current	UINT32	mA	
	48360	kWh	UINT32	Wh	
Meter 39	48362				Average of the voltage from each phase Average of the current from each phase
	48364				
	48366	Voltage Average	UINT32	mV	
	48368	Meter Total Current	UINT32	mA	
Meter 40	48370	kWh	UINT32	Wh	Average of the voltage from each phase Average of the current from each phase
	48372				
	48374				
	48376	Voltage Average	UINT32	mV	
Meter 41	48378	Meter Total Current	UINT32	mA	Average of the voltage from each phase Average of the current from each phase
	48380	kWh	UINT32	Wh	
	48382				
	48384				
Meter 42	48386	Voltage Average	UINT32	mV	Average of the voltage from each phase Average of the current from each phase
	48388	Meter Total Current	UINT32	mA	
	48390	kWh	UINT32	Wh	
	48392				
Meter 43	48394				Average of the voltage from each phase Average of the current from each phase
	48396	Voltage Average	UINT32	mV	
	48398	Meter Total Current	UINT32	mA	
	48400	kWh	UINT32	Wh	
Meter 44	48402				Average of the voltage from each phase Average of the current from each phase
	48404				
	48406	Voltage Average	UINT32	mV	
	48408	Meter Total Current	UINT32	mA	
Meter 45	48410	kWh	UINT32	Wh	Average of the voltage from each phase Average of the current from each phase
	48412				
	48414				
	48416	Voltage Average	UINT32	mV	
Meter 46	48418	Meter Total Current	UINT32	mA	Average of the voltage from each phase Average of the current from each phase
	48420	kWh	UINT32	Wh	
	48422				
	48424				
Meter 47	48426	Voltage Average	UINT32	mV	Average of the voltage from each phase Average of the current from each phase
	48428	Meter Total Current	UINT32	mA	
	48430				
	48432				

Element 0	47000	Meter	Enum		The meter that this element is associated with
	47001	THD	UINT16	0.01%	Total harmonic distortion for this waveform
	47002	2nd Harmonic	UINT16	0.01%	2nd harmonic component for this waveform
	47003	3rd Harmonic	UINT16	0.01%	3rd harmonic component for this waveform
	47004	4th Harmonic	UINT16	0.01%	4th harmonic component for this waveform
	47005	5th Harmonic	UINT16	0.01%	5th harmonic component for this waveform
	47006	6th Harmonic	UINT16	0.01%	6th harmonic component for this waveform
	47007	7th Harmonic	UINT16	0.01%	7th harmonic component for this waveform
	47008	8th Harmonic	UINT16	0.01%	8th harmonic component for this waveform
	47009	9th Harmonic	UINT16	0.01%	9th harmonic component for this waveform
	47010	10th Harmonic	UINT16	0.01%	10th harmonic component for this waveform
	47011	11th Harmonic	UINT16	0.01%	11th harmonic component for this waveform
Element 1	47012	12th Harmonic	UINT16	0.01%	12th harmonic component for this waveform
	47020	Meter	Enum		The meter that this element is associated with
	47021	THD	UINT16	0.01%	Total harmonic distortion for this waveform
	47022	2nd Harmonic	UINT16	0.01%	2nd harmonic component for this waveform
	47023	3rd Harmonic	UINT16	0.01%	3rd harmonic component for this waveform
	47024	4th Harmonic	UINT16	0.01%	4th harmonic component for this waveform
	47025	5th Harmonic	UINT16	0.01%	5th harmonic component for this waveform
	47026	6th Harmonic	UINT16	0.01%	6th harmonic component for this waveform
	47027	7th Harmonic	UINT16	0.01%	7th harmonic component for this waveform
	47028	8th Harmonic	UINT16	0.01%	8th harmonic component for this waveform
	47029	9th Harmonic	UINT16	0.01%	9th harmonic component for this waveform
	47030	10th Harmonic	UINT16	0.01%	10th harmonic component for this waveform
Element 2	47031	11th Harmonic	UINT16	0.01%	11th harmonic component for this waveform
	47032	12th Harmonic	UINT16	0.01%	12th harmonic component for this waveform
	47040	Meter	Enum		The meter that this element is associated with
	47041	THD	UINT16	0.01%	Total harmonic distortion for this waveform
	47042	2nd Harmonic	UINT16	0.01%	2nd harmonic component for this waveform
	47043	3rd Harmonic	UINT16	0.01%	3rd harmonic component for this waveform
	47044	4th Harmonic	UINT16	0.01%	4th harmonic component for this waveform
	47045	5th Harmonic	UINT16	0.01%	5th harmonic component for this waveform
47046	6th Harmonic	UINT16	0.01%	6th harmonic component for this waveform	
47047	7th Harmonic	UINT16	0.01%	7th harmonic component for this waveform	
47048	8th Harmonic	UINT16	0.01%	8th harmonic component for this waveform	

Element 44	47871	11th Harmonic	UINT16	0.01%	11th harmonic component for this waveform
	47872	12th Harmonic	UINT16	0.01%	12th harmonic component for this waveform
	47880	Meter	Enum		The meter that this element is associated with
	47881	THD	UINT16	0.01%	Total harmonic distortion for this waveform
	47882	2nd Harmonic	UINT16	0.01%	2nd harmonic component for this waveform
	47883	3rd Harmonic	UINT16	0.01%	3rd harmonic component for this waveform
	47884	4th Harmonic	UINT16	0.01%	4th harmonic component for this waveform
	47885	5th Harmonic	UINT16	0.01%	5th harmonic component for this waveform
	47886	6th Harmonic	UINT16	0.01%	6th harmonic component for this waveform
	47887	7th Harmonic	UINT16	0.01%	7th harmonic component for this waveform
	47888	8th Harmonic	UINT16	0.01%	8th harmonic component for this waveform
	47889	9th Harmonic	UINT16	0.01%	9th harmonic component for this waveform
Voltage A	47890	10th Harmonic	UINT16	0.01%	10th harmonic component for this waveform
	47891	11th Harmonic	UINT16	0.01%	11th harmonic component for this waveform
	47892	12th Harmonic	UINT16	0.01%	12th harmonic component for this waveform
	47900	Meter	Bit Field		The corresponding meter bit is set for each meter that is associated with this voltage
	47901	THD	UINT16	0.01%	Total harmonic distortion for this waveform
	47902	2nd Harmonic	UINT16	0.01%	2nd harmonic component for this waveform
	47903	3rd Harmonic	UINT16	0.01%	3rd harmonic component for this waveform
	47904	4th Harmonic	UINT16	0.01%	4th harmonic component for this waveform
	47905	5th Harmonic	UINT16	0.01%	5th harmonic component for this waveform
	47906	6th Harmonic	UINT16	0.01%	6th harmonic component for this waveform
	47907	7th Harmonic	UINT16	0.01%	7th harmonic component for this waveform
	47908	8th Harmonic	UINT16	0.01%	8th harmonic component for this waveform
Voltage B	47909	9th Harmonic	UINT16	0.01%	9th harmonic component for this waveform
	47910	10th Harmonic	UINT16	0.01%	10th harmonic component for this waveform
	47911	11th Harmonic	UINT16	0.01%	11th harmonic component for this waveform
	47912	12th Harmonic	UINT16	0.01%	12th harmonic component for this waveform
	47920	Meter	Bit Field		The corresponding meter bit is set for each meter that is associated with this voltage
	47921	THD	UINT16	0.01%	Total harmonic distortion for this waveform
	47922	2nd Harmonic	UINT16	0.01%	2nd harmonic component for this waveform
	47923	3rd Harmonic	UINT16	0.01%	3rd harmonic component for this waveform
	47924	4th Harmonic	UINT16	0.01%	4th harmonic component for this waveform
	47925	5th Harmonic	UINT16	0.01%	5th harmonic component for this waveform
	47926	6th Harmonic	UINT16	0.01%	6th harmonic component for this waveform
	47927	7th Harmonic	UINT16	0.01%	7th harmonic component for this waveform
Voltage C	47928	8th Harmonic	UINT16	0.01%	8th harmonic component for this waveform
	47929	9th Harmonic	UINT16	0.01%	9th harmonic component for this waveform
	47930	10th Harmonic	UINT16	0.01%	10th harmonic component for this waveform
	47931	11th Harmonic	UINT16	0.01%	11th harmonic component for this waveform
	47932	12th Harmonic	UINT16	0.01%	12th harmonic component for this waveform
	47940	Meter	Bit Field		The corresponding meter bit is set for each meter that is associated with this voltage
	47941	THD	UINT16	0.01%	Total harmonic distortion for this waveform
	47942	2nd Harmonic	UINT16	0.01%	2nd harmonic component for this waveform
	47943	3rd Harmonic	UINT16	0.01%	3rd harmonic component for this waveform
	47944	4th Harmonic	UINT16	0.01%	4th harmonic component for this waveform
	47945	5th Harmonic	UINT16	0.01%	5th harmonic component for this waveform
	47946	6th Harmonic	UINT16	0.01%	6th harmonic component for this waveform
47947	7th Harmonic	UINT16	0.01%	7th harmonic component for this waveform	
47948	8th Harmonic	UINT16	0.01%	8th harmonic component for this waveform	
47949	9th Harmonic	UINT16	0.01%	9th harmonic component for this waveform	
47950	10th Harmonic	UINT16	0.01%	10th harmonic component for this waveform	
47951	11th Harmonic	UINT16	0.01%	11th harmonic component for this waveform	
47952	12th Harmonic	UINT16	0.01%	12th harmonic component for this waveform	

System Parameters - Read Only

Modbus Address	Name	Format	Scale	Default	Description/Format
40001	Serial Number Low	UINT16	x1		This is consistent with the original document. This is effectively little Endian UINT32
40002	Serial Number High	UINT16	x1		This is consistent with the original document. This is effectively little Endian UINT32
40003	Firmware Version	UINT16	x1		
40004	OEM Identification	UINT16	x1		"PT" in ASCII
40005	Meter Model	UINT16	x1	636 {109, 431, 636, 45, 888}	
40014	Number of Curent Element on Unit	UINT16	x1	16	This is a maximum of 16 on the MP636
40015	Number of Meters on Unit	UINT16	x1		For the MP636, this will be 6, 8, or 16, for the 5x3 phase (+1x1phase), 8x2phase, or 16x1 phase
40016	Modbus Uptime	UINT32	x1		This is the number of seconds since the last power cycle on the modbus module.
40019	Meter Config	UINT16	x1		The configuration of the meter

Configuration Parameters

Modbus Address	Name	Format	Access	Default	Description/Format
48000	PTRatio	UINT16	R/W	1	The PT ratio that will be used in calculations. It does not affect meter operation.
48001	Address				Changes to the Modbus address take effect immediately. The next command must use the changed address, otherwise the module will not respond
48002	Baud Rate	Enumated	R/W	3 = 9600 bps 3 = 9600 bps 4 = 19200 bps 5 = 38400 bps 6 = 57600 bps 7 = 115200 bps	
48004	CT Ratio - Meter 1	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48005	CT Ratio - Meter 2	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48006	CT Ratio - Meter 3	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48007	CT Ratio - Meter 4	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48008	CT Ratio - Meter 5	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48009	CT Ratio - Meter 6	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48010	CT Ratio - Meter 7	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48011	CT Ratio - Meter 8	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48012	CT Ratio - Meter 9	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48013	CT Ratio - Meter 10	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48014	CT Ratio - Meter 11	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48015	CT Ratio - Meter 12	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48016	CT Ratio - Meter 13	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48017	CT Ratio - Meter 14	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48018	CT Ratio - Meter 15	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48019	CT Ratio - Meter 16	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48020	Demand Intervals	Enumerated	R/W	2	0 = 1 minute 1 = 5 minutes 2 = 15 minutes 3 = 30 minutes 4 = 60 minutes 5 = Disabled
48050	CT Ratio - Meter 1	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48051	CT Ratio - Meter 2	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48052	CT Ratio - Meter 3	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48053	CT Ratio - Meter 4	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48054	CT Ratio - Meter 5	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48055	CT Ratio - Meter 6	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48056	CT Ratio - Meter 7	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48057	CT Ratio - Meter 8	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48058	CT Ratio - Meter 9	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48059	CT Ratio - Meter 10	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48060	CT Ratio - Meter 11	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48061	CT Ratio - Meter 12	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48062	CT Ratio - Meter 13	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48063	CT Ratio - Meter 14	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48064	CT Ratio - Meter 15	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48065	CT Ratio - Meter 16	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48066	CT Ratio - Meter 17	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48067	CT Ratio - Meter 18	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48068	CT Ratio - Meter 19	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48069	CT Ratio - Meter 20	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48070	CT Ratio - Meter 21	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48071	CT Ratio - Meter 22	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48072	CT Ratio - Meter 23	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48073	CT Ratio - Meter 24	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48074	CT Ratio - Meter 25	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48075	CT Ratio - Meter 26	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48076	CT Ratio - Meter 27	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48077	CT Ratio - Meter 28	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48078	CT Ratio - Meter 29	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48079	CT Ratio - Meter 30	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48080	CT Ratio - Meter 31	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48081	CT Ratio - Meter 32	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48082	CT Ratio - Meter 33	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48083	CT Ratio - Meter 34	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48084	CT Ratio - Meter 35	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48085	CT Ratio - Meter 36	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48086	CT Ratio - Meter 37	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48087	CT Ratio - Meter 38	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48088	CT Ratio - Meter 39	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48089	CT Ratio - Meter 40	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48090	CT Ratio - Meter 41	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48091	CT Ratio - Meter 42	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.
48092	CT Ratio - Meter 43	UINT16	R/W	2000	The CT ratio that will be used in calculations. Minimum value of 1000.

Meter 1 Information

Modbus Address	Name	Format	Unit	Default	Description/Format
48100	Active Phases	Bit map	x1		0x0001 - Meter uses phase A 0x0002 - Meter uses phase B 0x0004 - Meter uses phase C
48101	Voltage A	UINT32	mV		The value will be the reported voltage * PT Ratio
48103	Voltage B	UINT32	mV		The value will be the reported voltage * PT Ratio
48105	Voltage C	UINT32	mV		The value will be the reported voltage * PT Ratio
48107	Current A	UINT32	mA		The value will be the reported current * CT Ratio/5
48109	Current B	UINT32	mA		The value will be the reported current * CT Ratio/5
48111	Current C	UINT32	mA		The value will be the reported current * CT Ratio/5
48113	Watts A	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
48115	Watts B	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
48117	Watts C	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
48119	Volt-Amp A	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5
48121	Volt-Amp B	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5
48123	Volt-Amp C	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5

48125				
48127				
48129				
48131	Power Factor A	INT32	0.001 Units	
48133	Power Factor B	INT32	0.001 Units	
48135	Power Factor C	INT32	0.001 Units	
48137				
48139				
48141				
48143	kWh	UINT32	Wh	
48145	kVAh	UINT32	VAh	
48147				
48149	Frequency	UINT32	0.01 Hz	
48151	Meter Demand Average	INT32	W	
48153	Meter Demand Peak	INT32	W	
48155	Voltage Average	UINT32	mV	Average of the voltage from each phase
48157	Meter Total Current	UINT32	mA	Average of the current from each phase
48159				
48161	Meter Total Watts	UINT32	0.01 W	
48163	Meter Total VA	UINT32	0.01 VA	
48165				
48167				
48169				

Meter 2 Information

Modbus Address	Name	Format	Unit	Default	Description/Format
48200	Active Phases	Bit map	x1		0x0001 - Meter uses phase A 0x0002 - Meter uses phase B 0x0004 - Meter uses phase C
48201	Voltage A	UINT32	mV		The value will be the reported voltage * PT Ratio
48203	Voltage B	UINT32	mV		The value will be the reported voltage * PT Ratio
48205	Voltage C	UINT32	mV		The value will be the reported voltage * PT Ratio
48207	Current A	UINT32	mA		The value will be the reported current * CTRatio/5
48209	Current B	UINT32	mA		The value will be the reported current * CTRatio/5
48211	Current C	UINT32	mA		The value will be the reported current * CTRatio/5
48213	Watts A	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
48215	Watts B	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
48217	Watts C	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
48219	Volt-Amp A	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5
48221	Volt-Amp B	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5
48223	Volt-Amp C	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5
48225					
48227					
48229					
48231	Power Factor A	INT32	0.001 Units		
48233	Power Factor B	INT32	0.001 Units		
48235	Power Factor C	INT32	0.001 Units		
48237					
48239					
48241					
48243	kWh	UINT32	WH		
48245	kVAh	UINT32	VA		
48247					
48249	Frequency	UINT32	0.01 Hz		
48251	Watt Demand Average	INT32	W		
48253	Watt Demand Peak	INT32	W		
48255	Voltage Average	UINT32	mV		Average of the voltage from each phase
48257	Meter Total Current	UINT32	mA		Average of the current from each phase
48259					
48261	Meter Total Watts	UINT32	0.01 W		
48263	Meter Total VA	UINT32	0.01 VA		
48265					

Meter x Information

where x = 1 ... 43

Meter Id	Start Address
1	41100
2	48200
3	48300
4	48400
5	48500
6	48600
7	48700
8	48800
9	48900
10	49000
11	49100
12	49200
13	49300
14	49400
15	49500
16	49600
17	49700
18	49800
19	49900
20	50000
21	50100
22	50200
23	50300
24	50400
25	50500
26	50600
27	50700
28	50800

29	50900
30	51000
31	51100
32	51200
33	51300
34	51400
35	51500
36	51600
37	51700
38	51800
39	51900
40	52000
41	52100
42	52200
43	52300

The start address for the meter is listed in the table above

Modbus Address	Name	Format	Unit	Default	Description/Format
48x00	Active Phases	Bit map	x1		0x0001 - Meter uses phase A 0x0002 - Meter uses phase B 0x0004 - Meter uses phase C
48x01	Voltage A	UIN32	mV		The value will be the reported voltage * PT Ratio
48x03	Voltage B	UIN32	mV		The value will be the reported voltage * PT Ratio
48x05	Voltage C	UIN32	mV		The value will be the reported voltage * PT Ratio
48x07	Current A	UIN32	mA		The value will be the reported current * CT Ratio/5
48x09	Current B	UIN32	mA		The value will be the reported current * CT Ratio/5
48x11	Current C	UIN32	mA		The value will be the reported current * CT Ratio/5
48x13	Watts A	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
48x15	Watts B	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
48x17	Watts C	INT32	0.01 W		The value will be the reported power * PT Ratio * CT Ratio / 5
48x19	Volt-Amp A	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5
48x21	Volt-Amp B	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5
48x23	Volt-Amp C	INT32	0.01 VA		The value will be the reported power * PT Ratio * CT Ratio / 5
48x25					
48x27					
48x29					
48x31	Power Factor A	INT32	0.001 Units		
48x33	Power Factor B	INT32	0.001 Units		
48x35	Power Factor C	INT32	0.001 Units		
48x37					
48x39					
48x41					
48x43	kWh	UIN32	Wh		
48x45	kVAh	UIN32	VAh		
48x47					
48x49	Frequency	UIN32	0.01 Hz		
48x51	Watt Demand Average	INT32	W		
48x53	Watt Demand Peak	INT32	W		
48x55	Voltage Average	UIN32	mV		Average of the voltage from each phase
48x57	Meter Total Current	UIN32	mA		Average of the current from each phase
48x59					
48x61	Meter Total Watts	UIN32	0.01 W		
48x63	Meter Total VA	UIN32	0.01 VA		
48x65	kW Demand exceeds set value	INT32	W		Sets the kW threshold that sets the demand flag.

Mini Register Map

Modbus Address	Name	Format	Unit	Default	Description/Format	
Meter 1 48000	53000	kWh	UIN32	Wh		
	53002	Demand Average	UIN32	W		
	53004	Demand Peak	UIN32	W		
	53006	Voltage Average	UIN32	mV		Average of the voltage from each phase
	53008	Meter Total Current	UIN32	mA		Average of the current from each phase
	Meter 2	53010	kWh	UIN32	Wh	
53012		Demand Average	UIN32	W		
53014		Demand Peak	UIN32	W		
53016		Voltage Average	UIN32	mV		Average of the voltage from each phase
53018		Meter Total Current	UIN32	mA		Average of the current from each phase
Meter 3		53020	kWh	UIN32	Wh	
	53022	Demand Average	UIN32	W		
	53024	Demand Peak	UIN32	W		
	53026	Voltage Average	UIN32	mV		Average of the voltage from each phase
	53028	Meter Total Current	UIN32	mA		Average of the current from each phase
	Meter 4	53030	kWh	UIN32	Wh	
53032		Demand Average	UIN32	W		
53034		Demand Peak	UIN32	W		
53036		Voltage Average	UIN32	mV		Average of the voltage from each phase
53038		Meter Total Current	UIN32	mA		Average of the current from each phase
Meter 5		53040	kWh	UIN32	Wh	
	53042	Demand Average	UIN32	W		
	53044	Demand Peak	UIN32	W		
	53046	Voltage Average	UIN32	mV		Average of the voltage from each phase
	53048	Meter Total Current	UIN32	mA		Average of the current from each phase
	Meter 6	53050	kWh	UIN32	Wh	
53052		Demand Average	UIN32	W		
53054		Demand Peak	UIN32	W		
53056		Voltage Average	UIN32	mV		Average of the voltage from each phase
53058		Meter Total Current	UIN32	mA		Average of the current from each phase
Meter 7		53060	kWh	UIN32	Wh	
	53062	Demand Average	UIN32	W		
	53064	Demand Peak	UIN32	W		
	53066	Voltage Average	UIN32	mV		Average of the voltage from each phase
	53068	Meter Total Current	UIN32	mA		Average of the current from each phase
	Meter 8	53070	kWh	UIN32	Wh	
53072		Demand Average	UIN32	W		
53074		Demand Peak	UIN32	W		
53076		Voltage Average	UIN32	mV		Average of the voltage from each phase
53078		Meter Total Current	UIN32	mA		Average of the current from each phase

	53292	Demand Average	UINT32	W	
	53294	Demand Peak	UINT32	W	
	53296	Voltage Average	UINT32	mV	Average of the voltage from each phase
	53298	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 31	53300	kWh	UINT32	Wh	
	53302	Demand Average	UINT32	W	
	53304	Demand Peak	UINT32	W	
	53306	Voltage Average	UINT32	mV	Average of the voltage from each phase
	53308	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 32	53310	kWh	UINT32	Wh	
	53312	Demand Average	UINT32	W	
	53314	Demand Peak	UINT32	W	
	53316	Voltage Average	UINT32	mV	Average of the voltage from each phase
	53318	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 33	53320	kWh	UINT32	Wh	
	53322	Demand Average	UINT32	W	
	53324	Demand Peak	UINT32	W	
	53326	Voltage Average	UINT32	mV	Average of the voltage from each phase
	53328	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 34	53330	kWh	UINT32	Wh	
	53332	Demand Average	UINT32	W	
	53334	Demand Peak	UINT32	W	
	53336	Voltage Average	UINT32	mV	Average of the voltage from each phase
	53338	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 35	53340	kWh	UINT32	Wh	
	53342	Demand Average	UINT32	W	
	53344	Demand Peak	UINT32	W	
	53346	Voltage Average	UINT32	mV	Average of the voltage from each phase
	53348	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 36	53350	kWh	UINT32	Wh	
	53352	Demand Average	UINT32	W	
	53354	Demand Peak	UINT32	W	
	53356	Voltage Average	UINT32	mV	Average of the voltage from each phase
	53358	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 37	53360	kWh	UINT32	Wh	
	53362	Demand Average	UINT32	W	
	53364	Demand Peak	UINT32	W	
	53366	Voltage Average	UINT32	mV	Average of the voltage from each phase
	53368	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 38	53370	kWh	UINT32	Wh	
	53372	Demand Average	UINT32	W	
	53374	Demand Peak	UINT32	W	
	53376	Voltage Average	UINT32	mV	Average of the voltage from each phase
	53378	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 39	53380	kWh	UINT32	Wh	
	53382	Demand Average	UINT32	W	
	53384	Demand Peak	UINT32	W	
	53386	Voltage Average	UINT32	mV	Average of the voltage from each phase
	53388	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 40	53390	kWh	UINT32	Wh	
	53392	Demand Average	UINT32	W	
	53394	Demand Peak	UINT32	W	
	53396	Voltage Average	UINT32	mV	Average of the voltage from each phase
	53398	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 41	53400	kWh	UINT32	Wh	
	53402	Demand Average	UINT32	W	
	53404	Demand Peak	UINT32	W	
	53406	Voltage Average	UINT32	mV	Average of the voltage from each phase
	53408	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 42	53410	kWh	UINT32	Wh	
	53412	Demand Average	UINT32	W	
	53414	Demand Peak	UINT32	W	
	53416	Voltage Average	UINT32	mV	Average of the voltage from each phase
	53418	Meter Total Current	UINT32	mA	Average of the current from each phase
Meter 43	53420	kWh	UINT32	Wh	
	53422	Demand Average	UINT32	W	
	53424	Demand Peak	UINT32	W	
	53426	Voltage Average	UINT32	mV	Average of the voltage from each phase
	53428	Meter Total Current	UINT32	mA	Average of the current from each phase

Element 0	47000	Meter	Enum		The meter that this element is associated with
	47001	THD	UINT16	0.01%	Total harmonic distortion for this waveform
	47002	Fundamental	UINT16	0.01%	Fundamental component for this waveform
	47003	2nd Harmonic	UINT16	0.01%	2nd harmonic component for this waveform
	47004	3rd Harmonic	UINT16	0.01%	3rd harmonic component for this waveform
	47005	4th Harmonic	UINT16	0.01%	4th harmonic component for this waveform
	47006	5th Harmonic	UINT16	0.01%	5th harmonic component for this waveform
	47007	6th Harmonic	UINT16	0.01%	6th harmonic component for this waveform
	47008	7th Harmonic	UINT16	0.01%	7th harmonic component for this waveform
	47009	8th Harmonic	UINT16	0.01%	8th harmonic component for this waveform
	47010	9th Harmonic	UINT16	0.01%	9th harmonic component for this waveform
	47011	10th Harmonic	UINT16	0.01%	10th harmonic component for this waveform
	47012	11th Harmonic	UINT16	0.01%	11th harmonic component for this waveform
	47013	12th Harmonic	UINT16	0.01%	12th harmonic component for this waveform
Element 1	47020	Meter	Enum		The meter that this element is associated with
	47021	THD	UINT16	0.01%	Total harmonic distortion for this waveform
	47022	Fundamental	UINT16	0.01%	Fundamental component for this waveform
	47023	2nd Harmonic	UINT16	0.01%	2nd harmonic component for this waveform
	47024	3rd Harmonic	UINT16	0.01%	3rd harmonic component for this waveform
	47025	4th Harmonic	UINT16	0.01%	4th harmonic component for this waveform
	47026	5th Harmonic	UINT16	0.01%	5th harmonic component for this waveform
	47027	6th Harmonic	UINT16	0.01%	6th harmonic component for this waveform
	47028	7th Harmonic	UINT16	0.01%	7th harmonic component for this waveform
	47029	8th Harmonic	UINT16	0.01%	8th harmonic component for this waveform
	47030	9th Harmonic	UINT16	0.01%	9th harmonic component for this waveform
	47031	10th Harmonic	UINT16	0.01%	10th harmonic component for this waveform
	47032	11th Harmonic	UINT16	0.01%	11th harmonic component for this waveform
	47033	12th Harmonic	UINT16	0.01%	12th harmonic component for this waveform
Element 2	47040	Meter	Enum		The meter that this element is associated with
	47041	THD	UINT16	0.01%	Total harmonic distortion for this waveform
	47042	Fundamental	UINT16	0.01%	Fundamental component for this waveform
	47043	2nd Harmonic	UINT16	0.01%	2nd harmonic component for this waveform

