

AINSI METER FORM	NUMBER OF JAWS	VOLTAGE	AMPERAGE	ADDITIONAL INFORMATION	OPTIONS			ICI PART NUMBER
					PULSE OUTPUT	ICI- MC APPROVAL TO SEAL (FOR REVENUE BILLING PURPOSE IN CANADA)	RADIO	
1 S	4	120/208V L-N	100	1ph 2w	NO	YES	NO	ICI29VM-ST-1S-4J-120V-100A-S
	4	120/208V L-N	100	1ph,2w	NO	CHECK METER (meter is approved but not sealed)	NO	ICI29VM-ST-1S-4J-120V-100A
	4	120/208V L-N	100	1ph, 2w	YES	NO	NO	ICI29VM-ST-1S-4J-120V-100A-PO
	4	120/208V L-N	100	1ph, 2w	NO	NO	RF	ICI29VM-ST-1S-4J-120V-100A-RF
	4	120/208V L-N	100	1ph, 2w	NO	YES	RFS	ICI29VM-ST-1S-4J-120V-100A-RFS
	4	120-347V L-N	100	1ph 2w	NO	NO	NO	ICI29VM-XT-1S-4J-120TO480V-100A
	4	120-347V L-N	200	1ph 2w	NO	NO	NO	ICI29VM-XT-1S-4J-120TO480V-200A
2S	4	120/240V L-L	200	1ph 3w	NO	YES	NO	ICI29VM-ST-2S-4J-240V-200A-S
	4	120/240V L-L	200	1ph 3w	NO	CHECK METER (meter is approved but not sealed)	NO	ICI29VM-ST-2S-4J-240V-200A
	4	120/240V L-L	200	1ph,3w	YES	NO	NO	ICI29VM-ST-2S-4J-240V-200A-PO
	4	120/240V L-L	200	1ph,3w	NO	NO	RF	ICI29VM-ST-2S-4J-240V-200A-RF
	4	120/240V L-L	200	1ph,3w	NO	YES	RFS	ICI29VM-ST-2S-4J-240V-200A-RFS
	4	120-347V L-N Autoranging	200	1ph 2w	NO	NO	NO	ICI29VM-XT-2S-4J-120to480V-200A
	4	120-347V L-N Autoranging	200	1ph 2w	YES	NO	NO	ICI29VM-XT-2S-4J-120/480V200APO
3S	5	120/240V L-L	20	2w or 3w (transformer rated) single phase (requires external* CTs)	NO	NO	NO	ICI29VM-ST-3S-5J-240V-20A
	5	120/240V L-L	20	2w or 3w (transformer rated) single phase (requires external* CTs)	YES	NO	NO	ICI29VM-ST-3S-5J-240V-20A-PO
	5	120-347V L-N Autoranging	20	2w or 3w (transformer rated) single phase (requires external* CTs)	NO	NO	NO	ICI29VM-XT-3S-5J-120to480V-20A
4S	6	120/240V L-L	20	3w (Requires external* CTs)	NO	NO	NO	ICI29VM-ST-4S-6J-240V-20A
	6	120/240V L-L	20	3w (Requires external* CTs)	YES	NO	NO	ICI29VM-ST-4S-6J-240V-20A-PO
	6	120-347V L-N	20	Autoranging,3w (Requires external* CTs)	NO	NO	NO	ICI29VM-XT-4S-6J-120to480V-20A
5S	8	120-347V L-N Autoranging	20	3w 2 element, (requires external* CTs)	NO	NO	NO	ICI29VM-XT-5S-8J-120to480V-20A
	8	120-347V L-N Autoranging	20	3w 2 element, (requires external* CTs)	YES	NO	NO	ICI29VM-XT-5S8J-120/480V-20A-PO
6S	13	120-347V L-N Autoranging	20	4w,(requires external* CTs)	NO	NO	NO	ICI29VM-XT-6S13J-120/480V-20A
	13	120-347V L-N Autoranging	20	4w,(requires external* CTs)	YES	NO	NO	ICI29VMXT-6S13J-120/480V-20A-PO
9S	13	120-347V L-N Autoranging	20	4w,(requires external* CTs)	NO	NO	NO	ICI29VM-XT-9S13J-120/480V-20A
	13	120-347V L-N Autoranging	20	4w,(requires external* CTs)	YES	NO	NO	ICI29VMXT-9S13J-120/480V-20A-PO
12S	5	120/208V L-N	200	3w 2 element	NO	YES	NO	ICI29VM-ST-12S-5J-120V-200A-S
	5	120/208V L-N	200	3w 2 element	NO	CHECK METER (meter is approved but not sealed)	NO	ICI29VM-ST-12S-5J-120V-200A
	5	120/208V L-N	200	3w 2 element	YES	NO	NO	ICI29VM-ST-12S-5J-120V-200A-PO
	5	120/208V L-N	200	3w 2 element	NO	NO	RF	ICI29VM-ST-12S-5J-120V-200A-RF
	5	120/208V L-N	200	3w 2 element	NO	YES	RFS	ICI29VM-ST-12S-5J-120V-200A-RFS
	5	120-347V L-N Autoranging	200	3w 2 element	NO	NO	NO	ICI29VM-XT-12S-5J-120/480V-200A
	5	120-347V L-N Autoranging	200	3w 2 element	YES	NO	NO	ICI29VM-XT-12S-5J120/480V200APO
16S	7	120-347V L-N Autoranging	200	3ph 4w	NO	YES	NO	ICI29VMXT-16S7J-120/480V-200A-S
	7	120-347V L-N Autoranging	200	3ph 4w	NO	CHECK METER (meter is approved but not sealed)	NO	ICI29VMXT-16S-7J-120to480V-200A
	7	120-347V L-N Autoranging	200	3ph 4w	YES	NO	NO	ICI29VMXT-16S7J-120/480V-200A-PO
	7	120-347V L-N Autoranging	200	3ph 4w	NO	NO	ARF	ICI29VMXT-16S7J-120/480V-200A-ARF
	7	120-347V L-N Autoranging	200	3ph 4w	NO	YES	ARFS	ICI29VMXT-16S7J-120/480V-200A-ARFS

Other forms are available upon request

* external CTs must be instrument CTs