

TEST CERTIFICATE
DOULTON STERASYL CANDLE

Object

To assess the performance capability of a Doulton Sterasyl candle to remove *Shigella* from a contaminated water supply. *Shigella sonnei* was used as a surrogate to represent all *Shigella* species, particularly *Shigella dysenteriae*.

Protocol

The test was designed to give a severe intensive challenge over a significant volume of throughput.

Water conditions - dechlorinated mains water spiked as follows:-

Minimum challenge - 6.14×10^5 cfu/100ml.
Mean Challenge (Geometric) - 7.2×10^5 cfu/100ml (721518)
Cultured organisms for use as a bacterial challenge were prepared as per the US EPA protocol.
Temperature - $20 \pm 2^\circ\text{C}$.
TOC - Approx 2 mg/l.
Turbidity - Low.
Cycle Time - 3 mins on, 9 mins agitation overnight.

Results


Day	Influent (cfu/100ml)	Effluent (cfu/100ml)	% Removal efficiency
1	722727	<1	>99.99986
2	666667	<1	>99.99985
3	881818	<1	>99.99989
4	613636	<1	>99.99984
5	750000	<1	>99.99987

Conclusions

Based on the above result the Doulton Sterasyl candles are capable of removing *Shigella* from a contaminated source to an efficiency of >99.999%.

The average efficiency over the test was 99.99986%.

signed



Date 27/11/15