

🕂 WARNING

PLEASE READ ALL INSTRUCTIONS BEFORE ATTEMPTING INSTALLATION

- To prevent personal injury or product damage only licensed electricians should install.
- To avoid electric shock or component damage disconnect power before attempting installation or servicing.
- This product must be installed in accordance with the national electric code (NEC) and all applicable federal, state and local electric codes and safety standards.
- Disconnect product and allow cooling prior to servicing.
- Any alteration or modification of this product is expressly forbidden as it may cause serious personal injury, death, property damage and/or product malfunction.
- To prevent product malfunction and/or electrical shock this product must be properly grounded.
- This luminaire is designed to operate in ambient temperatures ranging from -30°c to 40°c and to be horizontally mounted with the LEDs facing down.
- Wall mount only.

1 Junction box Mounting


- 1. Loosen screws and remove the front lens set carefully from the back plate.
- 2. Drill appropriate knockouts (B) for wiring, the fixture supports standard 3

1/4" and 4"Junction box.

- 3. Attach the back plate on the wall, use the supplied gaskets for a weather tight seal.
- 4. Finish wiring (Black for Line, White for Neutral and Yellow Green for Ground).
- 5. Replace the lens set on the hinges, make connections and close the lens set then tighten the screws.

2 Conduit Mounting

- 1. Loosen screws and remove the front lens set carefully from the back plate.
- 2. Remove 1/2" plug from where you intend to feed conduit .
- 3. Drilling out the holes (C) to secure it on the wall with choosing proper screws.
- 4. Finish wiring (Black for Line, White for Neutral and Yellow Green for Ground).
- 5. Replace the lens set on the hinges, make connections and close the lens set then tighten the screws.




 A - 1/2" NPS tapped holes (surface conduit or photo control)
B - 3/4" dia. Screw hole

Server Constraints of the server of the serv

PHOTOCELL INSTALLATION

Universal voltage driver permits operation at 120V to 277VAC, 60 Hz except fixtures factory ordered with a 120V photocell (P1) or 277V photocell (P2) or 347V photocell (P3)

- 1. Install photocell and wire as per diagram.
- 2. Use photocell rated for your supply voltage.



TROUBLESHOOTING

- 1. Check that the line voltage at the fixture is correct. Refer to wiring directions.
- 2. Is the fixture grounded properly?
- 3. Be sure the photocell, if used, is functioning properly.