

0630 PRAIRIE II SERIES

SPECIFICATIONS

GENERAL

The 0630 Prairie fixture is a medium scale, dramatic Wrightian / Mission squared edge design. It features a tall, straight four-sided decorative cast cage, a unique tree design grille, cast ballast housing assembly, acrylic lens and a dramatic cantilever roof design. The roof shall be appointed with an aluminum ring finial.

POST FITTER

The fitter or base shall be heavy wall cast aluminum, 319 alloy for high tensile strength. It shall have an inside diameter opening to accept a 3", 4" or 5" round or square pole or tenon. When ordered with a Sternberg aluminum pole, the fitter shall be set screwed to the pole top or tenon.

Smaller Version of 1230 Model Cast Aluminum Roof and Body Stylized Tree Design Type 3 or Type 5 Refractor Photocell (Optional) Post Fitter

EPA = 1.88 (ft²) WEIGHT = 25 LBS

BALLAST HOUSING

The ballast housing shall be heavy wall cast aluminum, 319 alloy for high tensile strength. The housing shall be mounted to the fix-

ture with four screws and to include a water gasket ring to prevent water entry into the ballast compartment. The ballast shall be attached to the ballast housing

to ensure high capacity heat sinking of ballast temperatures, keeping the ballast cooler and ensuring long life.

ELECTRICAL

Fixture shall be U.L. or E.T.L. listed. H.I.D. ballasts shall be high power factor with lamp starting down to -30 degrees C. Medium base and mogul base porcelain sockets are 4KV rated. The ballast/socket assembly shall be pre-wired when ballast is located in the fixture. All compact fluorescent (PL) ballasts shall be instant start electronic with a starting temperature of down to 0 degrees F. They shall have a 4-pin socket to accept quad or triple tube lamps. Ballasts shall be DOE EISA compliant.

FIXTURE HOUSING

The 0630 fixture shall be 16" wide and the overall height shall be 25". It shall be made of heavy wall cast aluminum, 319 alloy and lenses will be made of vandal resistant acrylic, available in white (WA), clear seeded (CSA), clear (CA), clear textured (CTA), prismatic (PA) acrylic and art glass (AGB). The 0630 fixture features a cast 8" wide window body with cast tree design grille work. The cast 16" square roof shall cantilever the fixture body and have a solid aluminum soffit with 8 cast corner braces. The entire fixture shall be made of cast aluminum, 319 alloy.

OPTICAL OPTIONS

Refractors shall be 5" diameter borosilicate glass with an I.E.S. Type 3 (RE3) or Type 5 (RE5) distribution. It shall be secured to the socket stem with $^{3}/8$ " plated steel threaded pipe nipple and rest on a cast aluminum holder with anti-shock gasket. The refractor will be secured to cast holder with a quarter-turn internal aluminum twist ring for ease of maintenance.

LIST NO. 0630 PRAIRIE II SERIES **Frosted Glass Mission Chimney** (FMC) is an optic option which adds an authentic Mission touch. **House Side Shield** (HSS) is an option which will block up to 120° of light in any one direction.




0630 PRAIRIE II

FIXTURES/FITTERS/ARMS PM-WB

Chain Hung

Stem Hung



SternbergLighting

BUILDING A PART NUMBER

POST & ARM FIXTURES

CENTER ARM MOUNTED FIXTURE POST TOP FIXTURE (PT)

LIGHT SOURCE POST POST CAP BALLAST

OPTICS OPTIONS LENS

FINISH

OF ARMS FIXTURE/POSTARM FIXT./FITTER

(See Post Section)

WATTS / TYPE / VOLTS

PT 0630/S4

4SQ10

OPTICS

100 MHP120

PEC

WA

BKT



WALL FIXTURES

LIGHT SOURCE FIXTURE / WATTS/TYPE/VOLTS WALL BRACKET

BALLAST

OPTIONS

MHP100/MED

LENS

WA

FINISH




PIER FIXTURES

Uses same information boxes as wall fixture

0630/P2PB

FIXTURE / PIER BASE



HANGING FIXTURES

FIXTURE / HANGING BRACKET

0630/HMA2WB

OVERALL DROP IN INCHES

WALL

ARMS

LIGHT SOURCE **BALLAST** WATTS/TYPE/VOLTS **OPTICS**

OPTIONS

BKT

LENS

FINISH

0630/HCH44

96 INCHES

100 MHP120

100 MHP120

RE3

MHP100/MED

CA

BKT

PART NUMBER SELECTIONS

FIXTURES • 0630

FITTERS

R3

R4

S4

S5

OPTICS

RE3

RE5

HSS

• FMC²

RO3

RO5

R5

POST ARMS

· HMA2 single

HMA2 twin

 HCF2 single HCF2 twin

VOLTAGES

120

208

• 240

277

480

MULTI

(120 - 277)

PIER BASE

BRACKET

HMA2WB

P2PB

LENSES

CA

CSA

• CTA

PA

WA

AGB

HANGING

HCH44

HSH44

BRACKETS

BALLASTS^{3,4}

35HPS¹

50HPS

70HPS

100HPS

• 50MHP

70MHP

100MHP

26PLT 32PLT

42PLT

INCAND

LAMPS 4

HPS35/MED

HPS50/MED

HPS70/MED

HPS100/MED

MHP50/MED

MHP70/MED MHP100/MED

PLT26 PLT32

PLT42

STANDARD FINISHES*

 BKT **Black Textured**

WHT White Textured

 PGT Park Green Textured

Architectural Medium ABZT **Bronze Textured**

 DBT **Dark Bronze Textured**

*Smooth Finishes are available upon request

CUSTOM FINISHES

 OI Old Iron

RT Rust

WBR Weathered Brown

CD Cedar

WBK Weathered Black

TT Two Tone

STERNBERG SELECT **FINISHES**

 VG Verde Green

 SI Swedish Iron

OWGT Old World Gray Textured

OPTIONS

• PEC Photocell-Electronic 120-277 Volt

FHS Single Fuse and Holder-120,277 Volt

FHD Dual Fuse and Holder-208,240,480V

QR Quartz Re-Strike

· LAMPS Select from List

NOTES:

135HPS is 120 volt only. ² MED base only when used

watts for HID. 4-pin for PL. ⁴ Metal halide systems are to house lamp.

3 Medium base sockets stand-

pulse start.

ard with ballasts up to 100





0630 PRAIRIE II SERIES

SPECIFICATIONS

LIST NO. 0630 PRAIRIE II SERIES

QUARTZ RE-STRIKE

The 0630 fixture can be supplied with an optional quartz re-strike system to retain constant fixture light if the H.I.D. lamp fails. The fixture will be equipped with a 100 watt quartz lamp and a controller to run on a 120 volt circuit and must be used in conjunction with a 120 volt or multi-tap ballast.

PHOTOCELLS

Photocells shall be the electronic button type. On single post top fixtures the photocell shall be mounted in the fitter and pre-wired to ballast. On multiple head fixture assemblies photocells shall be mounted in the pole shaft on an access plate and are not pre-wired as ballast housing assemblies and fitters are packaged separately for ease of wiring to source. The electronic button type photocell is instant on and a 5-10 second turn off and shall turn on at 1.5 footcandles with a turn-off at 2-3 footcandles. Photocells are 120-277 volt.

ARMS

All arms are made of cast aluminum and/or extruded aluminum. Arms with decorative filigree have meticulously detailed scroll work and gracefully curved brackets. All 0630 fixtures shall be bolted to the arm to ensure arms will be plumb, secure and level over the life of the installation.

FINISH

Prior to coating, each assembly shall be chemically cleaned and etched in a 5-stage washing system which includes alkaline cleaning, rinsing, phosphoric etching, reverse osmosis water rinsing, and non-chrome sealing to ensure corrosion resistance and excellent adhesion for the finish coating. The finish coating shall be electrostatically applied semi-gloss, super durable polyester powder baked at 400 degrees for a durable and superior, color retentive finish. Our optional antique Verde Green finish and Swedish Iron finish are hand brushed using a 3-step process. The total assembly shall be wrapped in shockproof wrapping or fully enclosed in corrugated cartons.

WARRANTY

Five-year limited warranty. See product and finish warranty guide for details.



