

## 7701B BIRMINGHAM UNLIT BOLLARD

## **SPECIFICATIONS**

### **GENERAL**


The Model 7701B decorative unlit bollard shall be cast aluminum, one-piece construction. The 16" diameter cast aluminum base shall be constructed with a 7<sup>1</sup>/4" diameter straight fluted cast aluminum shaft. The Model shall be Sternberg Lighting #7701B unlit bollard or #7701B-**QR** quick release unlit bollard.

### CONSTRUCTION

The base shall be designed with a tall and smoothly curved pedestal bottom section and transition to a tall twelve flute vertical base section and be made of heavy wall, 356 alloy cast aluminum. It shall have a 1" thick floor cast as an integral part of the base. The bollard cap shall be welded in place. The overall height of the bollard shall be 51".

## **QUICK RELEASE MOUNTING (Optional)**

The Model 7701B-QR shall have a quick release option which allows quick removal of the bollard for convenience or emergency access. The burial portion shall be made of ASTM 6061 aluminum extrusion and shall have a keyway and flexible connection system for securing to bollard. The bollard shall have a mated extension and anti-rotation key and padlock slot. The quick release system shall allow for a flush pavement installation after temporary bollard removal.



See installation template for exact door position

### **FINISH**

Prior to coating, each assembly shall be chemically cleaned and etched in a 5-stage washing system which includes alkaline cleaning, rinsing, phosphoric etching, reverse osmosis water rinsing, and non-chrome sealing to ensure corrosion resistance and excellent adhesion for the finish coating. The finish coating shall be electrostatically applied semi-gloss, super durable polyester powder baked at 400 degrees for a durable and superior, color retentive finish. Our optional antique Verde Green finish and Swedish Iron finish are hand brushed using a 3-step process. The total assembly shall be wrapped in shockproof wrapping or fully enclosed in corrugated cartons.

### **INSTALLATION**

Four, hot dipped galvanized "L" type anchor bolts shall be provided with the post for non-quick release bollard anchorage. Quick release anchorage requires no anchor bolts. A door shall be provided for anchor bolt access. It shall be secured with tamper-proof, stainless steel hardware.

Five-year limited warranty. See product and finish warranty guide for details.

### **BUILDING A PART NUMBER** PART NUMBER SELECTIONS OPTIONAL STERNBERG SELECT **BOLLARD** CHAIN **OPTIONS** FINISH **MODELS\*** STANDARD FINISHES\* MODEL **FINISHES** Black Textured • 7701B BKT VG Verde Green • 7701B-QR WHT White Textured CL2 7701B VG SI Swedish Iron PGT Park Green Textured . OWGT Old World Gray Textured Architectural Medium ABZT **OPTIONAL** Bronze Textured **CHAIN LOOP\*\*** DBT Dark Bronze Textured CL1 \*Smooth Finishes are available upon request Chain Loop **CUSTOM FINISHES** CL2 Chain Loops 180º OI Old Iron • RT Rust \*\* TO ORDER CHAIN: • WBR Weathered Brown Specify total length of CD Cedar chain required for project. • WBK Weathered Black TT Two Tone



## 7701LB BIRMINGHAM LIGHTED BOLLARD SPECIFICATIONS

### **GENERAL**

The Model 7701LB decorative lighted bollard shall be cast aluminum, one-piece construction. The 16" diameter cast aluminum base shall be constructed with a 7 <sup>1</sup>/4" diameter straight fluted cast aluminum shaft. The Model shall be Sternberg Lighting #7701LB lighted bollard or #7701LB-**QR** quick release lighted bollard.

### **CONSTRUCTION**

The base shall be designed with a tall and smoothly curved pedestal bottom section and transition to a tall twelve flute vertical base section and be made of heavy wall, 356 alloy cast aluminum. It shall have a 1" thick floor cast as an integral part of the base. The bollard cap shall be welded in place. The overall height of the bollard shall be 51".

The optical assembly shall be constructed of twelve fluted openings with a white acrylic lens. All electrical components shall be U.L. approved. H.I.D. ballasts shall be high power factor with lamp starting down to -30degrees C. Medium base porcelain sockets to be 4KV rated. The ballast/ socket assembly shall be pre-wired. Optional compact fluorescent (PL) ballasts shall be instant start electronic with a starting temperature of down to 0 degrees F. They shall have a 4-pin socket and support quad tube and triple tube lamps. Ballasts shall be DOE EISA compliant.

## QUICK RELEASE MOUNTING (Optional)

The Model 7701LB-QR shall have a quick release option which allows quick removal of the bollard for convenience or emergency access. The

burial portion shall be made of ASTM 6061 aluminum extrusion and shall have a keyway and flexible connection system for securing to bollard. The bollard shall have a mated extension and anti-rotation key and padlock slot. The quick release system shall allow for a flush pavement installation after temporary bollard removal.

# Optional Chain Loops STREET SIDE 51 BOLT CENTER LINE ACCESS DOOR

Weathered Brown

Weathered Black

Cedar

Two Tone

Verde Green

Swedish Iron

See installation template for exact door position.

### **FINISH**

Prior to coating, each assembly shall be chemically cleaned and etched in a 5-stage washing system which inc-ludes alkaline cleaning, rinsing, phosphoric etching, reverse osmosis water rinsing, and non-chrome sealing to ensure corrosion resistance and excellent adhesion for the finish coating. The finish coating shall be electrostatically applied semi-gloss, super durable polyester powder baked at 400 degrees for a durable and superior, color retentive finish. Our optional antique Verde Green finish and Swedish Iron finish are hand brushed using a 3-step process. The total assembly shall be wrapped in shockproof wrapping or fully enclosed in corrugated cartons.

SternbergLighting

ESTABLISHED 1923 / EMPLOYEE OWNED

Four, hot dipped galvanized "L" type anchor bolts shall be provided with the post for non-quick release bollard an-chorage. Quick release anchorage requires no anchor bolts. A door shall be provided for wiring and anchor bolt access. It shall be secured with tamper-proof, stainless steel hardware. Bollard will be provided with a grounding stud mounted on the base floor opposite the access door.

**WARRANTY** Five-year limited warranty. See product and finish warranty guide for details.

### **BUILDING A PART NUMBER** PART NUMBER SELECTIONS OPTIONAL LIGHT SOURCE • WBR **BALLASTS LAMPS** STANDARD FINISHES\* CHAIN BOLLARD MODEL **OPTIONS** BALLAST WATTS/TYPE/VOLTS FINISH CD 35HPS Black Textured HPS35/MFD BKT WRK • 50HPS • HPS50/MED WHT White Textured 7701LB CL2 **FHS** 50HPS120 VG 70HPS • HPS70/MED • PGT Park Green Textured TT Architectural Medium 100HPS HPS100/MED ABZT STERNBERG SELECT Bronze Textured 50MHP • MHP50/MED **FINISHES** • DBT Dark Bronze Textured 70MHP MHP70/MFD • VG **MODELS** \*Smooth Finishes are available upon request 100MHP • MHP100/MED SI 7701LB 26PLT PLT26 **CUSTOM FINISHES** · OWGT Old World Gray Textured 7701LB-QR 32PLT PLT32 0I Old Iron 42PLT • PLT42 • RT Rust \*\* TO ORDER CHAIN: INCAND Specify total length of chain required for project. **OPTIONAL VOLTAGES** • PEC1 Photocell-Bimetal 120 Volt · FHD Dual Fuse and CHAIN LOOP\*\* • 120 MHP- Metal halide • PEC2 Photocell-Bimetal 208-277 Volt Holder-208, 240, 480 Volt systems are pulse start 208 • PEC1-E Photocell-Electronic 120 Volt · GFI Ground Fault • CL1 • 240 PEC2-E Photocell-Electronic 208-277 Volt Interrupter Duplex Outlet<sup>1</sup> Chain Loop • 277 • FHS Single Fuse and Holder-120,277 Volt • LAMPS Select from List CL2 Chain • 480 <sup>1</sup>GFI not available with QR option Loops 180º MULTI

555 Lawrence Ave. Roselle, IL 60172 • 847-588-3400 • Fax 847-588-3440 www.sternberglighting.com Email: info@sternberglighting.com 7-15