

# Electric underfloor heating resistance test results



Comfortzone electric underfloor heating must be tested and registered online to qualify for the 10 year warranty

Your customer will need to submit resistance data online in order to register their 10 year warranty. Please make sure you complete **all** of the tests below and **fill out the entire form** and give a copy to your customer to ensure a smooth handover. Do not post this form. Please complete the warranty registration online - [www.comfortzone.co](http://www.comfortzone.co)

Underfloor heating resistance test results				Conductor to conductor			Conductor to earth			
Room Reference	Stock No.	Size (m <sup>2</sup> )	Connection wire extension?	Test A	Test B	Test C	Test A	Test B	Test C	
0	Example	8527	10m <sup>2</sup>	No	35.3	35.2	35.3	open	open	open
1										
2										
3										
4										
5										
6										

### Installer Details

Name: .....

Email: .....

Phone: .....

Part P No: .....

Address: .....

Postcode: .....

Signed: .....

### Customer Details

Name: .....

Email: .....

Phone: .....

Address: .....

Postcode: .....

Signed: .....

### Testing Guidance

You should test each mat/cable 3 times:

Test A before laying the mat.  
 Test B before laying the floor finish.  
 Test C after completing the floor finish.

Make sure you test conductor to conductor (which will give you a resistance reading)

And also test conductor to earth (which should read open circuit).

**PLEASE DO NOT POST THIS FORM TO US. The customer must fill in the warranty application form on [www.comfortzone.co](http://www.comfortzone.co)**

The Comfortzone heating mat ten year warranty against manufacturer defects is a limited liability warranty. In the event of a problem with your installation contact your Comfortzone stockist. Take photographs of installation at all 3 stages of installation for your records. Terms and conditions apply.