



Declaration of conformity

For the following equipment :

Product Name: Switching Power Supplies

Model Designation: APC-x-y (x=12, y=240OL, 350, 700; x= 16, y=350, 700)
APV-x-y (x=12, 16; y=5, 12, 15, 24)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

RoHS Directive (2011/65/EU)

Low Voltage Directive (2014/35/EU) :

EN60950-1:2006+A11:2009+A1:2010+A12:2011+A2:2013

BV report No : LD150819N051 for APC series
Nemko CB certificate No : 82891 for APV series

Electromagnetic Compatibility Directive (2014/30/EU) :

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

EN55022:2010

Class B

Harmonic current

EN61000-3-2: 2014

Voltage flicker

EN61000-3-3: 2013

EMS (Electro-Magnetic Susceptibility)

EN55024:2010

ESD air

EN61000-4-2:2009

Level 3 8KV

ESD contact

EN61000-4-2:2009

Level 2 4KV

RF field susceptibility

EN61000-4-3:2006+A1:2008+A2:2010

Level 2 3V/m

EFT bursts

EN61000-4-4:2012

Level 2 1KV/5KHz

Surge susceptibility

EN61000-4-5:2014

Level 3 2KV/Line-Line

Conducted susceptibility

EN61000-4-6:2014

Level 2 3V

Magnetic field immunity

EN61000-4-8:2010

Level 2 3A/m

Voltage dip, interruption

EN61000-4-11:2004 >95% dip 0.5 periods 30% dip 25 periods >95% interruptions 250 periods

Note:

Component power supply will be operated with a final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

This Declaration is effective from serial number HB6xxxxxx

Person responsible for marking this declaration :

MEAN WELL (Guangzhou) Electronics Co., Ltd.

(Manufacturer Name)

2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District, Guangzhou, China

(Manufacturer Address)

Howay_Lin/ Engineering Manager :

(Name / Position)

Howay Lin
(Signature)

Frank_Peng/ RD Manager :

(Name / Position)

Frank Peng
(Signature)

GuangZhou

(Place)

Apr. 20, 2016

(Date)