The Falls Bldg, 3304 Sawgrass Village Circle, Ponte Vedra Beach, FL 32082, 800-997-2443, Fax: 904-543-1330

The Falls Bldg, 3304 Sawgrass Village Circle, Ponte Vedra Beach

SUBMERSIBLE PUMP CABLE

INSULATION: RUBBER (RHW)
600 VOLTS

JACKET: HEAVY DUTY COLORED (CPE) 75C

SIZES: 14 AWG to 2 AWG

2,3 CONDUCTOR WITH OR WITHOUT GROUND USE/RHW 12 AWG AND LARGER

1.0 SCOPE:

This specification covers the construction requirements for submersible pump cable rated at 600 volts at operating temperatures up to 75 C. Individual conductors are insulated with "RHW" rubber and jacketed with colored CPE, and then twisted together. This cable is also suitable for direct burial UL labeled as follows: Sizes 14 AWG as "Submersible Pump Cable"; 12AWG to 2AWG as "USE-RHW" and "Submersible Pump Cable"

2.0 CONSTRUCTION:

2.1 2 & 3 CONDUCTORS - WITHOUT GROUND

SIZE AWG	STRANDING	INSULATION WALL	JACKET WALL	OVERALL DIAMETER	WEIGHT	AMPAC.	
14/2	SOLID	.045"	.030"	.440"	67	15	2
12/2	SOLID	.045"	.030"	.490"	90	20	1
10/2	SOLID	.045"	.030"	.520"	120	30	1
8/2	SOLID	.060"	.030"	.680"	210	50	۔ ا
14/3	SOLID	.045"	.030"	.460"	105	15	2
12/3	SOLID	.045"	.030"	.520"	135	20	
10/3	SOLID	.045"	.030"	.560"	180	30	1
8/3	SOLID	.060"	.030"	.740"	328	50	2
6/3	19 x .0372"	.060"	.030"	.820"	447	65	1
4/3	19 x .0469"	.060"	.030"	.920"	630	85	1
2/3	19 x .0591"	.060"	.030"	1.080"	860	115	

2.2 2 & 3 CONDUCTORS - WITH GROUND

SIZE	STRANDING	GROUND	INSULATION	JACKET	OVERALL	WEIGHT	AMPAC.	2.7
AWG		SIZE	WALL	WALL	DIAMETER			
14/2G	SOLID	14	.045"	.030"	.506"	120	15	2.8
12/2G	SOLID	12	.045"	.030"	.512"	165	20	2.0
10/2G	SOLID	10	.045"	.030"	.559"	207	30	
8/2G	SOLID	10	.060"	.030"	.640"	348	50	
14/3G	SOLID	14	.045"	.030"	.550"	150	15	
12/3G	SOLID	12	.045"	.030"	.575"	206	20	
10/3G	SOLID	10	.045"	.030"	.626"	250	30	2.9
8/3G	SOLID	10	.060"	.030"	.750"	443	50	
6/3G	19 x .0372'	' 8	.060"	.030"	.875"	607	65	
4/3G	19 x .0469'	' 8	.060"	.030"	1.000"	879	85	
2/3G	19 x .0591'	' 6	.060"	.030"	1.200"	1420	115	

Note: grounds have identical strandings, insulation and jacketing thickness.

2.3 Conductors:

Soft drawn bare copper conforming to ASTM B-3. Stranding shall conform to ASTM B-8.

2.4 Insulation:

UL RHW, 75 C, rubber, conforming to UL standard 44.

2.5 Jacket:

UL heavy duty CPE, colored, conforming to UL standard 44.

2.6 Color Code:

Jacket colored as follows:
2/C cables: BLACK/YELLOW
3/C cables: BLACK/YELLOW/GREEN
4/C cables: BLACK/YELLOW/RED/GREEN

Assembly:

Two, three or four jacketed conductors are twisted together in a suitable lay.

2.8 Marking:

Ink print jacket surface:
"Size AWG Type USE or Type RHW
600 Volts Paige Electric Corp. (UL)
Submersible Pump Cable.

2.9 Testing:

Physical and Electrical tests in accordance with the requirements of Underwriters' Laboratories standards 44 and 854 for Type USE/RHW Submersible Pump Cables.