



Member of the FM Global Group

FM Approvals  
1151 Boston Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

**Electronic Weighing Balances Models: EK300EP, EK300EP-K, EK3000EP, EK12KEP, EK3000EP-K, EK12KEP-K**

IS / I / 1 / C,D/ T3C; Ex ia IIB T3;

Specific Conditions for use:

1. The Electronic Weighing Balances shall only be used with four Energizer AA E91 alkaline LR6 AM3, or Duracell AA alkaline MN1500 LR6, or Panasonic AA alkaline LR6(XJ) 1.5V batteries.
2. The apparatus enclosure contains accessible metal parts and could be susceptible to electrostatic charges that could be a source of ignition. The user must consider a 170pF capacitance when considering suitability for use. Refer to IEC TS60079.32-1 for guidance.
3. Part of the enclosure is constructed of plastic. To prevent the risk of electrostatic sparking the non-metallic surface should only be cleaned with a damp cloth.

### Equipment Ratings:

Intrinsically Safe for Class I, Division 1, Groups C, D, Hazardous Locations and Intrinsically Safe for Class I, Zone 0, Group IIB hazardous locations. T3C;  
-25°C ≤ Ta ≤ 40°C.

### FM Approved for:

A&D Company, Limited  
Kitamoto-shi, Saitama Japan



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

CSA C22.2 No. 1010.1	2004
CAN/CSA C22.2 No 60079-0	2011
CAN/CSA C22.2 No 60079-11	2014

Original Project ID: 3054278

Approval Granted: September 1, 2015

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

J.E. Marquedant  
Manager of Electrical Systems

1 September 2015

Date