Item Number: MMBP



Installation Guide

Load Bypass Device

Introduction

The Diginet Load Bypass Device is designed to provide improved dimming performance of some LED's and CFL's when used in conjunction with Diginet 2-wire dimmer/timer/switch products. The device overcomes the following issues seen when controlling some LED or CFL light sources:

- When switched off, the LED/CFL lights flicker, pulse on/off or do not switch off completely
- When switching on, the LED/CFL lights have difficulty turning on and the dimmer indicators flicker or pulse




This product must be installed by a suitably qualified installer in accordance with standard safety procedures for mains-powered electrical equipment.

For more detailed information on the use of this product please see the datasheet on the Diginet web site. <u>www.diginet.net.au</u>

Installation

The Load Bypass Device is installed in parallel with the load, across the switched Active and Neutral, as shown in the diagram below.



Specifications

a	
Operating Voltage	220-240Vac 50Hz
	100mW
Power Dissipation	(Note: The device power dissipation is independent of the
	connected lighting load power)
Max Ambient	t₂max = 70°C
Temperature	
Operating Humidity	10% - 95% RH, non-condensing
Standards Compliance	AS/NZS CISPR15:2011
	AS/NZS 61347-2-11:2003
	IEC 61347-2-11
Dimensions	49mm x 15mm x 11mm
Connection Lead	Two core, double insulated, crimped ends
Туре	Switched Active and Neutral connections
Connection Lead	300mm
Length	

© Copyright Gerard Lighting Pty Ltd

The identified trademarks and copyrights are the property of Gerard Lighting Pty Ltd unless otherwise noted.

Printed on recycled paper



Product of Gerard Lighting Pty Ltd

ABN – 89 095 788 864 96-112 Gow Street Padstow NSW 2211 Diginet is a brand of Gerard Lighting Pty Ltd

Contact

General Enquiries: 1300 95 DALI (3254) or <u>sales@diginet.net.au</u> Technical Services: 1300 95 3244 or <u>support@diginet.net.au</u> Fax: 1300 95 3257

Issue 1 June 2016

14-14-031A-01-01

DIGINET.NET.AU