

CENELEC CERTIFICATION AGREEMENT

Accord de Certification du CENELEC • CCA • CENELEC-Zertifizierungs-Abkommen

NOTIFICATION OF TEST RESULTS

Product Connection Clamps (Screwless)

Tested by request of WAGO Kontakttechnik GmbH.,
Postfach 2880, D-32385 Minden, Germany.

Manufactured at (name and place) See page 2.

Rating and principal characteristics **1.5 mm², 17.5 A, 400 V, 2.5 mm², 24 A, 500 V,
2.5 mm², 24 A, 800 V, 4 mm², 32 A, 630 V.**

Trade mark (if any) WAGO

Model/Type Ref. **260-..., 261-..., 262-... and 264-...**

Additional information (if any) **This product is covered by the license of the ®-mark.**

A sample of the product has been tested and found to be in conformity with the current HD/EN and equivalent national standard (number and edition):

EN 60998-2-2 1993.

as shown in the test report (reference No.) **120039/-01, /-02, /-03, /-04.**

This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with provisions of the relevant specific standard.

This notification of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983. Any other body participating in it will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA, as long as the standard referred to above is still in force in the country of that body. This Notification of Test Results may be challenged if it is more than 3 years old.

Date **1996-04-22**

Signature



PO box 514, Lyskaer 8
DK 2730 Herlev • Denmark
Telephone +45 44 94 72 66
Telefax + 45 44 94 72 61

Internal Ref. **B. Ostermann.**

DEMKO
Testing and Certification

Discription: Connection devices as separate entities with screwless-type clamping units.

type: **260-... 1.5 mm², 17.5 A, 400 V.**
Terminal blocks with fixing flange or snap-in mounting foot.
2 or 4 conductors terminal blocks.
Colour: Grey, Light grey, Blue, Orange or Green-Yellow.
Test report No. 120039/-01, date 1996-04-22.

type: **261-... 2.5 mm², 24 A, 500 V.**
Terminal blocks with fixing flange or snap-in mounting foot.
With or with out push-bottom on one or both side.
2 or 4 conductors terminal blocks.
Colour: Grey, Light grey, Blue, Orange or Green-Yellow.
Test report No. 120039/-02, date 1996-04-22.

type: **262-... 4 mm², 32 A, 630 V.**
Terminal blocks with fixing flange or snap-in mounting foot.
2 or 4 conductors terminal blocks.
Colour: Grey, Light grey, Blue, Orange or Green-Yellow.
test report No. 120039/-03, date 1996-04-22.

type: **264-... 2.5 mm², 24 A, 800 V.**
Terminal blocks with fixing flange, snap-in mounting foot or
mounting on DIN rail type TS 35 or TS 15.
2 or 4 conductors terminal blocks.
Colour: Grey, Light grey, Blue, Orange or Green-Yellow.
Test report No. 120039/-04, date 1996-04-22.

This certificate covers screwless connection clamps type 26x-... followed by various numbers for customer specified variations. (see the relevant test reports).

Manufactured at (name and place):

WAGO Kontakttechnik GmbH.
Postfach 2880
D-32385 Minden,
Germany.

WAGO Contact GmbH.
Postfach 109
D-99702 Sondershausen,
Germany.

WAGO Contact SA.
Case postale 168
CH-1564 Domdidier,
Switzerland.